

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 28 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τετάρτη, 28 Μαΐου 2025	00:00	0,824						1	
	01:00	0,770						1	
	02:00	0,742						1	
	03:00	0,725						1	
	04:00	0,705						1	
	05:00	0,729						1	
	06:00	0,762						1	
	07:00	0,845						1	
	08:00	0,909						1	
	09:00	1,025					1	1	
	10:00	1,055					1	1	
	11:00	1,084					1	1	
	12:00	1,036					1	1	
	13:00	1,041					1	1	
	14:00	1,048					1	1	
	15:00	1,073					1	1	
	16:00	1,001					1	1	
	17:00	1,057					1	1	
	18:00	1,117					1	1	
	19:00	1,237					1	1	
	20:00	1,249					1	1	
	21:00	1,280					1	1	
	22:00	1,154					1	1	
	23:00	0,972					1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 29 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Πέμπτη, 29 Μαΐου 2025	00:00	0,858						1	
	01:00	0,805						1	
	02:00	0,791						1	
	03:00	0,752						1	
	04:00	0,761						1	
	05:00	0,776						1	
	06:00	0,805						1	
	07:00	0,857						1	
	08:00	0,965					1	1	
	09:00	1,024					1	1	
	10:00	1,015					1	1	
	11:00	1,010					1	1	
	12:00	1,035					1	1	
	13:00	1,072					1		1
	14:00	1,064					1		1
	15:00	1,040					1		1
	16:00	1,005					1		1
	17:00	1,074					1		1
	18:00	1,147					1		1
	19:00	1,209					1		1
	20:00	1,239					1		1
	21:00	1,255					1		1
	22:00	1,096					1		1
	23:00	0,969					1		1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 30 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η ε π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Παρασκευή, 30 Μαΐου 2025	00:00	0,873					1		1
	01:00	0,820							1
	02:00	0,777							1
	03:00	0,756							1
	04:00	0,743							1
	05:00	0,773							1
	06:00	0,795							1
	07:00	0,888							1
	08:00	0,953					1		1
	09:00	1,015					1		1
	10:00	1,049					1		1
	11:00	1,032					1		1
	12:00	1,063					1		1
	13:00	1,100					1		1
	14:00	1,074					1		1
	15:00	1,090					1		1
	16:00	1,071					1		1
	17:00	1,116					1		1
	18:00	1,178					1		1
	19:00	1,268					1		1
	20:00	1,300					1		1
	21:00	1,308					1		1
	22:00	1,131					1		1
	23:00	0,996					1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 31 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Σάββατο, 31 Μαΐου 2025	00:00	0,902					1		1
	01:00	0,822							1
	02:00	0,816							1
	03:00	0,791							1
	04:00	0,785							1
	05:00	0,806							1
	06:00	0,859							1
	07:00	0,893							1
	08:00	0,988					1		1
	09:00	1,102					1		1
	10:00	1,066					1		1
	11:00	1,105					1		1
	12:00	1,143					1		1
	13:00	1,165					1		1
	14:00	1,161					1		1
	15:00	1,096					1		1
	16:00	1,116					1		1
	17:00	1,162					1		1
	18:00	1,194					1		1
	19:00	1,215					1		1
	20:00	1,310					1		1
	21:00	1,302					1		1
	22:00	1,169					1		1
	23:00	1,018					1		1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 1 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Κυριακή, 1 Ιουνίου 2025	00:00	0,894					1		1
	01:00	0,850							1
	02:00	0,823							1
	03:00	0,797							1
	04:00	0,799							1
	05:00	0,806							1
	06:00	0,810							1
	07:00	0,891					1		1
	08:00	0,931					1		1
	09:00	1,018					1		1
	10:00	1,058					1		1
	11:00	1,094					1		1
	12:00	1,084					1		1
	13:00	1,086					1		1
	14:00	1,070					1		1
	15:00	1,095					1		1
	16:00	1,061					1		1
	17:00	1,100					1		1
	18:00	1,131					1		1
	19:00	1,200					1		1
	20:00	1,274					1		1
	21:00	1,261					1		1
	22:00	1,182					1		1
	23:00	0,994					1		1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 2 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Δευτέρα, 2 Ιουνίου 2025	00:00	0,885							1
	01:00	0,823							1
	02:00	0,772							1
	03:00	0,757							1
	04:00	0,765							1
	05:00	0,765							1
	06:00	0,801							1
	07:00	0,925					1		1
	08:00	0,987					1		1
	09:00	1,083					1		1
	10:00	1,075					1		1
	11:00	1,060					1		1
	12:00	1,080					1		1
	13:00	1,128					1		1
	14:00	1,151					1		1
	15:00	1,098					1		1
	16:00	1,126					1		1
	17:00	1,173					1		1
	18:00	1,212					1		1
	19:00	1,341					1		1
	20:00	1,347					1		1
	21:00	1,394					1		1
	22:00	1,272					1		1
	23:00	1,088					1		1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 3 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τρίτη, 3 Ιουνίου 2025	00:00	0,964					1		1
	01:00	0,903					1		1
	02:00	0,830							1
	03:00	0,815							1
	04:00	0,810							1
	05:00	0,846							1
	06:00	0,848							1
	07:00	0,912					1		1
	08:00	1,043					1		1
	09:00	1,125					1		1
	10:00	1,110					1		1
	11:00	1,145					1		1
	12:00	1,167					1		1
	13:00	1,144					1		1
	14:00	1,181					1		1
	15:00	1,156					1		1
	16:00	1,171					1		1
	17:00	1,208					1		1
	18:00	1,267					1		1
	19:00	1,357					1		1
	20:00	1,403					1		1
	21:00	1,412					1		1
	22:00	1,278					1		1
	23:00	1,103					1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης