

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 1 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Πέμπτη, 1 Μαΐου 2025	00:00	0,916		1					
	01:00	0,857		1					
	02:00	0,807		1					
	03:00	0,781		1					
	04:00	0,768		1					
	05:00	0,764		1					
	06:00	0,802		1					
	07:00	0,826		1					
	08:00	0,866		1					
	09:00	0,917		1					
	10:00	0,948		1		1			
	11:00	0,942		1		1			
	12:00	0,933		1		1			
	13:00	0,923		1		1			
	14:00	0,880		1					
	15:00	0,894		1					
	16:00	0,933		1		1			
	17:00	0,976		1		1			
	18:00	1,030		1		1			
	19:00	1,099		1		1			
	20:00	1,180		1		1			
	21:00	1,170		1		1			
	22:00	1,077		1		1			
	23:00	0,981		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 2 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Παρασκευή, 2 Μαΐου 2025	00:00	0,861		1					
	01:00	0,802		1					
	02:00	0,763		1					
	03:00	0,747		1					
	04:00	0,747		1					
	05:00	0,761		1					
	06:00	0,797		1					
	07:00	0,826		1					
	08:00	0,841		1					
	09:00	0,878		1					
	10:00	0,893		1					
	11:00	0,908		1					
	12:00	0,872		1					
	13:00	0,850		1					
	14:00	0,849		1					
	15:00	0,856		1					
	16:00	0,825		1					
	17:00	0,864		1					
	18:00	0,922		1		1			
	19:00	1,000		1		1			
	20:00	1,096		1		1			
	21:00	1,106		1		1			
	22:00	1,045		1		1			
	23:00	0,968		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 3 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Α	Ρ	Ε	Ε	Ε	Ε	Ε	Ε	Ε	Ε
Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	
Σάββατο, 3 Μαΐου 2025	00:00	0,847		1					
	01:00	0,782		1					
	02:00	0,742		1					
	03:00	0,721		1					
	04:00	0,718		1					
	05:00	0,730		1					
	06:00	0,760		1					
	07:00	0,787		1					
	08:00	0,798		1					
	09:00	0,805		1					
	10:00	0,800		1					
	11:00	0,785		1					
	12:00	0,765		1					
	13:00	0,752		1					
	14:00	0,746		1					
	15:00	0,752		1					
	16:00	0,740		1					
	17:00	0,769		1					
	18:00	0,818		1					
	19:00	0,883		1					
	20:00	0,976		1		1			
	21:00	1,005		1		1			
	22:00	0,980		1		1			
	23:00	0,938		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 4 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Κυριακή, 4 Μαΐου 2025	00:00	0,831		1					
	01:00	0,762		1					
	02:00	0,716		1					
	03:00	0,689		1					
	04:00	0,680		1					
	05:00	0,688		1					
	06:00	0,711		1					
	07:00	0,732		1					
	08:00	0,740		1					
	09:00	0,747		1					
	10:00	0,746		1					
	11:00	0,744		1					
	12:00	0,736		1					
	13:00	0,731		1					
	14:00	0,724		1					
	15:00	0,724		1					
	16:00	0,716		1					
	17:00	0,732		1					
	18:00	0,766		1					
	19:00	0,818		1					
	20:00	0,899		1		1			
	21:00	0,929		1		1			
	22:00	0,919		1		1			
	23:00	0,893		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 5 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Δευτέρα, 5 Μαΐου 2025	00:00	0,758		1					
	01:00	0,694		1					
	02:00	0,658		1					
	03:00	0,643		1					
	04:00	0,646		1					
	05:00	0,666		1					
	06:00	0,700		1					
	07:00	0,721		1					
	08:00	0,717		1					
	09:00	0,726		1					
	10:00	0,728		1					
	11:00	0,714		1					
	12:00	0,713		1					
	13:00	0,714		1					
	14:00	0,723		1					
	15:00	0,772		1					
	16:00	0,732		1					
	17:00	0,754		1					
	18:00	0,785		1					
	19:00	0,842		1					
	20:00	0,925		1		1			
	21:00	0,949		1		1			
	22:00	0,918		1		1			
	23:00	0,867		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 6 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Τρίτη, 6 Μαΐου 2025	00:00	0,723		1					
	01:00	0,674		1					
	02:00	0,652		1					
	03:00	0,651		1					
	04:00	0,662		1					
	05:00	0,687		1					
	06:00	0,721		1					
	07:00	0,744		1					
	08:00	0,728		1					
	09:00	0,727		1					
	10:00	0,711		1					
	11:00	0,698		1					
	12:00	0,691		1					
	13:00	0,688		1					
	14:00	0,696		1					
	15:00	0,703		1					
	16:00	0,718		1					
	17:00	0,751		1					
	18:00	0,792		1					
	19:00	0,851		1					
	20:00	0,936		1		1			
	21:00	0,959		1		1			
	22:00	0,925		1		1			
	23:00	0,868		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 7 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Τετάρτη, 7 Μαΐου 2025	00:00	0,718		1					
	01:00	0,671		1					
	02:00	0,647		1					
	03:00	0,645		1					
	04:00	0,655		1					
	05:00	0,674		1					
	06:00	0,707		1					
	07:00	0,729		1					
	08:00	0,723		1					
	09:00	0,720		1					
	10:00	0,716		1					
	11:00	0,744		1					
	12:00	0,742		1					
	13:00	0,702		1					
	14:00	0,710		1					
	15:00	0,727		1					
	16:00	0,734		1					
	17:00	0,776		1					
	18:00	0,809		1					
	19:00	0,857		1					
	20:00	0,931		1		1			
	21:00	0,956		1		1			
	22:00	0,928		1		1			
	23:00	0,880		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης