

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 5 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Πέμπτη, 5 Ιουνίου 2025	00:00	0,997		1		1			
	01:00	0,917		1					
	02:00	0,877		1					
	03:00	0,848		1					
	04:00	0,836		1					
	05:00	0,857		1					
	06:00	0,895		1					
	07:00	0,928		1					
	08:00	0,980		1		1			
	09:00	1,021		1		1			
	10:00	1,024		1		1			
	11:00	1,044		1		1			
	12:00	1,056		1		1			
	13:00	1,053		1		1			
	14:00	1,080		1		1			
	15:00	1,077		1		1			
	16:00	1,098		1		1			
	17:00	1,145		1		1			
	18:00	1,216		1		1			
	19:00	1,320		1		1			
	20:00	1,387		1		1			
	21:00	1,412		1		1			
	22:00	1,292		1		1			
	23:00	1,133		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 6 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Παρασκευή, 6 Ιουνίου 2025	00:00	1,015		1		1			
	01:00	0,934		1					
	02:00	0,886		1					
	03:00	0,860		1					
	04:00	0,857		1					
	05:00	0,880		1					
	06:00	0,915		1					
	07:00	0,946		1		1			
	08:00	0,986		1		1			
	09:00	1,021		1		1			
	10:00	1,031		1		1			
	11:00	1,048		1		1			
	12:00	1,061		1		1			
	13:00	1,063		1		1			
	14:00	1,084		1		1			
	15:00	1,081		1		1			
	16:00	1,098		1		1			
	17:00	1,138		1		1			
	18:00	1,200		1		1			
	19:00	1,295		1		1			
	20:00	1,363		1		1			
	21:00	1,396		1		1			
	22:00	1,280		1		1			
	23:00	1,133		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 7 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Α	Ρ	Ε	Ε	Ε	Ε	Ε	Ε	Ε	Ε
Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10	
Σάββατο, 7 Ιουνίου 2025	00:00	1,025		1		1			
	01:00	0,946		1		1			
	02:00	0,894		1					
	03:00	0,869		1					
	04:00	0,869		1					
	05:00	0,891		1					
	06:00	0,929		1					
	07:00	0,965		1		1			
	08:00	0,999		1		1			
	09:00	1,030		1		1			
	10:00	1,040		1		1			
	11:00	1,053		1		1			
	12:00	1,064		1		1			
	13:00	1,068		1		1			
	14:00	1,081		1		1			
	15:00	1,079		1		1			
	16:00	1,094		1		1			
	17:00	1,129		1		1			
	18:00	1,181		1		1			
	19:00	1,260		1		1			
	20:00	1,327		1		1			
	21:00	1,355		1		1			
	22:00	1,249		1		1			
	23:00	1,113		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 8 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Ε Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Κυριακή, 8 Ιουνίου 2025	00:00	1,018		1		1			
	01:00	0,939		1		1			
	02:00	0,887		1					
	03:00	0,862		1					
	04:00	0,861		1					
	05:00	0,882		1					
	06:00	0,918		1		1			
	07:00	0,952		1		1			
	08:00	0,980		1		1			
	09:00	1,006		1		1			
	10:00	1,018		1		1			
	11:00	1,030		1		1			
	12:00	1,037		1		1			
	13:00	1,040		1		1			
	14:00	1,047		1		1			
	15:00	1,049		1		1			
	16:00	1,056		1		1			
	17:00	1,085		1		1			
	18:00	1,126		1		1			
	19:00	1,193		1		1			
	20:00	1,256		1		1			
	21:00	1,280		1		1			
	22:00	1,189		1		1			
	23:00	1,062		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 9 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Δευτέρα, 9 Ιουνίου 2025	00:00	0,956		1		1			
	01:00	0,881		1					
	02:00	0,834		1					
	03:00	0,816		1					
	04:00	0,823		1					
	05:00	0,848		1					
	06:00	0,889		1					
	07:00	0,933		1		1			
	08:00	0,965		1		1			
	09:00	0,998		1		1			
	10:00	1,011		1		1			
	11:00	1,021		1		1			
	12:00	1,031		1		1			
	13:00	1,040		1		1			
	14:00	1,050		1		1			
	15:00	1,049		1		1			
	16:00	1,061		1		1			
	17:00	1,091		1		1			
	18:00	1,132		1		1			
	19:00	1,203		1		1			
	20:00	1,266		1		1			
	21:00	1,297		1		1			
	22:00	1,210		1		1			
	23:00	1,086		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 10 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Τρίτη, 10 Ιουνίου 2025	00:00	0,937		1		1			
	01:00	0,864		1					
	02:00	0,818		1					
	03:00	0,801		1					
	04:00	0,809		1					
	05:00	0,837		1					
	06:00	0,876		1					
	07:00	0,918		1		1			
	08:00	0,954		1		1			
	09:00	0,986		1		1			
	10:00	0,996		1		1			
	11:00	1,009		1		1			
	12:00	1,020		1		1			
	13:00	1,028		1		1			
	14:00	1,041		1		1			
	15:00	1,043		1		1			
	16:00	1,058		1		1			
	17:00	1,091		1		1			
	18:00	1,136		1		1			
	19:00	1,209		1		1			
	20:00	1,276		1		1			
	21:00	1,311		1		1			
	22:00	1,229		1		1			
	23:00	1,109		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 11 Ιουνίου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Τετάρτη, 11 Ιουνίου 2025	00:00	0,939		1		1			
	01:00	0,866		1					
	02:00	0,821		1					
	03:00	0,803		1					
	04:00	0,809		1					
	05:00	0,836		1					
	06:00	0,877		1					
	07:00	0,916		1					
	08:00	0,950		1		1			
	09:00	0,978		1		1			
	10:00	0,989		1		1			
	11:00	1,002		1		1			
	12:00	1,012		1		1			
	13:00	1,020		1		1			
	14:00	1,035		1		1			
	15:00	1,040		1		1			
	16:00	1,058		1		1			
	17:00	1,092		1		1			
	18:00	1,139		1		1			
	19:00	1,214		1		1			
	20:00	1,283		1		1			
	21:00	1,324		1		1			
	22:00	1,247		1		1			
	23:00	1,131		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης