

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 6 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 6 Μαρτίου 2025	00:00	1,541		1				1	
	01:00	1,446		1				1	
	02:00	1,384		1				1	
	03:00	1,346		1				1	
	04:00	1,359		1				1	
	05:00	1,475		1				1	
	06:00	1,566		1				1	
	07:00	1,595		1					1
	08:00	1,674		1					1
	09:00	1,621		1					1
	10:00	1,546		1					1
	11:00	1,539		1					1
	12:00	1,552		1					1
	13:00	1,601		1					1
	14:00	1,519		1					1
	15:00	1,416		1					1
	16:00	1,461		1					1
	17:00	1,581		1					1
	18:00	1,854		1					1
	19:00	2,140		1		1			1
	20:00	2,144		1		1			1
	21:00	1,972		1		1			1
	22:00	1,790		1		1			
	23:00	1,599		1		1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 7 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 7 Μαρτίου 2025	00:00	1,469		1		1			
	01:00	1,366		1		1			
	02:00	1,335		1		1			
	03:00	1,322		1		1			
	04:00	1,329		1		1			
	05:00	1,335		1		1			
	06:00	1,455		1		1			
	07:00	1,652		1		1			
	08:00	1,625		1		1			
	09:00	1,619		1		1			
	10:00	1,552		1		1			
	11:00	1,523		1		1			
	12:00	1,540		1		1			
	13:00	1,503		1		1			
	14:00	1,445		1		1			
	15:00	1,375		1		1			
	16:00	1,356		1		1			
	17:00	1,510		1		1			
	18:00	1,792		1		1			
	19:00	1,977		1		1	1		
	20:00	1,967		1		1	1		
	21:00	1,916		1		1	1		
	22:00	1,752				1	1		
	23:00	1,595				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 8 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 8 Μαρτίου 2025	00:00	1,452				1	1		
	01:00	1,360				1	1		
	02:00	1,289				1	1		
	03:00	1,265				1	1		
	04:00	1,264				1	1		
	05:00	1,316				1	1		
	06:00	1,384				1	1		
	07:00	1,422				1	1		
	08:00	1,458	1			1			
	09:00	1,478	1			1			
	10:00	1,467	1			1			
	11:00	1,468	1			1			
	12:00	1,414	1			1			
	13:00	1,459	1			1			
	14:00	1,354	1			1			
	15:00	1,342	1			1			
	16:00	1,410	1			1			
	17:00	1,562	1			1			
	18:00	1,773	1			1			
	19:00	1,944	1			1			
	20:00	1,932				1	1		
	21:00	1,792				1	1		
	22:00	1,629				1	1		
	23:00	1,487				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 9 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 9 Μαρτίου 2025	00:00	1,414				1	1		
	01:00	1,352				1	1		
	02:00	1,299				1	1		
	03:00	1,286				1	1		
	04:00	1,318				1	1		
	05:00	1,333				1	1		
	06:00	1,312				1	1		
	07:00	1,340				1			1
	08:00	1,398				1			1
	09:00	1,399				1			1
	10:00	1,368				1			1
	11:00	1,398				1			1
	12:00	1,460				1			1
	13:00	1,435				1			1
	14:00	1,353				1			1
	15:00	1,239				1			1
	16:00	1,268				1			1
	17:00	1,410				1			1
	18:00	1,650				1			1
	19:00	1,876				1			1
	20:00	1,901					1	1	
	21:00	1,802					1	1	
	22:00	1,685					1	1	
	23:00	1,473					1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 10 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 10 Μαρτίου 2025	00:00	1,310					1	1	
	01:00	1,242					1	1	
	02:00	1,223					1	1	
	03:00	1,266					1	1	
	04:00	1,229					1	1	
	05:00	1,275					1	1	
	06:00	1,403					1	1	
	07:00	1,516					1	1	
	08:00	1,454	1					1	
	09:00	1,372	1					1	
	10:00	1,412	1					1	
	11:00	1,329	1					1	
	12:00	1,353	1					1	
	13:00	1,384	1					1	
	14:00	1,312	1					1	
	15:00	1,236	1					1	
	16:00	1,261	1					1	
	17:00	1,413	1					1	
	18:00	1,669	1					1	
	19:00	1,953		1				1	
	20:00	1,958		1				1	
	21:00	1,801		1				1	
	22:00	1,621		1				1	
	23:00	1,424		1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 11 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 11 Μαρτίου 2025	00:00	1,289		1				1	
	01:00	1,268		1				1	
	02:00	1,234		1				1	
	03:00	1,187		1				1	
	04:00	1,186		1				1	
	05:00	1,266		1				1	
	06:00	1,352		1				1	
	07:00	1,419						1	1
	08:00	1,438						1	1
	09:00	1,428						1	1
	10:00	1,354						1	1
	11:00	1,325						1	1
	12:00	1,331						1	1
	13:00	1,286						1	1
	14:00	1,202				1			1
	15:00	1,194				1			1
	16:00	1,318				1			1
	17:00	1,452				1			1
	18:00	1,683				1			1
	19:00	1,982		1		1			
	20:00	2,019		1		1			
	21:00	1,790		1		1			
	22:00	1,582		1		1			
	23:00	1,410		1		1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 12 Μαρτίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 12 Μαρτίου 2025	00:00	1,302		1		1			
	01:00	1,230		1		1			
	02:00	1,206		1		1			
	03:00	1,197		1		1			
	04:00	1,179		1		1			
	05:00	1,211		1		1			
	06:00	0,533		1		1			
	07:00	0,600	1	1		1			
	08:00	0,661	1	1		1			
	09:00	0,852	1	1		1			
	10:00	0,961	1	1		1			
	11:00	1,639	1	1		1			
	12:00	1,787		1		1			
	13:00	1,794		1		1			
	14:00	1,692		1		1			
	15:00	1,684		1		1			
	16:00	1,670		1		1			
	17:00	1,687		1		1			
	18:00	1,853		1		1			
	19:00	2,069		1		1			
	20:00	2,026		1		1			
	21:00	1,783		1		1			
	22:00	1,601		1		1			
	23:00	1,418		1		1			

Γενική διακοπή στις 06:15, λόγο βλάβης στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης