

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 30 Ιανουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 30 Ιανουαρίου 2025	00:00	1,383			1	1			
	01:00	1,340			1	1			
	02:00	1,265			1	1			
	03:00	1,247			1	1			
	04:00	1,240			1	1			
	05:00	1,290			1	1			
	06:00	1,355			1	1			
	07:00	1,534			1	1			
	08:00	1,643			1	1			
	09:00	1,676			1	1			1
	10:00	1,592			1				1
	11:00	1,641			1				1
	12:00	1,838			1				1
	13:00	1,830			1				1
	14:00	1,708			1				1
	15:00	1,590			1				1
	16:00	1,523			1				1
	17:00	1,682			1				1
	18:00	1,911			1		1		1
	19:00	2,020			1		1		
	20:00	1,972			1		1		
	21:00	1,790			1		1		
	22:00	1,668			1		1		
	23:00	1,547			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 31 Ιανουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 31 Ιανουαρίου 2025	00:00	1,339			1		1		
	01:00	1,256			1		1		
	02:00	1,258			1		1		
	03:00	1,211			1		1		
	04:00	1,214			1		1		
	05:00	1,278			1		1		
	06:00	1,360			1		1		
	07:00	1,565			1		1		
	08:00	1,713			1		1		
	09:00	1,664			1		1		
	10:00	1,601	1		1				
	11:00	1,587	1		1				
	12:00	1,553	1		1				
	13:00	1,591	1		1				
	14:00	1,494	1		1				
	15:00	1,392	1		1				
	16:00	1,421	1		1				
	17:00	1,604	1		1				
	18:00	1,909	1		1			1	
	19:00	1,948			1			1	
	20:00	1,958			1			1	
	21:00	1,937			1			1	
	22:00	1,740			1			1	
	23:00	1,528			1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 1 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 1 Φεβρουαρίου 2025	00:00	1,412			1			1	
	01:00	1,328			1			1	
	02:00	1,285			1			1	
	03:00	1,257			1			1	
	04:00	1,274			1			1	
	05:00	1,303			1			1	
	06:00	1,361			1			1	
	07:00	1,481			1			1	
	08:00	1,582			1			1	
	09:00	1,575			1			1	
	10:00	1,548			1			1	
	11:00	1,476			1			1	
	12:00	1,496			1			1	
	13:00	1,510			1			1	
	14:00	1,423			1			1	
	15:00	1,385			1			1	
	16:00	1,485			1			1	
	17:00	1,611			1			1	
	18:00	1,875		1	1			1	
	19:00	1,991		1				1	
	20:00	1,968		1				1	
	21:00	1,742		1				1	
	22:00	1,638		1				1	
	23:00	1,534		1				1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 2 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 2 Φεβρουαρίου 2025	00:00	1,380		1				1	
	01:00	1,296		1				1	
	02:00	1,283		1				1	
	03:00	1,274		1				1	
	04:00	1,286		1				1	
	05:00	1,319		1				1	
	06:00	1,382		1				1	
	07:00	1,447		1				1	
	08:00	1,551		1				1	
	09:00	1,688		1				1	1
	10:00	1,653		1					1
	11:00	1,654		1					1
	12:00	1,624		1					1
	13:00	1,615		1					1
	14:00	1,512		1					1
	15:00	1,481		1					1
	16:00	1,520		1					1
	17:00	1,665		1					1
	18:00	1,831		1	1				1
	19:00	1,945		1	1				
	20:00	1,884		1	1				
	21:00	1,762		1	1				
	22:00	1,654		1	1				
	23:00	1,497		1	1				



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 3 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 3 Φεβρουαρίου 2025	00:00	1,352		1	1				
	01:00	1,268		1	1				
	02:00	1,255		1	1				
	03:00	1,227		1	1				
	04:00	1,189		1	1				
	05:00	1,270		1	1				
	06:00	1,421		1	1				
	07:00	1,597		1	1				
	08:00	1,667	1		1				
	09:00	1,644	1		1				
	10:00	1,586	1		1				
	11:00	1,547	1		1				
	12:00	1,542	1		1				
	13:00	1,595	1		1				
	14:00	1,586	1		1				
	15:00	1,444	1		1				
	16:00	1,516	1		1				
	17:00	1,729	1		1				
	18:00	1,943	1		1	1			
	19:00	2,029			1	1			
	20:00	2,017			1	1			
	21:00	1,830			1	1			
	22:00	1,683			1	1			
	23:00	1,511			1	1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 4 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 4 Φεβρουαρίου 2025	00:00	1,432			1	1			
	01:00	1,355			1	1			
	02:00	1,295			1	1			
	03:00	1,279			1	1			
	04:00	1,309			1	1			
	05:00	1,337			1	1			
	06:00	1,472			1	1			
	07:00	1,745			1	1			
	08:00	2,037			1	1			
	09:00	2,219			1	1	1		
	10:00	2,238			1	1	1		
	11:00	2,221			1	1	1		
	12:00	2,124			1	1	1		
	13:00	2,082			1	1			
	14:00	1,965			1	1			
	15:00	1,957			1	1			
	16:00	1,931			1	1			
	17:00	1,941			1	1			
	18:00	2,113			1	1	1		
	19:00	2,229			1	1	1		
	20:00	2,229			1	1	1		
	21:00	2,012			1	1	1		
	22:00	1,815			1		1		
	23:00	1,679			1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 5 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 5 Φεβρουαρίου 2025	00:00	1,503			1		1		
	01:00	1,382			1		1		
	02:00	1,366			1		1		
	03:00	1,382			1		1		
	04:00	1,340			1		1		
	05:00	1,381			1		1		
	06:00	1,523			1		1		
	07:00	1,745			1		1		
	08:00	1,930			1		1		
	09:00	2,122			1		1		
	10:00	2,192			1		1		1
	11:00	2,103			1		1		1
	12:00	1,985			1		1	1	
	13:00	1,974			1			1	
	14:00	1,890			1			1	
	15:00	1,779			1			1	
	16:00	1,841			1			1	
	17:00	1,995			1			1	
	18:00	2,224		1	1			1	
	19:00	2,275		1	1			1	
	20:00	2,209		1	1			1	
	21:00	2,029		1	1			1	
	22:00	1,867		1	1			1	
	23:00	1,701		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης