

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 11 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 11 Απριλίου 2025	00:00	1,418				1	1		
	01:00	1,287				1	1		
	02:00	1,203				1	1		
	03:00	1,167				1	1		
	04:00	1,177				1	1		
	05:00	1,242				1	1		
	06:00	1,354				1	1		
	07:00	1,479				1	1		
	08:00	1,566				1	1		
	09:00	1,574				1	1		
	10:00	1,613				1	1		
	11:00	1,582				1	1		
	12:00	1,613				1	1		
	13:00	1,583				1	1		
	14:00	1,514				1	1		
	15:00	1,422				1	1		
	16:00	1,364				1	1		
	17:00	1,416				1	1		
	18:00	1,545				1	1		
	19:00	1,752				1	1		
	20:00	1,983				1	1	1	
	21:00	2,018				1	1	1	
	22:00	1,927				1	1	1	
	23:00	1,711				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 12 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 12 Απριλίου 2025	00:00	1,421				1	1		
	01:00	1,299				1	1		
	02:00	1,218				1	1		
	03:00	1,184				1	1		
	04:00	1,196				1	1		
	05:00	1,255				1	1		
	06:00	1,353				1	1		
	07:00	1,467				1	1		
	08:00	1,577				1	1		
	09:00	1,656				1	1		
	10:00	1,687				1	1		
	11:00	1,666				1	1		
	12:00	1,624				1	1		
	13:00	1,480				1	1		
	14:00	1,365				1	1		
	15:00	1,314				1	1		
	16:00	1,322				1	1		
	17:00	1,383				1	1		
	18:00	1,511				1	1		
	19:00	1,718				1	1		
	20:00	1,951				1	1	1	
	21:00	1,999				1	1	1	
	22:00	1,914				1	1	1	
	23:00	1,705				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 13 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 13 Απριλίου 2025	00:00	1,416				1	1		
	01:00	1,296				1	1		
	02:00	1,217				1	1		
	03:00	1,180				1	1		
	04:00	1,181				1	1		
	05:00	1,225				1	1		
	06:00	1,318				1	1		
	07:00	1,423				1	1		
	08:00	1,482				1	1		
	09:00	1,510				1	1		
	10:00	1,516				1	1		
	11:00	1,479				1	1		
	12:00	1,435				1	1		
	13:00	1,401				1	1		
	14:00	1,360				1	1		
	15:00	1,313				1	1		
	16:00	1,316				1	1		
	17:00	1,375				1	1		
	18:00	1,483				1	1		
	19:00	1,662				1	1		
	20:00	1,885				1	1	1	
	21:00	1,936				1	1	1	
	22:00	1,866				1	1	1	
	23:00	1,684				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 14 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 14 Απριλίου 2025	00:00	1,386				1	1		
	01:00	1,252				1	1		
	02:00	1,171				1	1		
	03:00	1,149				1	1		
	04:00	1,184				1	1		
	05:00	1,274				1	1		
	06:00	1,414				1	1		
	07:00	1,566				1	1		
	08:00	1,611				1	1		
	09:00	1,628				1	1		
	10:00	1,603				1	1		
	11:00	1,566				1	1		
	12:00	1,539				1	1		
	13:00	1,490				1	1		
	14:00	1,440				1	1		
	15:00	1,403				1	1		
	16:00	1,424				1	1		
	17:00	1,482				1	1		
	18:00	1,605				1	1		
	19:00	1,770				1	1		
	20:00	1,990				1	1	1	
	21:00	2,008				1	1	1	
	22:00	1,916				1	1	1	
	23:00	1,720				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 15 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 15 Απριλίου 2025	00:00	1,385				1	1		
	01:00	1,253				1	1		
	02:00	1,171				1	1		
	03:00	1,150				1	1		
	04:00	1,192				1	1		
	05:00	1,288				1	1		
	06:00	1,431				1	1		
	07:00	1,591				1	1		
	08:00	1,648				1	1		
	09:00	1,642				1	1		
	10:00	1,589				1	1		
	11:00	1,553				1	1		
	12:00	1,486				1	1		
	13:00	1,432				1	1		
	14:00	1,384				1	1		
	15:00	1,321				1	1		
	16:00	1,314				1	1		
	17:00	1,370				1	1		
	18:00	1,503				1	1		
	19:00	1,685				1	1		
	20:00	1,927				1	1	1	
	21:00	1,965				1	1	1	
	22:00	1,885				1	1	1	
	23:00	1,699				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 16 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Α Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 16 Απριλίου 2025	00:00	1,369				1	1		
	01:00	1,245				1	1		
	02:00	1,160				1	1		
	03:00	1,136				1	1		
	04:00	1,168				1	1		
	05:00	1,252				1	1		
	06:00	1,380				1	1		
	07:00	1,531				1	1		
	08:00	1,583				1	1		
	09:00	1,574				1	1		
	10:00	1,525				1	1		
	11:00	1,483				1	1		
	12:00	1,411				1	1		
	13:00	1,347				1	1		
	14:00	1,289				1	1		
	15:00	1,232				1	1		
	16:00	1,224				1	1		
	17:00	1,273				1	1		
	18:00	1,406				1	1		
	19:00	1,602				1	1		
	20:00	1,841				1	1	1	
	21:00	1,899				1	1	1	
	22:00	1,846				1	1	1	
	23:00	1,685				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 17 Απριλίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 17 Απριλίου 2025	00:00	1,383				1	1		
	01:00	1,257				1	1		
	02:00	1,172				1	1		
	03:00	1,147				1	1		
	04:00	1,180				1	1		
	05:00	1,265				1	1		
	06:00	1,394				1	1		
	07:00	1,546				1	1		
	08:00	1,599				1	1		
	09:00	1,590				1	1		
	10:00	1,540				1	1		
	11:00	1,498				1	1		
	12:00	1,425				1	1		
	13:00	1,360				1	1		
	14:00	1,302				1	1		
	15:00	1,244				1	1		
	16:00	1,236				1	1		
	17:00	1,286				1	1		
	18:00	1,420				1	1		
	19:00	1,618				1	1		
	20:00	1,859				1	1	1	
	21:00	1,918				1	1	1	
	22:00	1,864				1	1	1	
	23:00	1,702				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης