

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 31 Ιανουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 31 Ιανουαρίου 2025	00:00	1,352			1	1			
	01:00	1,277			1	1			
	02:00	1,217			1	1			
	03:00	1,184			1	1			
	04:00	1,189			1	1			
	05:00	1,238			1	1			
	06:00	1,327			1	1			
	07:00	1,453			1	1			
	08:00	1,572			1	1			
	09:00	1,673			1	1			
	10:00	1,769			1	1			
	11:00	1,825			1	1			
	12:00	1,818			1	1			
	13:00	1,764			1	1			
	14:00	1,700			1	1			
	15:00	1,641			1	1			
	16:00	1,630			1	1			
	17:00	1,739			1	1			
	18:00	1,893			1	1			
	19:00	2,012			1	1	1		
	20:00	2,032			1	1	1		
	21:00	1,914			1	1			
	22:00	1,678			1	1			
	23:00	1,388			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 1 Φεβρουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 1 Φεβρουαρίου 2025	00:00	1,396			1	1			
	01:00	1,316			1	1			
	02:00	1,251			1	1			
	03:00	1,214			1	1			
	04:00	1,216			1	1			
	05:00	1,265			1	1			
	06:00	1,358			1	1			
	07:00	1,490			1	1			
	08:00	1,627			1	1			
	09:00	1,753			1	1			
	10:00	1,855			1	1			
	11:00	1,906			1	1			
	12:00	1,900			1	1			
	13:00	1,852			1	1			
	14:00	1,779			1	1			
	15:00	1,625			1	1			
	16:00	1,611			1	1			
	17:00	1,708			1	1			
	18:00	1,883			1	1			
	19:00	2,000			1	1	1		
	20:00	2,038			1	1	1		
	21:00	1,937			1	1			
	22:00	1,712			1	1			
	23:00	1,425			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 2 Φεβρουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 2 Φεβρουαρίου 2025	00:00	1,446			1	1			
	01:00	1,361			1	1			
	02:00	1,289			1	1			
	03:00	1,245			1	1			
	04:00	1,240			1	1			
	05:00	1,286			1	1			
	06:00	1,381			1	1			
	07:00	1,516			1	1			
	08:00	1,660			1	1			
	09:00	1,744			1	1			
	10:00	1,809			1	1			
	11:00	1,832			1	1			
	12:00	1,837			1	1			
	13:00	1,881			1	1			
	14:00	1,736			1	1			
	15:00	1,674			1	1			
	16:00	1,666			1	1			
	17:00	1,746			1	1			
	18:00	1,893			1	1			
	19:00	1,991			1	1	1		
	20:00	2,024			1	1	1		
	21:00	1,927			1	1			
	22:00	1,714			1	1			
	23:00	1,440			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 3 Φεβρουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 3 Φεβρουαρίου 2025	00:00	1,434			1	1			
	01:00	1,349			1	1			
	02:00	1,282			1	1			
	03:00	1,243			1	1			
	04:00	1,240			1	1			
	05:00	1,289			1	1			
	06:00	1,387			1	1			
	07:00	1,526			1	1			
	08:00	1,680			1	1			
	09:00	1,763			1	1			
	10:00	1,817			1	1			
	11:00	1,823			1	1			
	12:00	1,909			1	1			
	13:00	1,916			1	1			
	14:00	1,724			1	1			
	15:00	1,675			1	1			
	16:00	1,699			1	1			
	17:00	1,799			1	1			
	18:00	1,978			1	1	1		
	19:00	2,085			1	1	1		
	20:00	2,111			1	1	1		
	21:00	2,002			1	1	1		
	22:00	1,770			1	1			
	23:00	1,478			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 4 Φεβρουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 4 Φεβρουαρίου 2025	00:00	1,463			1	1			
	01:00	1,376			1	1			
	02:00	1,306			1	1			
	03:00	1,265			1	1			
	04:00	1,258			1	1			
	05:00	1,307			1	1			
	06:00	1,420			1	1			
	07:00	1,569			1	1			
	08:00	1,721			1	1			
	09:00	1,851			1	1			
	10:00	1,974			1	1	1		
	11:00	2,040			1	1	1		
	12:00	2,051			1	1	1		
	13:00	1,841			1	1			
	14:00	1,775			1	1			
	15:00	1,739			1	1			
	16:00	1,768			1	1			
	17:00	1,887			1	1			
	18:00	2,062			1	1	1		
	19:00	2,166			1	1	1		
	20:00	2,192			1	1	1		
	21:00	2,086			1	1	1		
	22:00	1,863			1	1			
	23:00	1,579			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 5 Φεβρουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 5 Φεβρουαρίου 2025	00:00	1,484			1	1			
	01:00	1,398			1	1			
	02:00	1,329			1	1			
	03:00	1,292			1	1			
	04:00	1,298			1	1			
	05:00	1,363			1	1			
	06:00	1,487			1	1			
	07:00	1,658			1	1			
	08:00	1,821			1	1			
	09:00	1,897			1	1			
	10:00	1,955			1	1	1		
	11:00	1,969			1	1	1		
	12:00	1,946			1	1	1		
	13:00	1,927			1	1	1		
	14:00	1,978			1	1	1		
	15:00	1,972			1	1	1		
	16:00	1,906			1	1	1		
	17:00	2,028			1	1	1		
	18:00	2,152			1	1	1		
	19:00	2,247			1	1	1		
	20:00	2,267			1	1	1		
	21:00	2,163			1	1	1		
	22:00	1,945			1	1			
	23:00	1,668			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 6 Φεβρουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 6 Φεβρουαρίου 2025	00:00	1,582			1	1			
	01:00	1,483			1	1			
	02:00	1,399			1	1			
	03:00	1,352			1	1			
	04:00	1,322			1	1			
	05:00	1,361			1	1			
	06:00	1,534			1	1			
	07:00	1,724			1	1			
	08:00	1,886			1	1			
	09:00	2,040			1	1	1		
	10:00	2,216			1	1	1		
	11:00	2,212			1	1	1		
	12:00	2,235			1	1	1		
	13:00	2,275			1	1	1		
	14:00	2,245			1	1	1		
	15:00	2,134			1	1	1		
	16:00	2,007			1	1	1		
	17:00	2,085			1	1	1		
	18:00	2,222			1	1	1		
	19:00	2,310			1	1	1		
	20:00	2,339			1	1	1		
	21:00	2,258			1	1	1		
	22:00	2,073			1	1	1		
	23:00	1,838			1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης