

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 11 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 11 Φεβρουαρίου 2025	00:00	2,031	1			1					1
	01:00	1,830	1			1					1
	02:00	1,603	1			1					1
	03:00	1,284	1								1
	04:00	1,239	1								1
	05:00	1,317	1								1
	06:00	1,394	1								1
	07:00	1,594	1								1
	08:00	1,913	1				1				1
	09:00	2,280				1	1				1
	10:00	2,365				1	1				1
	11:00	2,488				1	1				1
	12:00	2,474				1	1				1
	13:00	2,463				1	1				1
	14:00	2,520				1	1				1
	15:00	2,630	1			1	1				1
	16:00	2,354	1			1	1				1
	17:00	3,261	1			1	1			1	1
	18:00	3,663	1			1	1			1	1
	19:00	3,751	1			1	1			1	1
	20:00	3,738	1			1	1			1	1
	21:00	3,497	1			1	1			1	1
	22:00	3,146	1			1	1			1	1
	23:00	2,694	1			1	1				1

Μερική διακοπή στις 16:12 λόγω σφάλματος στο δίκτυο.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 12 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 12 Φεβρουαρίου 2025	00:00	2,264	1			1					1
	01:00	2,032	1			1					1
	02:00	1,962	1			1					1
	03:00	1,963	1			1					1
	04:00	2,011	1			1					1
	05:00	2,014	1			1					1
	06:00	2,082	1			1					1
	07:00	2,516	1			1					1
	08:00	2,668	1			1					1
	09:00	2,645	1			1					1
	10:00	2,684				1	1				1
	11:00	2,656				1	1				1
	12:00	2,390				1	1				1
	13:00	2,331				1	1				1
	14:00	2,378				1	1				1
	15:00	2,460				1	1				1
	16:00	2,636				1	1			1	1
	17:00	2,742				1	1			1	1
	18:00	2,983				1	1			1	1
	19:00	2,922				1	1			1	1
	20:00	2,955				1	1			1	1
	21:00	2,719				1	1			1	1
	22:00	2,418				1	1			1	1
	23:00	2,432				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 13 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 13 Φεβρουαρίου 2025	00:00	2,256				1	1				1
	01:00	2,076				1	1				1
	02:00	2,001				1	1				1
	03:00	1,980				1	1				1
	04:00	1,979				1	1				1
	05:00	1,991				1	1				1
	06:00	2,032				1	1				1
	07:00	2,484				1	1				1
	08:00	2,527				1	1				1
	09:00	2,333				1	1				1
	10:00	2,391				1	1				1
	11:00	2,382				1	1				1
	12:00	2,421				1	1				1
	13:00	2,435				1	1				1
	14:00	2,477				1	1				1
	15:00	2,631				1	1				1
	16:00	2,839				1	1				1
	17:00	2,854				1	1			1	1
	18:00	2,740				1	1			1	1
	19:00	2,884				1	1			1	1
	20:00	2,834				1	1			1	1
	21:00	2,698				1	1			1	1
	22:00	2,340				1	1			1	1
	23:00	2,209				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 14 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 14 Φεβρουαρίου 2025	00:00	2,050				1	1				1
	01:00	1,807				1	1				1
	02:00	1,729				1	1				1
	03:00	1,687				1	1				1
	04:00	1,709				1	1				1
	05:00	1,774				1	1				1
	06:00	1,985				1	1				1
	07:00	2,118				1	1				1
	08:00	2,223				1	1				1
	09:00	2,141				1	1				1
	10:00	2,149				1	1				1
	11:00	2,101				1	1				1
	12:00	2,035				1	1				1
	13:00	2,004				1	1				1
	14:00	2,191				1	1				1
	15:00	2,252				1	1				1
	16:00	2,408				1	1				1
	17:00	2,647				1	1				1
	18:00	2,665				1	1				1
	19:00	2,447				1	1			1	1
	20:00	2,529				1	1			1	1
	21:00	2,772				1	1			1	1
	22:00	2,508				1	1				1
	23:00	2,162				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 15 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 15 Φεβρουαρίου 2025	00:00	1,816				1	1				1
	01:00	1,644				1	1				1
	02:00	1,549				1	1				1
	03:00	1,532				1	1				1
	04:00	1,530				1	1				1
	05:00	1,556				1	1				1
	06:00	1,612				1	1				1
	07:00	1,892				1	1				1
	08:00	2,360				1	1				1
	09:00	2,710	1			1	1				1
	10:00	2,903	1			1	1				1
	11:00	2,920	1			1	1				1
	12:00	3,038	1			1	1				1
	13:00	2,936	1			1	1				1
	14:00	2,881	1			1	1				1
	15:00	2,919	1			1	1				1
	16:00	2,859	1			1	1				1
	17:00	2,980	1			1	1				1
	18:00	3,298	1			1	1			1	1
	19:00	3,422	1			1	1			1	1
	20:00	3,406	1			1	1			1	1
	21:00	2,880	1			1	1			1	1
	22:00	2,503				1	1				1
	23:00	2,187				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 16 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 16 Φεβρουαρίου 2025	00:00	1,825				1	1				1
	01:00	1,595				1	1				1
	02:00	1,475				1	1				1
	03:00	1,469				1	1				1
	04:00	1,477				1	1				1
	05:00	1,504				1	1				1
	06:00	1,604				1	1				1
	07:00	1,822				1	1				1
	08:00	2,101				1	1				1
	09:00	2,272				1	1				1
	10:00	2,258				1	1				1
	11:00	2,301				1	1				1
	12:00	2,244	1			1					1
	13:00	2,174				1	1				1
	14:00	2,271				1	1				1
	15:00	2,494				1	1				1
	16:00	2,664				1	1				1
	17:00	2,729				1	1				1
	18:00	2,570				1	1			1	1
	19:00	2,742				1	1			1	1
	20:00	2,770				1	1			1	1
	21:00	2,646				1	1				1
	22:00	2,455				1	1				1
	23:00	2,104				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 17 Φεβρουαρίου 2025						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 17 Φεβρουαρίου 2025	00:00	1,730				1	1				1
	01:00	1,546				1	1				1
	02:00	1,448				1	1				1
	03:00	1,417				1	1				1
	04:00	1,410				1	1				1
	05:00	1,474				1	1				1
	06:00	1,583				1	1				1
	07:00	1,862				1	1				1
	08:00	2,159				1	1				1
	09:00	2,289				1	1				1
	10:00	2,501				1	1				1
	11:00	2,515				1	1				1
	12:00	2,606				1	1				1
	13:00	2,362				1	1				1
	14:00	2,427				1	1				1
	15:00	2,540				1	1				1
	16:00	2,521				1	1				1
	17:00	2,633				1	1				1
	18:00	2,679				1	1			1	1
	19:00	2,476				1	1			1	1
	20:00	2,464				1	1			1	1
	21:00	2,662				1	1				1
	22:00	2,395				1	1				1
	23:00	2,069				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης