

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 2 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 2 Απριλίου 2025	00:00	0,937	1								
	01:00	0,871	1								
	02:00	0,833	1								
	03:00	0,820	1								
	04:00	0,812	1								
	05:00	0,839	1								
	06:00	0,914	1								
	07:00	1,008	1			1					
	08:00	1,199	1			1					
	09:00	1,326	1			1					
	10:00	1,365	1			1					
	11:00	1,399	1			1					
	12:00	1,460	1			1					
	13:00	1,429	1			1					
	14:00	1,355	1			1					
	15:00	1,321	1			1					
	16:00	1,384	1			1					
	17:00	1,428	1			1					
	18:00	1,535	1			1					
	19:00	1,616	1			1					
	20:00	1,561	1			1					
	21:00	1,410	1			1					
	22:00	1,264	1			1					
	23:00	1,134	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 3 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 3 Απριλίου 2025	00:00	0,946	1			1					
	01:00	0,884	1								
	02:00	0,839	1								
	03:00	0,814	1								
	04:00	0,810	1								
	05:00	0,847	1								
	06:00	0,930	1								
	07:00	1,042	1			1					
	08:00	1,187	1			1					
	09:00	1,283	1			1					
	10:00	1,316	1			1					
	11:00	1,335	1			1					
	12:00	1,340	1			1					
	13:00	1,314	1			1					
	14:00	1,274	1			1					
	15:00	1,240	1			1					
	16:00	1,245	1			1					
	17:00	1,330	1			1					
	18:00	1,484	1			1					
	19:00	1,597	1			1					
	20:00	1,575	1			1					
	21:00	1,417	1			1					
	22:00	1,263	1			1					
	23:00	1,131	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 4 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 4 Απριλίου 2025	00:00	0,949	1			1					
	01:00	0,888	1								
	02:00	0,845	1								
	03:00	0,816	1								
	04:00	0,812	1								
	05:00	0,849	1								
	06:00	0,928	1								
	07:00	1,036	1			1					
	08:00	1,185	1			1					
	09:00	1,276	1			1					
	10:00	1,325	1			1					
	11:00	1,339	1			1					
	12:00	1,335	1			1					
	13:00	1,293	1			1					
	14:00	1,233	1			1					
	15:00	1,194	1			1					
	16:00	1,203	1			1					
	17:00	1,297	1			1					
	18:00	1,440	1			1					
	19:00	1,538	1			1					
	20:00	1,550	1			1					
	21:00	1,428	1			1					
	22:00	1,240	1			1					
	23:00	1,112	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 5 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 5 Απριλίου 2025	00:00	0,935	1								
	01:00	0,877	1								
	02:00	0,835	1								
	03:00	0,808	1								
	04:00	0,801	1								
	05:00	0,830	1								
	06:00	0,896	1								
	07:00	1,007	1			1					
	08:00	1,169	1			1					
	09:00	1,254	1			1					
	10:00	1,299	1			1					
	11:00	1,318	1			1					
	12:00	1,328	1			1					
	13:00	1,288	1			1					
	14:00	1,245	1			1					
	15:00	1,180	1			1					
	16:00	1,191	1			1					
	17:00	1,285	1			1					
	18:00	1,433	1			1					
	19:00	1,544	1			1					
	20:00	1,556	1			1					
	21:00	1,366	1			1					
	22:00	1,214	1			1					
	23:00	1,083	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 6 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 6 Απριλίου 2025	00:00	0,926	1								
	01:00	0,879	1								
	02:00	0,713	1								
	03:00	0,677	1								
	04:00	0,788	1								
	05:00	0,811	1								
	06:00	0,870	1								
	07:00	0,971	1			1					
	08:00	1,080	1			1					
	09:00	1,168	1			1					
	10:00	1,244	1			1					
	11:00	1,280	1			1					
	12:00	1,280	1			1					
	13:00	1,244	1			1					
	14:00	1,192	1			1					
	15:00	1,140	1			1					
	16:00	1,155	1			1					
	17:00	1,218	1			1					
	18:00	1,311	1			1					
	19:00	1,424	1			1					
	20:00	1,463	1			1					
	21:00	1,344	1			1					
	22:00	1,214	1			1					
	23:00	1,084	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 7 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 7 Απριλίου 2025	00:00	0,914	1								
	01:00	0,846	1								
	02:00	0,805	1								
	03:00	0,780	1								
	04:00	0,782	1								
	05:00	0,825	1								
	06:00	0,909	1								
	07:00	1,028	1			1					
	08:00	1,188	1			1					
	09:00	1,296	1			1					
	10:00	1,292	1			1					
	11:00	1,354	1			1					
	12:00	1,377	1			1					
	13:00	1,344	1			1					
	14:00	1,296	1			1					
	15:00	1,226	1			1					
	16:00	1,229	1			1					
	17:00	1,313	1			1					
	18:00	1,432	1			1					
	19:00	1,515	1			1					
	20:00	1,489	1			1					
	21:00	1,392	1			1					
	22:00	1,245	1			1					
	23:00	1,106	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 8 Απριλίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 8 Απριλίου 2025	00:00	0,946	1			1					
	01:00	0,883	1								
	02:00	0,837	1								
	03:00	0,814	1								
	04:00	0,813	1								
	05:00	0,845	1								
	06:00	0,927	1								
	07:00	1,041	1			1					
	08:00	1,233	1			1					
	09:00	1,333	1			1					
	10:00	1,323	1			1					
	11:00	1,336	1			1					
	12:00	1,351	1			1					
	13:00	1,327	1			1					
	14:00	1,277	1			1					
	15:00	1,235	1			1					
	16:00	1,265	1			1					
	17:00	1,368	1			1					
	18:00	1,522	1			1					
	19:00	1,637	1			1					
	20:00	1,623	1			1					
	21:00	1,514	1			1					
	22:00	1,351	1			1					
	23:00	1,194	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης