

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 5 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 5 Φεβρουαρίου 2025	00:00	1,643	1			1					
	01:00	1,511	1			1					
	02:00	1,415	1			1					
	03:00	1,379	1			1					
	04:00	1,394	1			1					
	05:00	1,440	1			1					
	06:00	1,522	1			1					
	07:00	1,739	1			1					
	08:00	1,875	1			1	1				
	09:00	2,003	1			1	1				
	10:00	2,058	1			1	1				
	11:00	2,067	1			1	1				
	12:00	2,065	1			1	1				
	13:00	2,027	1			1	1				
	14:00	1,999	1			1	1				
	15:00	2,025	1			1	1				
	16:00	2,181	1			1	1				
	17:00	2,310	1			1	1				
	18:00	2,440	1			1	1				
	19:00	2,613	1			1	1				
	20:00	2,647	1			1	1				
	21:00	2,529	1			1	1				
	22:00	2,271	1			1	1				
	23:00	1,971	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 6 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ε Ε Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 6 Φεβρουαρίου 2025	00:00	1,667	1			1					
	01:00	1,539	1			1					
	02:00	1,436	1			1					
	03:00	1,378	1			1					
	04:00	1,373	1			1					
	05:00	1,428	1			1					
	06:00	1,549	1			1					
	07:00	1,785	1			1					
	08:00	1,913	1			1	1				
	09:00	2,011	1			1	1				
	10:00	2,069	1			1	1				
	11:00	2,091	1			1	1				
	12:00	2,085	1			1	1				
	13:00	2,054	1			1	1				
	14:00	2,017	1			1	1				
	15:00	1,986	1			1	1				
	16:00	2,086	1			1	1				
	17:00	2,249	1			1	1				
	18:00	2,456	1			1	1				
	19:00	2,604	1			1	1				
	20:00	2,620	1			1	1				
	21:00	2,482	1			1	1				
	22:00	2,233	1			1	1				
	23:00	1,970	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 7 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 7 Φεβρουαρίου 2025	00:00	1,662	1			1					
	01:00	1,538	1			1					
	02:00	1,431	1			1					
	03:00	1,358	1			1					
	04:00	1,334	1			1					
	05:00	1,381	1			1					
	06:00	1,513	1			1					
	07:00	1,704	1			1					
	08:00	1,841	1			1	1				
	09:00	1,908	1			1	1				
	10:00	1,923	1			1	1				
	11:00	1,912	1			1	1				
	12:00	1,898	1			1	1				
	13:00	1,877	1			1	1				
	14:00	1,858	1			1	1				
	15:00	1,856	1			1	1				
	16:00	1,936	1			1	1				
	17:00	2,107	1			1	1				
	18:00	2,365	1			1	1				
	19:00	2,494	1			1	1				
	20:00	2,555	1			1	1				
	21:00	2,432	1			1	1				
	22:00	2,180	1			1	1				
	23:00	1,937	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 8 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 8 Φεβρουαρίου 2025	00:00	1,583	1			1					
	01:00	1,468	1			1					
	02:00	1,369	1			1					
	03:00	1,302	1			1					
	04:00	1,277	1			1					
	05:00	1,302	1			1					
	06:00	1,413	1			1					
	07:00	1,583	1			1					
	08:00	1,733	1			1					
	09:00	1,790	1			1					
	10:00	1,817	1			1					
	11:00	1,828	1			1					
	12:00	1,825	1			1					
	13:00	1,820	1			1					
	14:00	1,794	1			1					
	15:00	1,793	1			1					
	16:00	1,874	1			1	1				
	17:00	2,047	1			1	1				
	18:00	2,300	1			1	1				
	19:00	2,426	1			1	1				
	20:00	2,446	1			1	1				
	21:00	2,303	1			1	1				
	22:00	2,078	1			1	1				
	23:00	1,837	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 9 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 9 Φεβρουαρίου 2025	00:00	1,506	1			1					
	01:00	1,405	1			1					
	02:00	1,322	1			1					
	03:00	1,260	1			1					
	04:00	1,238	1			1					
	05:00	1,257	1			1					
	06:00	1,331	1			1					
	07:00	1,496	1			1					
	08:00	1,622	1			1					
	09:00	1,686	1			1					
	10:00	1,736	1			1					
	11:00	1,766	1			1					
	12:00	1,772	1			1					
	13:00	1,759	1			1					
	14:00	1,731	1			1					
	15:00	1,738	1			1					
	16:00	1,816	1			1					
	17:00	1,972	1			1	1				
	18:00	2,215	1			1	1				
	19:00	2,336	1			1	1				
	20:00	2,328	1			1	1				
	21:00	2,207	1			1	1				
	22:00	1,987	1			1	1				
	23:00	1,745	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 10 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 10 Φεβρουαρίου 2025	00:00	1,476	1			1					
	01:00	1,380	1			1					
	02:00	1,304	1			1					
	03:00	1,252	1			1					
	04:00	1,247	1			1					
	05:00	1,294	1			1					
	06:00	1,392	1			1					
	07:00	1,574	1			1					
	08:00	1,695	1			1					
	09:00	1,750	1			1					
	10:00	1,789	1			1					
	11:00	1,793	1			1					
	12:00	1,789	1			1					
	13:00	1,745	1			1					
	14:00	1,705	1			1					
	15:00	1,705	1			1					
	16:00	1,776	1			1					
	17:00	1,940	1			1	1				
	18:00	2,210	1			1	1				
	19:00	2,350	1			1	1				
	20:00	2,359	1			1	1				
	21:00	2,217	1			1	1				
	22:00	1,973	1			1	1				
	23:00	1,711	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 11 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 11 Φεβρουαρίου 2025	00:00	1,458	1			1					
	01:00	1,365	1			1					
	02:00	1,292	1			1					
	03:00	1,251	1			1					
	04:00	1,250	1			1					
	05:00	1,293	1			1					
	06:00	1,387	1			1					
	07:00	1,570	1			1					
	08:00	1,698	1			1					
	09:00	1,765	1			1					
	10:00	1,807	1			1	1				
	11:00	1,878	1			1	1				
	12:00	1,910	1			1	1				
	13:00	1,903	1			1	1				
	14:00	1,866	1			1	1				
	15:00	1,853	1			1	1				
	16:00	1,893	1			1	1				
	17:00	2,007	1			1	1				
	18:00	2,192	1			1	1				
	19:00	2,312	1			1	1				
	20:00	2,316	1			1	1				
	21:00	2,166	1			1	1				
	22:00	1,920	1			1	1				
	23:00	1,674	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης