

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 12 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 12 Φεβρουαρίου 2025	00:00	1,924	1			1	1				
	01:00	1,762	1				1				
	02:00	1,590	1				1				
	03:00	1,371	1				1				
	04:00	1,329	1				1				
	05:00	1,383	1				1				
	06:00	1,728	1				1				
	07:00	1,982	1			1	1				
	08:00	2,108	1			1	1				
	09:00	2,158	1			1	1				
	10:00	2,178	1			1	1				
	11:00	2,171	1			1	1				
	12:00	2,171	1			1	1				
	13:00	2,144	1			1	1				
	14:00	2,117	1			1	1				
	15:00	2,121	1			1	1				
	16:00	2,207	1			1	1				
	17:00	2,420	1			1	1				
	18:00	2,612	1			1	1				
	19:00	2,754	1			1	1				
	20:00	2,788	1			1	1				
	21:00	2,723	1			1	1				
	22:00	2,540	1			1	1				
	23:00	2,320	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 13 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 13 Φεβρουαρίου 2025	00:00	1,815	1			1					
	01:00	1,671	1			1					
	02:00	1,536	1			1					
	03:00	1,390	1			1					
	04:00	1,344	1			1					
	05:00	1,400	1			1					
	06:00	1,654	1			1					
	07:00	1,903	1			1	1				
	08:00	2,031	1			1	1				
	09:00	2,079	1			1	1				
	10:00	2,097	1			1	1				
	11:00	2,105	1			1	1				
	12:00	2,088	1			1	1				
	13:00	2,054	1			1	1				
	14:00	2,013	1			1	1				
	15:00	2,014	1			1	1				
	16:00	2,089	1			1	1				
	17:00	2,272	1			1	1				
	18:00	2,527	1			1	1				
	19:00	2,676	1			1	1				
	20:00	2,694	1			1	1				
	21:00	2,598	1			1	1				
	22:00	2,433	1			1	1				
	23:00	2,169	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 14 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 14 Φεβρουαρίου 2025	00:00	1,734	1			1					
	01:00	1,610	1			1					
	02:00	1,514	1			1					
	03:00	1,421	1			1					
	04:00	1,377	1			1					
	05:00	1,419	1			1					
	06:00	1,576	1			1					
	07:00	1,782	1			1					
	08:00	1,920	1			1	1				
	09:00	1,979	1			1	1				
	10:00	2,009	1			1	1				
	11:00	2,016	1			1	1				
	12:00	2,007	1			1	1				
	13:00	1,973	1			1	1				
	14:00	1,930	1			1	1				
	15:00	1,954	1			1	1				
	16:00	2,055	1			1	1				
	17:00	2,209	1			1	1				
	18:00	2,396	1			1	1				
	19:00	2,526	1			1	1				
	20:00	2,545	1			1	1				
	21:00	2,423	1			1	1				
	22:00	2,285	1			1	1				
	23:00	1,997	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 15 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 15 Φεβρουαρίου 2025	00:00	1,643	1			1					
	01:00	1,543	1			1					
	02:00	1,471	1			1					
	03:00	1,409	1			1					
	04:00	1,373	1			1					
	05:00	1,392	1			1					
	06:00	1,499	1			1					
	07:00	1,653	1			1					
	08:00	1,810	1			1					
	09:00	1,911	1			1	1				
	10:00	1,987	1			1	1				
	11:00	2,044	1			1	1				
	12:00	2,072	1			1	1				
	13:00	2,038	1			1	1				
	14:00	1,969	1			1	1				
	15:00	1,980	1			1	1				
	16:00	2,038	1			1	1				
	17:00	2,157	1			1	1				
	18:00	2,312	1			1	1				
	19:00	2,403	1			1	1				
	20:00	2,411	1			1	1				
	21:00	2,324	1			1	1				
	22:00	2,164	1			1	1				
	23:00	1,883	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 16 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 16 Φεβρουαρίου 2025	00:00	1,582	1			1					
	01:00	1,481	1			1					
	02:00	1,406	1			1					
	03:00	1,301	1			1					
	04:00	1,267	1			1					
	05:00	1,286	1			1					
	06:00	1,358	1			1					
	07:00	1,498	1			1					
	08:00	1,637	1			1					
	09:00	1,754	1			1					
	10:00	1,831	1			1					
	11:00	1,878	1			1	1				
	12:00	1,935	1			1	1				
	13:00	1,946	1			1	1				
	14:00	1,910	1			1	1				
	15:00	1,880	1			1	1				
	16:00	1,897	1			1	1				
	17:00	2,054	1			1	1				
	18:00	2,241	1			1	1				
	19:00	2,296	1			1	1				
	20:00	2,331	1			1	1				
	21:00	2,282	1			1	1				
	22:00	2,105	1			1	1				
	23:00	1,855	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 17 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 17 Φεβρουαρίου 2025	00:00	1,559	1			1					
	01:00	1,466	1			1					
	02:00	1,401	1			1					
	03:00	1,342	1			1					
	04:00	1,317	1			1					
	05:00	1,357	1			1					
	06:00	1,454	1			1					
	07:00	1,638	1			1					
	08:00	1,759	1			1					
	09:00	1,826	1			1					
	10:00	1,865	1			1	1				
	11:00	1,923	1			1	1				
	12:00	1,936	1			1	1				
	13:00	1,924	1			1	1				
	14:00	1,886	1			1	1				
	15:00	1,884	1			1	1				
	16:00	1,933	1			1	1				
	17:00	2,141	1			1	1				
	18:00	2,351	1			1	1				
	19:00	2,431	1			1	1				
	20:00	2,456	1			1	1				
	21:00	2,383	1			1	1				
	22:00	2,170	1			1	1				
	23:00	1,914	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 18 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 18 Φεβρουαρίου 2025	00:00	1,614	1			1					
	01:00	1,508	1			1					
	02:00	1,418	1			1					
	03:00	1,346	1			1					
	04:00	1,323	1			1					
	05:00	1,373	1			1					
	06:00	1,517	1			1					
	07:00	1,714	1			1					
	08:00	1,865	1			1	1				
	09:00	1,962	1			1	1				
	10:00	2,003	1			1	1				
	11:00	1,990	1			1	1				
	12:00	2,049	1			1	1				
	13:00	1,983	1			1	1				
	14:00	1,937	1			1	1				
	15:00	1,986	1			1	1				
	16:00	2,017	1			1	1				
	17:00	2,194	1			1	1				
	18:00	2,409	1			1	1				
	19:00	2,519	1			1	1				
	20:00	2,537	1			1	1				
	21:00	2,431	1			1	1				
	22:00	2,185	1			1	1				
	23:00	1,918	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης