

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 12 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 12 Μαρτίου 2025	00:00	0,964	1				1				
	01:00	0,901	1								
	02:00	0,858	1								
	03:00	0,835	1								
	04:00	0,829	1								
	05:00	0,865	1								
	06:00	0,940	1				1				
	07:00	1,054	1				1				
	08:00	1,163	1				1				
	09:00	1,235	1				1				
	10:00	1,273	1				1				
	11:00	1,288	1				1				
	12:00	1,305	1				1				
	13:00	1,286	1				1				
	14:00	1,248	1				1				
	15:00	1,239	1				1				
	16:00	1,301	1				1				
	17:00	1,436	1				1				
	18:00	1,650	1				1				
	19:00	1,749	1				1				
	20:00	1,722	1				1				
	21:00	1,554	1				1				
	22:00	1,352	1				1				
	23:00	1,125	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 13 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 13 Μαρτίου 2025	00:00	0,981	1			1					
	01:00	0,924	1								
	02:00	0,878	1								
	03:00	0,851	1								
	04:00	0,845	1								
	05:00	0,875	1								
	06:00	0,946	1			1					
	07:00	1,054	1			1					
	08:00	1,168	1			1					
	09:00	1,242	1			1					
	10:00	1,296	1			1					
	11:00	1,315	1			1					
	12:00	1,312	1			1					
	13:00	1,282	1			1					
	14:00	1,221	1			1					
	15:00	1,272	1			1					
	16:00	1,300	1			1					
	17:00	1,366	1			1					
	18:00	1,558	1			1					
	19:00	1,671	1			1					
	20:00	1,662	1			1					
	21:00	1,540	1			1					
	22:00	1,366	1			1					
	23:00	1,133	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 14 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 14 Μαρτίου 2025	00:00	0,984	1			1					
	01:00	0,925	1								
	02:00	0,877	1								
	03:00	0,850	1								
	04:00	0,845	1								
	05:00	0,878	1								
	06:00	0,954	1			1					
	07:00	1,066	1			1					
	08:00	1,183	1			1					
	09:00	1,252	1			1					
	10:00	1,277	1			1					
	11:00	1,322	1			1					
	12:00	1,357	1			1					
	13:00	1,336	1			1					
	14:00	1,285	1			1					
	15:00	1,229	1			1					
	16:00	1,215	1			1					
	17:00	1,284	1			1					
	18:00	1,453	1			1					
	19:00	1,573	1			1					
	20:00	1,608	1			1					
	21:00	1,516	1			1					
	22:00	1,358	1			1					
	23:00	1,174	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 15 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 15 Μαρτίου 2025	00:00	1,006	1			1					
	01:00	0,951	1			1					
	02:00	0,907	1								
	03:00	0,882	1								
	04:00	0,881	1								
	05:00	0,916	1								
	06:00	0,979	1			1					
	07:00	1,090	1			1					
	08:00	1,184	1			1					
	09:00	1,253	1			1					
	10:00	1,301	1			1					
	11:00	1,354	1			1					
	12:00	1,395	1			1					
	13:00	1,429	1			1					
	14:00	1,388	1			1					
	15:00	1,316	1			1					
	16:00	1,273	1			1					
	17:00	1,294	1			1					
	18:00	1,411	1			1					
	19:00	1,554	1			1					
	20:00	1,597	1			1					
	21:00	1,493	1			1					
	22:00	1,316	1			1					
	23:00	1,149	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 16 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 16 Μαρτίου 2025	00:00	1,027	1			1					
	01:00	0,961	1			1					
	02:00	0,908	1								
	03:00	0,874	1								
	04:00	0,866	1								
	05:00	0,893	1								
	06:00	0,958	1			1					
	07:00	1,050	1			1					
	08:00	1,160	1			1					
	09:00	1,276	1			1					
	10:00	1,358	1			1					
	11:00	1,428	1			1					
	12:00	1,471	1			1					
	13:00	1,482	1			1					
	14:00	1,443	1			1					
	15:00	1,365	1			1					
	16:00	1,319	1			1					
	17:00	1,323	1			1					
	18:00	1,393	1			1					
	19:00	1,459	1			1					
	20:00	1,502	1			1					
	21:00	1,446	1			1					
	22:00	1,315	1			1					
	23:00	1,155	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 17 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 17 Μαρτίου 2025	00:00	1,006	1			1					
	01:00	0,940	1			1					
	02:00	0,888	1								
	03:00	0,862	1								
	04:00	0,865	1								
	05:00	0,908	1								
	06:00	0,997	1			1					
	07:00	1,115	1			1					
	08:00	1,243	1			1					
	09:00	1,355	1			1					
	10:00	1,417	1			1					
	11:00	1,458	1			1					
	12:00	1,489	1			1					
	13:00	1,478	1			1					
	14:00	1,424	1			1					
	15:00	1,330	1			1					
	16:00	1,268	1			1					
	17:00	1,298	1			1					
	18:00	1,434	1			1					
	19:00	1,547	1			1					
	20:00	1,595	1			1					
	21:00	1,492	1			1					
	22:00	1,368	1			1					
	23:00	1,205	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 18 Μαρτίου 2025				
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 18 Μαρτίου 2025	00:00	1,028	1			1					
	01:00	0,958	1			1					
	02:00	0,906	1								
	03:00	0,874	1								
	04:00	0,870	1								
	05:00	0,916	1								
	06:00	1,001	1			1					
	07:00	1,121	1			1					
	08:00	1,242	1			1					
	09:00	1,333	1			1					
	10:00	1,377	1			1					
	11:00	1,406	1			1					
	12:00	1,429	1			1					
	13:00	1,394	1			1					
	14:00	1,314	1			1					
	15:00	1,291	1			1					
	16:00	1,302	1			1					
	17:00	1,396	1			1					
	18:00	1,546	1			1					
	19:00	1,645	1			1					
	20:00	1,649	1			1					
	21:00	1,510	1			1					
	22:00	1,354	1			1					
	23:00	1,199	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης