

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 18 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 18 Ιουνίου 2025	00:00	1,892	1				1	1			
	01:00	1,774	1				1	1			
	02:00	1,678	1				1	1			
	03:00	1,611	1				1	1			
	04:00	1,570	1				1	1			
	05:00	1,579	1				1	1			
	06:00	1,630	1				1	1			
	07:00	1,772	1				1	1			
	08:00	1,943	1				1	1			
	09:00	2,064	1				1	1			
	10:00	2,160	1				1	1			
	11:00	2,234	1				1	1			
	12:00	2,318	1				1	1	1		
	13:00	2,358	1				1	1	1		
	14:00	2,353	1				1	1	1		
	15:00	2,245	1				1	1			
	16:00	2,152	1				1	1			
	17:00	2,178	1				1	1			
	18:00	2,286	1				1	1	1		
	19:00	2,392	1				1	1	1		
	20:00	2,402	1				1	1	1		
	21:00	2,388	1				1	1	1		
	22:00	2,286	1				1	1	1		
	23:00	2,129	1				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 19 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 19 Ιουνίου 2025	00:00	1,940	1				1	1			
	01:00	1,842	1				1	1			
	02:00	1,755	1				1	1			
	03:00	1,672	1				1	1			
	04:00	1,620	1				1	1			
	05:00	1,607	1				1	1			
	06:00	1,646	1				1	1			
	07:00	1,784	1				1	1			
	08:00	1,939	1				1	1			
	09:00	2,075	1				1	1			
	10:00	2,187	1				1	1			
	11:00	2,283	1				1	1	1		
	12:00	2,354	1				1	1	1		
	13:00	2,372	1				1	1	1		
	14:00	2,373	1				1	1	1		
	15:00	2,288	1				1	1	1		
	16:00	2,273	1				1	1	1		
	17:00	2,282	1				1	1	1		
	18:00	2,355	1				1	1	1		
	19:00	2,409	1				1	1	1		
	20:00	2,409	1				1	1	1		
	21:00	2,335	1				1	1	1		
	22:00	2,186	1				1	1			
	23:00	1,988	1				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 20 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 20 Ιουνίου 2025	00:00	1,883	1				1	1			
	01:00	1,785	1				1	1			
	02:00	1,697	1				1	1			
	03:00	1,625	1				1	1			
	04:00	1,579	1				1	1			
	05:00	1,573	1				1	1			
	06:00	1,600	1				1	1			
	07:00	1,765	1				1	1			
	08:00	1,911	1				1	1			
	09:00	2,048	1				1	1			
	10:00	2,172	1				1	1			
	11:00	2,277	1				1	1	1		
	12:00	2,365	1				1	1	1		
	13:00	2,420	1				1	1	1		
	14:00	2,440	1				1	1	1		
	15:00	2,392	1				1	1	1		
	16:00	2,368	1				1	1	1		
	17:00	2,369	1				1	1	1		
	18:00	2,439	1				1	1	1		
	19:00	2,493	1				1	1	1		
	20:00	2,485	1				1	1	1		
	21:00	2,375	1				1	1	1		
	22:00	2,221	1				1	1			
	23:00	2,005	1				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 21 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 21 Ιουνίου 2025	00:00	1,939	1			1	1				
	01:00	1,838	1			1	1				
	02:00	1,748	1			1	1				
	03:00	1,673	1			1	1				
	04:00	1,621	1			1	1				
	05:00	1,599	1			1	1				
	06:00	1,614	1			1	1				
	07:00	1,752	1			1	1				
	08:00	1,895	1			1	1				
	09:00	2,037	1			1	1				
	10:00	2,161	1			1	1				
	11:00	2,276	1			1	1	1			
	12:00	2,373	1			1	1	1			
	13:00	2,433	1			1	1	1			
	14:00	2,445	1			1	1	1			
	15:00	2,404	1			1	1	1			
	16:00	2,358	1			1	1	1			
	17:00	2,374	1			1	1	1			
	18:00	2,415	1			1	1	1			
	19:00	2,465	1			1	1	1			
	20:00	2,448	1			1	1	1			
	21:00	2,321	1			1	1	1			
	22:00	2,157	1			1	1				
	23:00	1,948	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 22 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 22 Ιουνίου 2025	00:00	1,901	1			1	1				
	01:00	1,804	1			1	1				
	02:00	1,717	1			1	1				
	03:00	1,643	1			1	1				
	04:00	1,594	1			1	1				
	05:00	1,573	1			1	1				
	06:00	1,586	1			1	1				
	07:00	1,719	1			1	1				
	08:00	1,855	1			1	1				
	09:00	2,011	1			1	1				
	10:00	2,141	1			1	1				
	11:00	2,257	1			1	1				
	12:00	2,370	1			1	1	1			
	13:00	2,441	1			1	1	1			
	14:00	2,457	1			1	1	1			
	15:00	2,413	1			1	1	1			
	16:00	2,360	1			1	1	1			
	17:00	2,380	1			1	1	1			
	18:00	2,433	1			1	1	1			
	19:00	2,505	1			1	1	1			
	20:00	2,471	1			1	1	1			
	21:00	2,390	1			1	1	1			
	22:00	2,266	1			1	1	1			
	23:00	2,074	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 23 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 23 Ιουνίου 2025	00:00	2,011	1			1	1				
	01:00	1,913	1			1	1				
	02:00	1,821	1			1	1				
	03:00	1,746	1			1	1				
	04:00	1,698	1			1	1				
	05:00	1,689	1			1	1				
	06:00	1,717	1			1	1				
	07:00	1,857	1			1	1				
	08:00	2,017	1			1	1				
	09:00	2,146	1			1	1				
	10:00	2,248	1			1	1				
	11:00	2,336	1			1	1	1			
	12:00	2,426	1			1	1	1			
	13:00	2,509	1			1	1	1			
	14:00	2,531	1			1	1	1			
	15:00	2,512	1			1	1	1			
	16:00	2,464	1			1	1	1			
	17:00	2,437	1			1	1	1			
	18:00	2,474	1			1	1	1			
	19:00	2,554	1			1	1	1			
	20:00	2,551	1			1	1	1			
	21:00	2,486	1			1	1	1			
	22:00	2,375	1			1	1	1			
	23:00	2,186	1			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 24 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 24 Ιουνίου 2025	00:00	2,123	1				1	1			
	01:00	2,021	1				1	1			
	02:00	1,926	1				1	1			
	03:00	1,837	1				1	1			
	04:00	1,774	1				1	1			
	05:00	1,770	1				1	1			
	06:00	1,807	1				1	1			
	07:00	1,924	1				1	1			
	08:00	2,073	1				1	1			
	09:00	2,202	1				1	1			
	10:00	2,315	1				1	1	1		
	11:00	2,415	1				1	1	1		
	12:00	2,508	1				1	1	1		
	13:00	2,570	1				1	1	1		
	14:00	2,600	1				1	1	1		
	15:00	2,547	1				1	1	1		
	16:00	2,467	1				1	1	1		
	17:00	2,429	1				1	1	1		
	18:00	2,475	1				1	1	1		
	19:00	2,561	1				1	1	1		
	20:00	2,582	1				1	1	1		
	21:00	2,489	1				1	1	1		
	22:00	2,341	1				1	1	1		
	23:00	2,122	1				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης