

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 25 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 25 Ιουνίου 2025	00:00	2,082	1			1	1				
	01:00	1,986	1			1	1				
	02:00	1,885	1			1	1				
	03:00	1,810	1			1	1				
	04:00	1,756	1			1	1				
	05:00	1,722	1			1	1				
	06:00	1,760	1			1	1				
	07:00	1,878	1			1	1				
	08:00	2,044	1			1	1				
	09:00	2,174	1			1	1				
	10:00	2,290	1			1	1	1			
	11:00	2,398	1			1	1	1			
	12:00	2,470	1			1	1	1			
	13:00	2,535	1			1	1	1			
	14:00	2,556	1			1	1	1			
	15:00	2,567	1			1	1	1			
	16:00	2,549	1			1	1	1			
	17:00	2,505	1			1	1	1			
	18:00	2,562	1			1	1	1			
	19:00	2,683	1			1	1	1			
	20:00	2,694	1			1	1	1			
	21:00	2,701	1			1	1	1			
	22:00	2,517	1			1	1	1			
	23:00	2,284	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 26 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 26 Ιουνίου 2025	00:00	2,213	1			1	1				
	01:00	2,108	1			1	1				
	02:00	1,997	1			1	1				
	03:00	1,903	1			1	1				
	04:00	1,845	1			1	1				
	05:00	1,816	1			1	1				
	06:00	1,846	1			1	1				
	07:00	1,975	1			1	1				
	08:00	2,128	1			1	1				
	09:00	2,284	1			1	1	1			
	10:00	2,415	1			1	1	1			
	11:00	2,537	1			1	1	1			
	12:00	2,657	1			1	1	1			
	13:00	2,768	1			1	1	1			
	14:00	2,827	1			1	1	1			
	15:00	2,830	1			1	1	1			
	16:00	2,730	1			1	1	1			
	17:00	2,699	1			1	1	1			
	18:00	2,748	1			1	1	1			
	19:00	2,813	1			1	1	1			
	20:00	2,777	1			1	1	1			
	21:00	2,676	1			1	1	1			
	22:00	2,493	1			1	1	1			
	23:00	2,252	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 27 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 27 Ιουνίου 2025	00:00	2,284	1			1	1	1			
	01:00	2,165	1			1	1				
	02:00	2,062	1			1	1				
	03:00	1,973	1			1	1				
	04:00	1,907	1			1	1				
	05:00	1,876	1			1	1				
	06:00	1,887	1			1	1				
	07:00	2,007	1			1	1				
	08:00	2,164	1			1	1				
	09:00	2,336	1			1	1	1			
	10:00	2,492	1			1	1	1			
	11:00	2,636	1			1	1	1			
	12:00	2,763	1			1	1	1			
	13:00	2,881	1			1	1	1	1		
	14:00	2,954	1			1	1	1	1		
	15:00	2,931	1			1	1	1	1		
	16:00	2,854	1			1	1	1			
	17:00	2,770	1			1	1	1			
	18:00	2,852	1			1	1	1			
	19:00	2,923	1			1	1	1	1		
	20:00	2,864	1			1	1	1	1		
	21:00	2,756	1			1	1	1			
	22:00	2,604	1			1	1	1			
	23:00	2,409	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 28 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 28 Ιουνίου 2025	00:00	2,436	1			1	1	1			
	01:00	2,315	1			1	1	1			
	02:00	2,201	1			1	1				
	03:00	2,095	1			1	1				
	04:00	2,015	1			1	1				
	05:00	1,970	1			1	1				
	06:00	1,971	1			1	1				
	07:00	2,077	1			1	1				
	08:00	2,221	1			1	1				
	09:00	2,388	1			1	1	1			
	10:00	2,553	1			1	1	1			
	11:00	2,701	1			1	1	1			
	12:00	2,824	1			1	1	1			
	13:00	2,940	1			1	1	1	1		
	14:00	3,022	1			1	1	1	1		
	15:00	3,031	1			1	1	1	1		
	16:00	2,981	1			1	1	1	1		
	17:00	2,931	1			1	1	1	1		
	18:00	2,971	1			1	1	1	1		
	19:00	3,006	1			1	1	1	1		
	20:00	2,962	1			1	1	1	1		
	21:00	2,888	1			1	1	1	1		
	22:00	2,811	1			1	1	1			
	23:00	2,656	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 29 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 29 Ιουνίου 2025	00:00	2,670	1			1	1	1			
	01:00	2,545	1			1	1	1			
	02:00	2,421	1			1	1	1			
	03:00	2,309	1			1	1	1			
	04:00	2,215	1			1	1				
	05:00	2,175	1			1	1				
	06:00	2,154	1			1	1				
	07:00	2,199	1			1	1				
	08:00	2,296	1			1	1	1			
	09:00	2,427	1			1	1	1			
	10:00	2,551	1			1	1	1			
	11:00	2,666	1			1	1	1			
	12:00	2,772	1			1	1	1			
	13:00	2,868	1			1	1	1			
	14:00	2,939	1			1	1	1	1		
	15:00	2,960	1			1	1	1	1		
	16:00	2,947	1			1	1	1	1		
	17:00	2,933	1			1	1	1	1		
	18:00	2,975	1			1	1	1	1		
	19:00	3,021	1			1	1	1	1		
	20:00	2,982	1			1	1	1	1		
	21:00	2,946	1			1	1	1	1		
	22:00	2,900	1			1	1	1	1		
	23:00	2,745	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 30 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 30 Ιουνίου 2025	00:00	2,710	1			1	1	1			
	01:00	2,577	1			1	1	1			
	02:00	2,448	1			1	1	1			
	03:00	2,330	1			1	1	1			
	04:00	2,235	1			1	1				
	05:00	2,179	1			1	1				
	06:00	2,182	1			1	1				
	07:00	2,276	1			1	1	1			
	08:00	2,408	1			1	1	1			
	09:00	2,556	1			1	1	1			
	10:00	2,682	1			1	1	1			
	11:00	2,797	1			1	1	1			
	12:00	2,898	1			1	1	1	1		
	13:00	2,980	1			1	1	1	1		
	14:00	3,028	1			1	1	1	1		
	15:00	3,013	1			1	1	1	1		
	16:00	2,968	1			1	1	1	1		
	17:00	2,921	1			1	1	1	1		
	18:00	2,973	1			1	1	1	1		
	19:00	3,041	1			1	1	1	1		
	20:00	3,073	1			1	1	1	1		
	21:00	3,041	1			1	1	1	1		
	22:00	2,910	1			1	1	1	1		
	23:00	2,690	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 1 Ιουλίου 2025				
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ε Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 1 Ιουλίου 2025	00:00	2,605	1			1	1	1			
	01:00	2,452	1			1	1	1			
	02:00	2,310	1			1	1	1			
	03:00	2,188	1			1	1				
	04:00	2,096	1			1	1				
	05:00	2,039	1			1	1				
	06:00	2,072	1			1	1				
	07:00	2,208	1			1	1				
	08:00	2,380	1			1	1	1			
	09:00	2,563	1			1	1	1			
	10:00	2,710	1			1	1	1			
	11:00	2,833	1			1	1	1			
	12:00	2,926	1			1	1	1	1		
	13:00	3,000	1			1	1	1	1		
	14:00	3,036	1			1	1	1	1		
	15:00	3,014	1			1	1	1	1		
	16:00	2,968	1			1	1	1	1		
	17:00	2,937	1			1	1	1	1		
	18:00	2,994	1			1	1	1	1		
	19:00	3,075	1			1	1	1	1		
	20:00	3,115	1			1	1	1	1		
	21:00	3,049	1			1	1	1	1		
	22:00	2,896	1			1	1	1	1		
	23:00	2,661	1			1	1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης