

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 1 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τρίτη, 1 Ιουλίου 2025	00:00	1,610		1	1				
	01:00	1,564		1	1				
	02:00	1,489		1	1				
	03:00	1,420		1	1				
	04:00	1,433		1	1				
	05:00	1,311		1	1				
	06:00	1,350		1	1				
	07:00	1,472		1	1	1			
	08:00	1,618		1	1	1			
	09:00	1,721		1	1	1			
	10:00	1,724		1	1	1			
	11:00	1,748		1	1	1			
	12:00	1,785		1	1	1			
	13:00	1,788		1	1	1			
	14:00	1,802		1	1				
	15:00	1,741		1	1				
	16:00	1,753		1	1				
	17:00	1,837		1	1				
	18:00	1,943		1	1				
	19:00	1,994	1	1	1				
	20:00	2,122	1	1	1				
	21:00	2,209	1	1	1				
	22:00	2,092	1	1	1				
	23:00	1,881	1	1	1				

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 2 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τετάρτη, 2 Ιουλίου 2025	00:00	1,687		1	1				
	01:00	1,572		1	1				
	02:00	1,484		1	1				
	03:00	1,431		1	1				
	04:00	1,407		1	1				
	05:00	1,409		1	1				
	06:00	1,419		1	1				
	07:00	1,508		1	1	1			
	08:00	1,620		1	1	1			
	09:00	1,783		1	1	1			
	10:00	1,860		1	1	1			
	11:00	1,820		1	1	1			
	12:00	1,822		1	1	1			
	13:00	1,800		1	1	1			
	14:00	1,774		1	1				
	15:00	1,517		1	1				
	16:00	1,407	1		1	1			
	17:00	1,882	1	1	1				
	18:00	2,013	1	1	1				
	19:00	2,099	1	1	1				
	20:00	2,123	1	1	1				
	21:00	2,192	1	1	1				
	22:00	2,064	1	1	1				
	23:00	1,889	1	1	1				

Μισθωμένη ισχύς 1 MW. Γενική διακοπή κατά το διάστημα 15:50 – 16:20 λόγω βλάβης της G2.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 3 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Πέμπτη, 3 Ιουλίου 2025	00:00	1,692		1	1				
	01:00	1,566		1	1				
	02:00	1,491		1	1				
	03:00	1,474		1	1				
	04:00	1,420		1	1				
	05:00	1,434		1	1				
	06:00	1,429		1	1				
	07:00	1,547		1	1	1			
	08:00	1,677		1	1	1			
	09:00	1,622		1	1	1			
	10:00	1,653		1	1	1			
	11:00	1,568		1	1	1			
	12:00	1,633		1	1	1			
	13:00	1,736		1	1	1			
	14:00	1,745		1	1	1			
	15:00	1,716		1	1	1			
	16:00	1,683		1	1	1			
	17:00	1,749		1	1	1			
	18:00	1,794		1	1	1			
	19:00	1,875		1	1	1			
	20:00	1,954		1	1	1			
	21:00	1,979		1	1	1			
	22:00	1,914		1	1	1			
	23:00	1,751		1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 4 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Παρασκευή, 4 Ιουλίου 2025	00:00	1,613		1	1				
	01:00	1,445		1	1				
	02:00	1,389		1	1				
	03:00	1,261		1	1				
	04:00	1,234		1	1				
	05:00	1,219		1	1				
	06:00	1,219		1	1				
	07:00	1,339		1	1				
	08:00	1,560		1	1	1			
	09:00	1,816		1	1	1			
	10:00	1,898		1	1	1			
	11:00	1,945		1	1	1			
	12:00	1,941		1	1	1			
	13:00	1,913		1	1	1			
	14:00	1,904		1	1	1			
	15:00	1,821		1	1	1			
	16:00	1,882		1	1	1			1
	17:00	1,938		1	1	1			1
	18:00	2,078		1	1	1			1
	19:00	2,156		1	1	1			
	20:00	2,180		1	1	1			
	21:00	2,207		1	1	1			
	22:00	2,100		1	1	1			
	23:00	1,951		1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 5 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Υ Λ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Σάββατο, 5 Ιουλίου 2025	00:00	1,767		1	1				
	01:00	1,654		1	1				
	02:00	1,582		1	1				
	03:00	1,514		1	1				
	04:00	1,484		1	1				
	05:00	1,461		1	1				
	06:00	1,470		1	1				
	07:00	1,571		1	1				
	08:00	1,727		1	1				
	09:00	1,826		1					1
	10:00	1,880		1					1
	11:00	1,942		1					1
	12:00	2,023		1					1
	13:00	2,006		1	1				1
	14:00	1,940		1	1				1
	15:00	1,951		1	1				1
	16:00	1,991		1	1				1
	17:00	1,909		1	1				1
	18:00	2,052		1	1				1
	19:00	2,133		1	1				1
	20:00	2,131		1	1				1
	21:00	2,260		1	1				1
	22:00	2,163		1	1				1
	23:00	2,015		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 6 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Κυριακή, 6 Ιουλίου 2025	00:00	1,798	1		1				
	01:00	1,704	1		1				
	02:00	1,624	1		1				
	03:00	1,552	1		1				
	04:00	1,501	1		1				
	05:00	1,504	1		1				
	06:00	1,484	1		1				
	07:00	1,513	1		1				
	08:00	1,707		1	1				
	09:00	1,818		1	1	1			
	10:00	1,906		1	1	1			
	11:00	1,950		1	1	1			
	12:00	1,972		1	1	1			
	13:00	2,112		1	1	1			
	14:00	2,011		1	1	1			
	15:00	1,962		1	1	1			
	16:00	1,995		1	1	1			
	17:00	2,033		1	1	1			
	18:00	2,151		1	1	1			
	19:00	2,187		1	1	1			
	20:00	2,269		1	1	1			
	21:00	2,258		1	1	1			
	22:00	2,161		1	1	1			
	23:00	2,003		1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 7 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Υ Λ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Δευτέρα, 7 Ιουλίου 2025	00:00	1,782		1	1				
	01:00	1,680		1	1				
	02:00	1,606		1	1				
	03:00	1,568		1	1				
	04:00	1,506		1	1				
	05:00	1,482		1	1				
	06:00	1,496		1	1				
	07:00	1,605		1	1				
	08:00	1,815		1	1	1			
	09:00	1,977		1	1	1			
	10:00	2,025		1	1	1			
	11:00	2,004		1	1	1			
	12:00	2,077			1	1			1
	13:00	2,116			1	1			1
	14:00	2,139			1	1			1
	15:00	2,054			1	1			1
	16:00	2,106			1	1			1
	17:00	2,163			1	1			1
	18:00	2,225			1	1			1
	19:00	2,335			1	1			1
	20:00	2,457			1	1			1
	21:00	2,461			1	1			1
	22:00	2,329			1	1			1
	23:00	2,127			1	1			1

Μισθωμένη ισχύς 1 MW.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης