

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας			Δευτέρα, 30 Ιούνιος 2025							
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Δευτέρα, 30 Ιούνιος 2025	00:00	40,96		1	1	1	1	1	1		1		6
	01:00	38,55		1	1	1	1	1	1		1		4
	02:00	37,34		1	1	1	1	1	1		1		4
	03:00	36,43		1	1	1	1	1	1		1		4
	04:00	35,75		1	1	1	1	1	1		1		4
	05:00	35,55		1	1	1	1	1	1		1		4
	06:00	36,24		1	1	1	1	1	1		1		5
	07:00	39,56		1	1	1	1	1	1		1	1	3
	08:00	42,66		1	1	1	1	1	1		1	1	8
	09:00	45,89		1	1	1	1	1	1		1	1	9
	10:00	47,99		1	1	1	1	1	1		1	1	13
	11:00	49,00		1	1	1	1		1		1	1	13
	12:00	50,62		1	1	1	1		1		1	1	13
	13:00	51,61		1	1	1	1		1		1	1	13
	14:00	51,39		1	1	1	1		1		1	1	13
	15:00	50,75		1	1	1	1	1	1		1	1	9
	16:00	50,36		1	1	1	1	1	1		1	1	9
	17:00	50,26		1	1	1	1	1	1		1	1	9
	18:00	51,46		1	1	1	1	1	1		1	1	10
	19:00	51,32		1	1	1	1	1	1		1	1	10
	20:00	50,35		1	1	1	1	1	1		1	1	16
	21:00	50,90		1	1	1	1	1	1		1	1	13
	22:00	48,21		1	1		1	1	1		1	1	10
	23:00	44,35		1	1		1	1	1		1	1	8

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10 MW. Η G31 & G32 βρίσκονται σε δοκιμαστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης