

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Τρίτη, 1 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τρίτη, 1 Ιούλιος 2025	00:00	41,11		1	1		1	1	1		1	1	6
	01:00	38,26		1	1		1	1	1		1	1	
	02:00	36,31		1	1		1	1	1		1	1	
	03:00	35,61		1	1		1		1		1	1	
	04:00	34,53		1	1		1		1		1	1	
	05:00	34,40		1	1		1		1		1	1	
	06:00	35,72		1	1		1		1		1	1	1
	07:00	39,48		1	1		1		1		1	1	6
	08:00	43,51		1	1		1		1		1	1	10
	09:00	46,32		1	1		1		1		1	1	12
	10:00	49,37		1	1		1		1		1	1	14
	11:00	51,49		1	1		1		1		1	1	14
	12:00	52,49		1	1	1	1		1		1	1	14
	13:00	52,33		1	1	1	1		1		1	1	21
	14:00	54,49		1	1	1	1	1		1	1	1	14
	15:00	53,94		1	1	1	1	1		1	1	1	13
	16:00	53,25		1	1	1	1	1		1	1	1	15
	17:00	53,66		1	1	1		1		1	1	1	15
	18:00	54,10		1	1	1		1		1	1	1	14
	19:00	53,30		1	1	1		1		1	1	1	14
	20:00	52,45		1	1	1		1		1	1	1	14
	21:00	52,63		1	1	1		1		1	1	1	14
	22:00	51,20		1	1	1		1		1	1	1	13
	23:00	46,13		1	1	1		1		1	1	1	8

Μισθωμένη ισχύς 14 MW. Τρία φορητά H/Z βρίσκονται σε βλάβη. Η G31 & G32 βρίσκονται σε δοκιμαστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης