

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 10 Ιούλιος 2025									
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000	
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)	
Πέμπτη, 10 Ιούλιος 2025	00:00	44,66		1	1	1	1		1	1	1	1		
	01:00	41,28		1	1	1	1		1	1	1	1		
	02:00	40,13		1	1	1	1		1	1	1	1	1	
	03:00	38,72		1	1	1	1		1	1	1	1	1	
	04:00	37,90		1	1	1	1		1	1	1	1	1	
	05:00	38,22		1	1	1	1		1	1	1	1	1	
	06:00	39,62		1	1	1	1		1	1	1	1	1	
	07:00	43,90		1	1	1	1		1	1	1	1	1	
	08:00	48,19		1	1	1	1		1	1	1	1	1	2
	09:00	51,87		1	1	1	1		1	1	1	1	1	7
	10:00	53,94		1	1	1	1		1	1	1	1	1	8
	11:00	51,15		1	1	1	1		1	1	1	1	1	8
	12:00	55,31		1	1	1	1		1	1	1	1	1	13
	13:00	57,14		1	1	1	1		1	1	1	1	1	12
	14:00	57,38		1	1	1	1		1	1	1	1	1	12
	15:00	56,15		1	1	1	1		1	1	1	1	1	11
	16:00	55,50		1	1	1	1		1	1	1	1	1	11
	17:00	55,48		1	1	1	1		1	1	1	1	1	11
	18:00	55,04		1	1	1	1		1	1	1	1	1	11
	19:00	54,97		1	1	1	1		1	1	1	1	1	9
	20:00	53,49		1	1	1	1		1	1	1	1	1	9
	21:00	52,64		1	1	1	1		1	1	1	1	1	8
	22:00	49,37		1	1	1	1		1	1	1	1	1	6
	23:00	46,01		1	1	1	1		1	1	1	1	1	

Μισθωμένη ισχύς 14 MW. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη. Μερική διακοπή 11:20 - 12:11.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης