

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 12 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)		7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	10,000	10,000	1,100	
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Σάββατο, 12 Ιούλιος 2025	00:00	41,72		1	1	1	1	1	1	1	1	1	
	01:00	39,14		1	1	1	1	1		1	1	1	
	02:00	38,14		1	1	1	1	1		1	1	1	
	03:00	37,14		1	1	1	1	1		1	1	1	
	04:00	37,01		1	1	1	1	1		1	1	1	
	05:00	36,66		1	1	1	1	1		1	1	1	
	06:00	37,82		1	1	1	1	1		1	1	1	
	07:00	41,51		1	1	1	1	1		1	1	1	
	08:00	40,92		1	1	1	1	1		1	1	1	3
	09:00	48,68		1	1	1	1	1		1	1	1	7
	10:00	51,31		1	1	1	1	1		1	1	1	7
	11:00	52,79		1	1	1	1	1		1	1	1	7
	12:00	53,80		1	1	1	1	1		1	1	1	9
	13:00	55,04		1	1	1	1	1		1	1	1	9
	14:00	54,93		1	1	1	1	1		1	1	1	9
	15:00	54,30		1	1	1	1	1		1	1	1	9
	16:00	53,95		1	1	1	1	1		1	1	1	9
	17:00	54,46		1	1	1	1	1		1	1	1	9
	18:00	55,06		1	1	1	1	1		1	1	1	9
	19:00	53,89		1	1	1	1	1		1	1	1	9
	20:00	52,98		1	1	1	1	1		1	1	1	9
	21:00	52,03		1	1	1	1	1		1	1	1	9
	22:00	50,45		1	1	1	1	1		1	1	1	7
	23:00	47,12		1	1	1	1	1		1	1	1	3

Μισθωμένη ισχύς 14 MW. Τρία φορητά H/Z βρίσκονται σε βλάβη. Πλύσιμο της G2 06:12-06:54. Μερική διακοπή 08:01-08:49.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης