

ΗΣ ΚΥΘΟΟΥ		Προτεινόμενος ΗΕΠ				Πέμπτη, 3 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ε Ε Ρ Α Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Πέμπτη, 3 Ιουλίου 2025	00:00	1,966		1					1		1	
	01:00	1,802		1					1		1	
	02:00	1,684		1					1		1	
	03:00	1,615		1							1	
	04:00	1,572		1							1	
	05:00	1,540		1							1	
	06:00	1,549		1							1	
	07:00	1,588		1							1	
	08:00	1,649		1							1	
	09:00	1,726		1					1		1	
	10:00	1,810		1					1		1	
	11:00	1,887		1					1		1	
	12:00	1,917		1					1		1	
	13:00	1,929		1					1		1	
	14:00	1,921		1					1		1	
	15:00	1,900		1					1		1	
	16:00	1,934		1					1		1	
	17:00	1,994		1					1		1	
	18:00	2,134		1					1		1	
	19:00	2,278		1					1		1	
	20:00	2,260		1					1		1	
	21:00	2,281		1					1		1	
	22:00	2,204		1					1		1	
23:00	2,083		1					1		1		

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 4 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Παρασκευή, 4 Ιουλίου 2025	00:00	1,949		1					1		1	
	01:00	1,789		1					1		1	
	02:00	1,671		1					1		1	
	03:00	1,596		1							1	
	04:00	1,552		1							1	
	05:00	1,530		1							1	
	06:00	1,540		1							1	
	07:00	1,588		1							1	
	08:00	1,652		1							1	
	09:00	1,736		1					1		1	
	10:00	1,823		1					1		1	
	11:00	1,889		1					1		1	
	12:00	1,916		1					1		1	
	13:00	1,934		1					1		1	
	14:00	1,932		1					1		1	
	15:00	1,922		1					1		1	
	16:00	2,139		1					1		1	
	17:00	2,194		1					1		1	
	18:00	2,331		1					1		1	
	19:00	2,474		1					1		1	
	20:00	2,479		1					1		1	
	21:00	2,408		1					1		1	
	22:00	2,313		1					1		1	
	23:00	2,164		1					1		1	

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 5 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ Θ Ε Τ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Σάββατο, 5 Ιουλίου 2025	00:00	2,114		1					1		1	
	01:00	1,967		1					1		1	
	02:00	1,841		1					1		1	
	03:00	1,742		1					1		1	
	04:00	1,671		1							1	
	05:00	1,627		1							1	
	06:00	1,621		1							1	
	07:00	1,688		1							1	
	08:00	1,801		1					1		1	
	09:00	1,901		1					1		1	
	10:00	2,012		1					1		1	
	11:00	2,097		1					1		1	
	12:00	2,154		1					1		1	
	13:00	2,180		1					1		1	
	14:00	2,190		1					1		1	
	15:00	2,196		1					1		1	
	16:00	2,318		1					1		1	
	17:00	2,375		1					1		1	
	18:00	2,487		1					1		1	
	19:00	2,608		1					1	1	1	
	20:00	2,590		1					1	1	1	
	21:00	2,434		1					1		1	
	22:00	2,332		1					1		1	
	23:00	2,168		1					1		1	

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 6 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ρ Α Τ Η Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Κυριακή, 6 Ιουλίου 2025	00:00	2,250		1					1	1		
	01:00	2,095		1					1	1		
	02:00	1,958		1					1	1		
	03:00	1,843		1					1	1		
	04:00	1,756		1					1	1		
	05:00	1,695		1					1	1		
	06:00	1,669		1					1	1		
	07:00	1,726		1					1	1		
	08:00	1,839		1					1	1		
	09:00	1,923		1					1	1		
	10:00	2,029		1					1	1		
	11:00	2,112		1					1	1		
	12:00	2,161		1					1	1		
	13:00	2,183		1					1	1		
	14:00	2,169		1					1	1		
	15:00	2,143		1					1	1		
	16:00	2,170		1					1	1		
	17:00	2,192		1					1	1		
	18:00	2,275		1					1	1		
	19:00	2,360		1					1	1		
	20:00	2,382		1					1	1		
	21:00	2,291		1					1	1		
	22:00	2,176		1					1	1		
	23:00	2,034		1					1	1		

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 7 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Δευτέρα, 7 Ιουλίου 2025	00:00	2,110		1					1	1		
	01:00	1,947		1					1	1		
	02:00	1,822		1					1	1		
	03:00	1,731		1					1	1		
	04:00	1,670		1						1		
	05:00	1,636		1						1		
	06:00	1,630		1						1		
	07:00	1,682		1						1		
	08:00	1,787		1					1	1		
	09:00	1,868		1					1	1		
	10:00	1,968		1					1	1		
	11:00	2,042		1					1	1		
	12:00	2,110		1					1	1		
	13:00	2,155		1					1	1		
	14:00	2,178		1					1	1		
	15:00	2,177		1					1	1		
	16:00	2,214		1					1	1		
	17:00	2,254		1					1	1		
	18:00	2,350		1					1	1		
	19:00	2,435		1					1	1		
	20:00	2,425		1					1	1		
	21:00	2,246		1					1	1		
	22:00	2,122		1					1	1		
	23:00	1,983		1					1	1		

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 8 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τρίτη, 8 Ιουλίου 2025	00:00	2,055		1					1	1		
	01:00	1,909		1					1	1		
	02:00	1,795		1					1	1		
	03:00	1,713		1					1	1		
	04:00	1,660		1					1			
	05:00	1,633		1					1			
	06:00	1,641		1					1			
	07:00	1,697		1					1	1		
	08:00	1,816		1					1	1		
	09:00	1,929		1					1	1		
	10:00	2,054		1					1	1		
	11:00	2,165		1					1	1		
	12:00	2,257		1					1	1		
	13:00	2,325		1					1	1		
	14:00	2,348		1					1	1		
	15:00	2,342		1					1	1		
	16:00	2,374		1					1	1		
	17:00	2,408		1					1	1		
	18:00	2,506		1					1	1		
	19:00	2,581		1					1	1		
	20:00	2,531		1					1	1		
	21:00	2,344		1					1	1		
	22:00	2,233		1					1	1		
	23:00	2,090		1					1	1		

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 9 Ιουλίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,300	0,300	0,300	0,300	1,000	1,000	1,000	1,000		
Ρ	Θ	Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	HZ (x2)
Τετάρτη, 9 Ιουλίου 2025			00:00	2,178		1					1	1		
			01:00	2,024		1					1	1		
			02:00	1,890		1					1	1		
			03:00	1,801		1					1	1		
			04:00	1,746		1					1	1		
			05:00	1,712		1					1	1		
			06:00	1,709		1					1	1		
			07:00	1,750		1					1	1		
			08:00	1,849		1					1	1		
			09:00	1,977		1					1	1		
			10:00	2,129		1					1	1		
			11:00	2,269		1					1	1		
			12:00	2,362		1					1	1		
			13:00	2,426		1					1	1		
			14:00	2,450		1					1	1		
			15:00	2,450		1					1	1		
			16:00	2,481		1					1	1		
			17:00	2,529		1					1	1		
			18:00	2,645		1					1	1		1
			19:00	2,755		1					1	1		1
			20:00	2,691		1					1	1		1
			21:00	2,520		1					1	1		1
			22:00	2,412		1					1	1		
			23:00	2,244		1					1	1		

Μισθωμένη ισχύς 2 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης