

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 2 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ρ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τετάρτη, 2 Ιουλίου 2025	00:00	1,793			1			1	1	
	01:00	1,610			1			1	1	
	02:00	1,555			1			1	1	
	03:00	1,438			1			1	1	
	04:00	1,398						1	1	
	05:00	1,343						1	1	
	06:00	1,363						1	1	
	07:00	1,411						1	1	
	08:00	1,558						1	1	
	09:00	1,632						1	1	
	10:00	1,671						1	1	
	11:00	1,693						1	1	
	12:00	1,703				1		1	1	
	13:00	1,745				1		1	1	
	14:00	1,707				1		1	1	
	15:00	1,718				1		1	1	
	16:00	1,760				1		1	1	
	17:00	1,837				1		1	1	
	18:00	1,916				1		1	1	
	19:00	1,945				1		1	1	
	20:00	1,922				1		1	1	
	21:00	1,912				1		1	1	
	22:00	1,836				1		1	1	
	23:00	1,834				1		1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 3 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Πέμπτη, 3 Ιουλίου 2025	00:00	1,536				1			1	
	01:00	1,421				1			1	
	02:00	1,323				1			1	
	03:00	1,269				1			1	
	04:00	1,197				1			1	
	05:00	1,202				1			1	
	06:00	1,214				1			1	
	07:00	1,318				1			1	
	08:00	1,455				1			1	
	09:00	1,569				1			1	
	10:00	1,638			1	1			1	
	11:00	1,702			1	1			1	
	12:00	1,656			1	1			1	
	13:00	1,719			1	1			1	
	14:00	1,736			1	1			1	
	15:00	1,710			1	1			1	
	16:00	1,739			1	1			1	
	17:00	1,871			1	1			1	
	18:00	1,906			1	1			1	
	19:00	1,960			1	1			1	
	20:00	2,017			1	1			1	
	21:00	2,004			1	1			1	
	22:00	1,922			1	1			1	
	23:00	1,712			1	1			1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 4 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Παρασκευή, 4 Ιουλίου 2025	00:00	1,524			1	1			1	
	01:00	1,399			1				1	
	02:00	1,325			1				1	
	03:00	1,259			1				1	
	04:00	1,229			1				1	
	05:00	1,227			1				1	
	06:00	1,255			1				1	
	07:00	1,289			1				1	
	08:00	1,484			1				1	
	09:00	1,632			1			1	1	
	10:00	1,726			1			1	1	
	11:00	1,792			1			1	1	
	12:00	1,800			1			1	1	
	13:00	1,853			1			1	1	
	14:00	1,844			1			1	1	
	15:00	1,828			1			1	1	
	16:00	1,880			1			1	1	
	17:00	1,924			1			1	1	
	18:00	2,010			1			1	1	
	19:00	2,138			1			1	1	
	20:00	2,125			1			1	1	
	21:00	2,169			1			1	1	
	22:00	2,012			1			1	1	
	23:00	1,848			1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 5 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Σάββατο, 5 Ιουλίου 2025	00:00	1,647			1			1	1	
	01:00	1,497			1			1		
	02:00	1,392			1			1		
	03:00	1,341			1			1		
	04:00	1,263			1			1		
	05:00	1,253			1			1		
	06:00	1,286			1			1		
	07:00	1,446			1			1		
	08:00	1,551			1			1	1	
	09:00	1,683			1			1	1	
	10:00	1,828			1			1	1	
	11:00	1,884			1			1	1	
	12:00	1,897			1			1	1	
	13:00	1,911			1			1	1	
	14:00	1,884			1			1	1	
	15:00	1,956			1			1	1	
	16:00	1,976			1			1	1	
	17:00	2,068			1			1	1	
	18:00	2,143			1			1	1	
	19:00	2,210			1			1	1	
	20:00	2,256			1			1	1	
	21:00	2,273			1			1	1	
	22:00	2,134			1			1	1	
	23:00	2,029			1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 6 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ε Σ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Κυριακή, 6 Ιουλίου 2025	00:00	1,894				1		1	1	
	01:00	1,720				1		1	1	
	02:00	1,603				1		1	1	
	03:00	1,541						1	1	
	04:00	1,498						1	1	
	05:00	1,481						1	1	
	06:00	1,427						1	1	
	07:00	1,512						1	1	
	08:00	1,612						1	1	
	09:00	1,805		1				1	1	
	10:00	1,978		1				1	1	
	11:00	2,078		1				1	1	
	12:00	2,060		1				1	1	
	13:00	2,052		1				1	1	
	14:00	2,009		1				1	1	
	15:00	2,001		1				1	1	
	16:00	2,016		1				1	1	
	17:00	2,157		1				1	1	
	18:00	2,152		1				1	1	
	19:00	2,230		1				1	1	
	20:00	2,288		1				1	1	
	21:00	2,313		1				1	1	
	22:00	2,153		1				1	1	
	23:00	1,976		1				1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 7 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Δευτέρα, 7 Ιουλίου 2025	00:00	1,746		1				1	1	
	01:00	1,527		1				1	1	
	02:00	1,423		1					1	
	03:00	1,345		1					1	
	04:00	1,282		1					1	
	05:00	1,270		1					1	
	06:00	1,276		1					1	
	07:00	1,466		1					1	
	08:00	1,627		1					1	
	09:00	1,796		1		1			1	
	10:00	1,958		1		1			1	
	11:00	1,999		1				1	1	
	12:00	2,018		1				1	1	
	13:00	2,065		1				1	1	
	14:00	2,119		1				1	1	
	15:00	2,156		1				1	1	
	16:00	2,183		1				1	1	
	17:00	2,217		1				1	1	
	18:00	2,277		1				1	1	
	19:00	2,345		1				1	1	
	20:00	2,336		1				1	1	
	21:00	2,396		1				1	1	
	22:00	2,326		1				1	1	
	23:00	2,124		1				1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 8 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τρίτη, 8 Ιουλίου 2025	00:00	1,860						1		1
	01:00	1,708		1				1	1	
	02:00	1,569		1				1	1	
	03:00	1,473		1				1	1	
	04:00	1,379		1					1	
	05:00	1,378		1					1	
	06:00	1,351		1					1	
	07:00	1,508		1					1	
	08:00	1,698		1				1	1	
	09:00	1,935		1				1	1	
	10:00	2,038		1				1	1	
	11:00	2,084		1				1	1	
	12:00	2,191		1				1	1	
	13:00	2,252		1				1	1	
	14:00	2,285		1				1	1	
	15:00	2,313		1				1	1	
	16:00	2,304		1				1	1	
	17:00	2,431		1	1			1	1	
	18:00	2,527		1	1			1	1	
	19:00	2,601		1	1			1	1	
	20:00	2,495		1	1			1	1	
	21:00	2,534		1	1			1	1	
	22:00	2,506		1	1			1	1	
	23:00	2,320		1	1			1	1	

Μισθωμένη ισχύς 1 MW.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης