

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 25 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Τετάρτη, 25 Ιουνίου 2025	00:00	1,489				1		1		
	01:00	1,360				1		1		
	02:00	1,283				1		1		
	03:00	1,242				1		1		
	04:00	1,181				1		1		
	05:00	1,215				1		1		
	06:00	1,213				1		1		
	07:00	1,367				1		1		
	08:00	1,494				1		1		
	09:00	1,569				1		1		
	10:00	1,667			1	1		1		
	11:00	1,697			1	1		1		
	12:00	1,719			1	1		1		
	13:00	1,755			1	1		1		
	14:00	1,726			1	1		1		
	15:00	1,754			1	1		1		
	16:00	1,819			1	1		1		
	17:00	1,865			1	1		1		
	18:00	1,981			1	1		1		
	19:00	1,978			1	1		1		
	20:00	2,064			1	1		1		
	21:00	2,102			1	1		1		
	22:00	2,071			1	1		1		
	23:00	1,955			1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 26 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Πέμπτη, 26 Ιουνίου 2025	00:00	1,745			1	1		1		
	01:00	1,612			1	1		1		
	02:00	1,502				1		1		
	03:00	1,465				1		1		
	04:00	1,375				1		1		
	05:00	1,364				1		1		
	06:00	1,353				1		1		
	07:00	1,508				1		1		
	08:00	1,578				1		1		
	09:00	1,714			1	1		1		
	10:00	1,805			1	1		1		
	11:00	1,865			1	1		1		
	12:00	1,836			1	1		1		
	13:00	1,938			1	1		1		
	14:00	1,927			1	1		1		
	15:00	1,900			1	1		1		
	16:00	1,997			1	1		1		
	17:00	2,069			1	1		1		
	18:00	2,122			1	1		1		
	19:00	2,135			1	1		1		
	20:00	2,191			1	1		1		
	21:00	2,168			1	1		1		
	22:00	2,181			1	1		1		
	23:00	2,090			1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 27 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Παρασκευή, 27 Ιουνίου 2025	00:00	1,895			1	1		1		
	01:00	1,776			1	1		1		
	02:00	1,669			1	1		1		
	03:00	1,621			1	1		1		
	04:00	1,542				1		1		
	05:00	1,530				1		1		
	06:00	1,502				1		1		
	07:00	1,640				1		1		
	08:00	1,718			1	1		1		
	09:00	1,837			1	1		1		
	10:00	1,919			1	1		1		
	11:00	1,961			1	1		1		
	12:00	2,048			1	1		1		
	13:00	2,115			1	1		1		
	14:00	2,116			1	1		1		
	15:00	2,108			1	1		1		
	16:00	2,189			1	1		1		
	17:00	2,284			1	1		1		
	18:00	2,327			1	1		1		
	19:00	2,467			1	1		1		
	20:00	2,478		1	1	1		1		
	21:00	2,515		1	1	1		1		
	22:00	2,481		1	1	1		1		
	23:00	2,415		1	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 28 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Σάββατο, 28 Ιουνίου 2025	00:00	2,240			1	1		1		
	01:00	2,069			1	1		1		
	02:00	1,953			1	1		1		
	03:00	1,826			1	1		1		
	04:00	1,715			1	1		1		
	05:00	1,707			1	1		1		
	06:00	1,656			1	1		1		
	07:00	1,731			1	1		1		
	08:00	1,831			1	1		1		
	09:00	1,892			1	1		1		
	10:00	1,964			1	1		1		
	11:00	1,990			1	1		1		
	12:00	2,025			1	1		1		
	13:00	2,109			1	1		1		
	14:00	2,109			1	1		1		
	15:00	2,097			1	1		1		
	16:00	2,169			1	1		1		
	17:00	2,264			1	1		1		
	18:00	2,309			1	1		1		
	19:00	2,307			1	1		1		
	20:00	2,266			1	1		1		
	21:00	2,192			1	1		1		
	22:00	2,173			1	1		1		
	23:00	2,062			1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 29 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Κυριακή, 29 Ιουνίου 2025	00:00	1,875		1	1	1				
	01:00	1,746		1	1	1				
	02:00	1,618		1	1	1				
	03:00	1,583		1	1	1				
	04:00	1,492		1	1	1				
	05:00	1,472		1	1	1				
	06:00	1,461		1		1				
	07:00	1,511		1		1				
	08:00	1,627		1		1				
	09:00	1,731		1	1					
	10:00	1,772		1	1				1	
	11:00	1,869		1	1				1	
	12:00	1,832		1	1				1	
	13:00	1,832		1	1				1	
	14:00	1,812		1	1				1	
	15:00	1,739		1	1				1	
	16:00	1,799		1	1				1	
	17:00	1,851		1	1				1	
	18:00	1,916		1	1				1	
	19:00	1,989		1	1				1	
	20:00	1,949		1	1				1	
	21:00	1,973		1	1				1	
	22:00	1,838		1	1				1	
	23:00	1,687		1	1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 30 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	
Δευτέρα, 30 Ιουνίου 2025	00:00	1,500		1					1	
	01:00	1,358		1					1	
	02:00	1,260		1					1	
	03:00	1,165		1					1	
	04:00	1,152		1					1	
	05:00	1,141		1					1	
	06:00	1,193		1					1	
	07:00	1,293		1					1	
	08:00	1,416		1					1	
	09:00	1,539		1					1	
	10:00	1,633		1	1				1	
	11:00	1,698		1	1				1	
	12:00	1,659		1	1				1	
	13:00	1,692		1	1				1	
	14:00	1,721			1			1	1	
	15:00	1,661			1			1	1	
	16:00	1,725			1			1	1	
	17:00	1,811			1			1	1	
	18:00	1,832			1			1	1	
	19:00	1,954			1			1	1	
	20:00	1,941			1			1	1	
	21:00	1,945			1			1	1	
	22:00	1,865			1			1	1	
	23:00	1,714			1			1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 1 Ιουλίου 2025							
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10	HZ (X1)
Τρίτη, 1 Ιουλίου 2025	00:00	1,524						1	1	
	01:00	1,421						1	1	
	02:00	1,331						1	1	
	03:00	1,282						1	1	
	04:00	1,229						1	1	
	05:00	1,247						1	1	
	06:00	1,265						1	1	
	07:00	1,379						1	1	
	08:00	1,532						1	1	
	09:00	1,709			1			1	1	
	10:00	1,757			1			1	1	
	11:00	1,815			1			1	1	
	12:00	1,819			1			1	1	
	13:00	1,872			1			1	1	
	14:00	1,918			1			1	1	
	15:00	1,918			1			1	1	
	16:00	1,994			1			1	1	
	17:00	2,035			1			1	1	
	18:00	2,096			1			1	1	
	19:00	2,160			1			1	1	
	20:00	2,211			1			1	1	
	21:00	2,260			1			1	1	
	22:00	2,192			1			1	1	
	23:00	1,987			1			1	1	

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης