

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 26 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 26 Ιουνίου 2025	00:00	2,231			1		1	1	
	01:00	2,011			1		1	1	
	02:00	1,907			1			1	
	03:00	1,829			1			1	
	04:00	1,795			1			1	
	05:00	1,717			1			1	
	06:00	1,708			1			1	
	07:00	1,982		1	1			1	
	08:00	2,215	1	1	1				
	09:00	2,240	1	1	1				
	10:00	2,370	1	1	1				
	11:00	2,376	1	1	1				
	12:00	2,383	1	1	1				
	13:00	2,538	1	1	1				
	14:00	2,591	1	1	1				
	15:00	2,453	1	1	1	1			
	16:00	2,346	1	1	1	1			
	17:00	2,412	1	1	1	1			
	18:00	2,631	1	1	1	1			
	19:00	2,755	1	1	1	1			
	20:00	2,817	1	1	1	1			
	21:00	2,874	1	1	1	1			
	22:00	2,671	1	1	1	1			
	23:00	2,526		1	1	1			

Στις 13:47 - 15:58 πραγματοποιήθηκαν εργασίες στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 27 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 27 Ιουνίου 2025	00:00	2,357		1	1	1			
	01:00	2,175		1	1	1			
	02:00	2,085		1	1	1			
	03:00	1,977		1	1	1			
	04:00	1,926		1	1	1			
	05:00	1,914		1	1	1			
	06:00	1,585		1	1	1			
	07:00	1,720		1	1	1			
	08:00	1,886		1	1	1			
	09:00	2,322		1	1	1			
	10:00	2,327		1	1	1			
	11:00	2,367		1	1	1			
	12:00	2,499		1	1	1			
	13:00	2,718		1	1	1			
	14:00	2,757		1	1	1			
	15:00	2,631		1	1	1			
	16:00	2,577		1	1	1			
	17:00	2,738		1	1	1			
	18:00	2,871	1	1	1	1			
	19:00	3,032	1	1	1	1			
	20:00	2,995	1	1	1	1			
	21:00	3,045	1	1	1	1			
	22:00	2,889	1	1	1	1			
	23:00	2,801	1	1	1	1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 28 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 28 Ιουνίου 2025	00:00	2,649		1	1	1			
	01:00	2,473		1	1	1			
	02:00	2,320		1	1	1			
	03:00	2,202		1	1	1			
	04:00	2,109		1	1	1			
	05:00	2,004		1	1	1			
	06:00	1,870		1	1	1			
	07:00	2,131		1	1	1			
	08:00	2,285		1	1	1			
	09:00	2,329			1	1	1		
	10:00	2,364			1	1	1		
	11:00	2,416			1	1	1		
	12:00	2,534			1	1	1		
	13:00	2,635			1	1	1		
	14:00	2,648			1	1	1		
	15:00	2,607			1	1	1		
	16:00	2,573			1	1	1		
	17:00	2,714			1	1	1		
	18:00	2,799	1		1	1	1		
	19:00	2,883	1		1	1	1		
	20:00	2,757	1		1	1	1		
	21:00	2,800	1		1	1	1		
	22:00	2,650	1		1	1	1		
	23:00	2,477			1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 29 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 29 Ιουνίου 2025	00:00	2,320			1	1	1		
	01:00	2,175			1	1	1		
	02:00	2,072			1	1	1		
	03:00	1,976			1	1	1		
	04:00	1,911			1	1	1		
	05:00	1,866			1	1	1		
	06:00	1,801				1	1		
	07:00	1,984	1			1	1		
	08:00	2,135	1			1	1		
	09:00	2,144	1			1	1		
	10:00	2,236	1			1	1		
	11:00	2,232	1			1	1		
	12:00	2,276	1			1	1		
	13:00	2,388	1			1	1		
	14:00	2,080	1			1	1		
	15:00	1,898	1			1	1		
	16:00	1,943	1			1	1		
	17:00	2,086	1			1	1		
	18:00	2,276	1			1	1		
	19:00	2,433	1			1	1		
	20:00	2,419	1			1	1		
	21:00	2,497	1			1	1	1	
	22:00	2,330				1	1	1	
	23:00	2,202				1	1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 30 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 30 Ιουνίου 2025	00:00	1,986				1	1	1	
	01:00	1,830				1	1	1	
	02:00	1,708					1	1	
	03:00	1,629					1	1	
	04:00	1,608					1	1	
	05:00	1,593					1	1	
	06:00	1,624					1	1	
	07:00	1,843					1	1	
	08:00	2,044	1				1	1	
	09:00	2,115	1				1	1	
	10:00	2,205	1				1	1	
	11:00	2,140	1				1	1	
	12:00	2,183	1				1	1	
	13:00	2,348	1				1	1	
	14:00	2,355	1				1	1	
	15:00	2,114	1				1	1	
	16:00	2,081	1				1	1	
	17:00	2,260	1				1	1	
	18:00	2,424	1				1	1	
	19:00	2,576	1				1	1	
	20:00	2,670	1				1	1	
	21:00	2,751	1				1	1	
	22:00	2,572	1				1	1	
	23:00	2,402		1			1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 1 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 1 Ιουλίου 2025	00:00	2,204		1			1	1	
	01:00	2,052		1			1	1	
	02:00	1,929		1			1	1	
	03:00	1,850		1			1	1	
	04:00	1,793		1			1	1	
	05:00	1,807		1				1	
	06:00	1,823		1				1	
	07:00	2,026		1				1	
	08:00	2,203		1	1			1	
	09:00	2,348		1	1			1	
	10:00	2,420		1	1			1	
	11:00	2,442		1	1			1	
	12:00	2,522		1	1			1	
	13:00	2,664		1	1			1	
	14:00	2,655		1	1			1	
	15:00	2,418		1	1			1	
	16:00	2,359		1	1			1	
	17:00	2,491		1	1			1	
	18:00	2,680		1	1			1	
	19:00	2,832	1	1	1			1	
	20:00	2,945	1	1	1			1	
	21:00	2,960	1	1	1			1	
	22:00	2,824	1	1	1			1	
	23:00	2,598	1	1	1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 2 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,100	1,100	1,100	1,100	1,100	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 2 Ιουλίου 2025	00:00	2,355		1	1			1	
	01:00	2,173		1	1			1	
	02:00	2,002		1	1			1	
	03:00	1,895		1	1			1	
	04:00	1,834		1	1			1	
	05:00	1,774			1			1	
	06:00	1,844			1			1	
	07:00	1,995			1			1	
	08:00	2,167			1	1	1		
	09:00	2,260			1	1	1		
	10:00	2,280			1	1	1		
	11:00	2,300			1	1	1		
	12:00	2,314			1	1	1		
	13:00	2,453			1	1	1		
	14:00	2,411			1	1	1		
	15:00	2,241			1	1	1		
	16:00	2,141			1	1	1		
	17:00	2,304			1	1	1		
	18:00	2,497			1	1	1		
	19:00	2,619			1	1	1		
	20:00	2,748			1	1	1		
	21:00	2,841			1	1	1		
	22:00	2,623			1	1	1		
	23:00	2,392			1	1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης