

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 24 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 24 Ιουνίου 2025	00:00	2,139	1				1				1
	01:00	2,007	1				1				1
	02:00	1,910	1				1				1
	03:00	1,847	1				1				1
	04:00	1,796	1				1				1
	05:00	1,755	1				1				1
	06:00	1,693	1				1				1
	07:00	1,952	1				1				1
	08:00	2,078	1				1				1
	09:00	2,187					1			1	1
	10:00	2,286					1			1	1
	11:00	2,462					1			1	1
	12:00	2,547					1			1	1
	13:00	2,663	1				1			1	1
	14:00	2,664	1				1			1	1
	15:00	2,517	1				1			1	1
	16:00	2,436	1				1			1	1
	17:00	2,472	1				1				1
	18:00	2,633	1				1	1			1
	19:00	2,661	1				1	1			1
	20:00	2,598	1				1	1			1
	21:00	2,647	1				1	1			1
	22:00	2,537	1				1	1			1
	23:00	2,350					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 25 Ιουνίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
Η Ρ Α Ρ Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Τετάρτη, 25 Ιουνίου 2025	00:00	2,164				1	1				1	
	01:00	2,001				1	1				1	
	02:00	1,906				1	1				1	
	03:00	1,850				1	1				1	
	04:00	1,799				1	1				1	
	05:00	1,776				1	1				1	
	06:00	1,717				1	1				1	
	07:00	1,979				1	1				1	
	08:00	2,148				1	1				1	
	09:00	2,211				1	1				1	
	10:00	2,307				1	1				1	
	11:00	2,449				1	1			1	1	
	12:00	2,632				1	1			1	1	
	13:00	2,691				1	1			1	1	
	14:00	2,769				1	1			1	1	
	15:00	2,678				1	1			1	1	
	16:00	2,647				1	1			1	1	
	17:00	2,711				1	1			1	1	
	18:00	2,811				1	1			1	1	
	19:00	2,815				1	1			1	1	
	20:00	2,812				1	1			1	1	
	21:00	2,776				1	1			1	1	
	22:00	2,663	1				1	1				1
	23:00	2,461	1				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 26 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 26 Ιουνίου 2025	00:00	2,238	1			1				1	
	01:00	2,099	1			1			1		
	02:00	1,991	1			1			1		
	03:00	1,926	1			1			1		
	04:00	1,856	1			1			1		
	05:00	1,796	1			1			1		
	06:00	1,716	1			1			1		
	07:00	2,041	1			1			1		
	08:00	2,242	1			1			1		
	09:00	2,428				1		1	1		
	10:00	2,540				1		1	1		
	11:00	2,627				1		1	1		
	12:00	2,742	1			1		1	1		
	13:00	2,890	1			1		1	1		
	14:00	2,912	1			1		1	1		
	15:00	2,793	1			1		1	1		
	16:00	2,756	1			1		1	1		
	17:00	2,732	1			1		1	1		
	18:00	2,815	1			1		1	1		
	19:00	2,880	1			1		1	1		
	20:00	2,806	1			1		1	1		
	21:00	2,838	1		1	1		1	1		
	22:00	2,756	1		1	1			1		
	23:00	2,546	1		1	1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 27 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η Ρ Α Σ Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 27 Ιουνίου 2025	00:00	2,374				1	1				1
	01:00	2,222				1	1				1
	02:00	2,112				1	1				1
	03:00	2,046				1	1				1
	04:00	2,015				1	1				1
	05:00	1,985				1	1				1
	06:00	1,883				1	1				1
	07:00	2,150				1	1				1
	08:00	2,408				1	1				1
	09:00	2,614	1			1	1				1
	10:00	2,702	1			1	1				1
	11:00	2,855	1			1	1		1		
	12:00	2,974	1			1	1		1		
	13:00	2,881	1			1	1		1		
	14:00	2,964	1			1	1		1		
	15:00	3,040	1			1	1		1		
	16:00	2,936	1			1	1				1
	17:00	2,814	1			1	1				1
	18:00	2,974	1			1	1				1
	19:00	3,077	1			1	1				1
	20:00	3,027	1			1	1				1
	21:00	2,969	1			1	1				1
	22:00	2,876	1			1	1				1
	23:00	2,728	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 28 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 28 Ιουνίου 2025	00:00	2,577	1			1	1				1
	01:00	2,385				1	1				1
	02:00	2,301				1	1				1
	03:00	2,244				1	1				1
	04:00	2,184				1	1				1
	05:00	2,078				1	1				1
	06:00	1,985				1	1				1
	07:00	2,198				1	1				1
	08:00	2,417				1	1				1
	09:00	2,605				1	1				1
	10:00	2,734				1	1			1	1
	11:00	2,906				1	1			1	1
	12:00	2,978				1	1			1	1
	13:00	3,065				1	1			1	1
	14:00	3,135				1	1			1	1
	15:00	3,109				1	1			1	1
	16:00	3,075				1	1			1	1
	17:00	3,082				1	1			1	1
	18:00	3,019				1	1			1	1
	19:00	3,124				1	1			1	1
	20:00	3,000				1	1			1	1
	21:00	2,950	1			1	1				1
	22:00	2,917	1			1	1				1
	23:00	2,790	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 29 Ιουνίου 2025							
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000	
Η Ρ Α Ρ Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
Κυριακή, 29 Ιουνίου 2025	00:00	2,649	1			1	1				1	
	01:00	2,459	1				1				1	
	02:00	2,325	1				1				1	
	03:00	2,273	1				1				1	
	04:00	2,210	1				1				1	
	05:00	2,155	1				1				1	
	06:00	2,079	1				1				1	
	07:00	2,196					1			1	1	
	08:00	2,329					1			1	1	
	09:00	2,421					1			1	1	
	10:00	2,501					1			1	1	
	11:00	2,634	1				1			1	1	
	12:00	2,606	1				1			1	1	
	13:00	2,602	1				1			1	1	
	14:00	2,662	1				1			1	1	
	15:00	2,665	1				1			1	1	
	16:00	2,690	1				1			1	1	
	17:00	2,743	1				1			1	1	
	18:00	2,816	1				1			1	1	
	19:00	2,810	1				1			1	1	
	20:00	2,901	1				1			1	1	
	21:00	2,988	1				1	1	1		1	1
	22:00	2,917	1				1	1	1			1
	23:00	2,794	1				1	1	1			1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 30 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,900	0,000	0,000	0,900	0,900	0,700	0,700	0,900	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 30 Ιουνίου 2025	00:00	2,576	1			1	1				1
	01:00	2,392	1			1	1				
	02:00	2,266	1			1	1				
	03:00	2,182	1			1	1				
	04:00	2,122	1			1	1				
	05:00	2,028	1			1	1				
	06:00	1,930	1			1	1				
	07:00	2,204	1			1	1				
	08:00	2,347	1			1	1			1	
	09:00	2,484	1			1	1			1	
	10:00	2,530	1			1	1			1	
	11:00	2,615				1	1			1	1
	12:00	2,696				1	1			1	1
	13:00	2,815				1	1			1	1
	14:00	2,843				1	1			1	1
	15:00	2,760				1	1			1	1
	16:00	2,715				1	1			1	1
	17:00	2,732				1	1			1	1
	18:00	2,837				1	1			1	1
	19:00	2,859				1	1			1	1
	20:00	2,830				1	1			1	1
	21:00	2,852	1			1	1				1
	22:00	2,796	1			1	1				1
	23:00	2,614	1			1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης