

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 19 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Τρίτη, 19 Αυγούστου 2025	00:00	2,362		1	1	1			1
	01:00	2,145		1	1	1			
	02:00	1,980		1	1	1			
	03:00	1,846		1	1				
	04:00	1,832		1	1				
	05:00	1,812		1	1				
	06:00	1,821		1	1				
	07:00	1,883		1	1				
	08:00	2,013		1	1				1
	09:00	2,262		1	1				1
	10:00	2,538		1	1				1
	11:00	2,555		1	1				1
	12:00	2,583		1	1				1
	13:00	2,583		1	1				1
	14:00	2,624		1	1				1
	15:00	2,464		1	1				1
	16:00	2,436		1	1				1
	17:00	2,577		1	1				1
	18:00	2,710		1	1				1
	19:00	2,847		1	1	1			1
	20:00	3,164		1	1	1			1
	21:00	2,964		1	1	1			1
	22:00	2,782		1	1	1			1
	23:00	2,588		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 20 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τετάρτη, 20 Αυγούστου 2025	00:00	2,343		1	1	1			1
	01:00	2,130		1	1	1			
	02:00	1,981			1	1			
	03:00	1,884			1	1			
	04:00	1,871			1	1			
	05:00	1,852			1	1			
	06:00	1,852			1	1			
	07:00	1,901			1	1			
	08:00	2,115			1	1			1
	09:00	2,390			1	1			1
	10:00	2,521			1	1			1
	11:00	2,489		1	1	1			1
	12:00	2,498		1	1				1
	13:00	2,573		1	1				1
	14:00	2,584		1	1				1
	15:00	2,410		1	1				1
	16:00	2,425		1	1				1
	17:00	2,536		1	1				1
	18:00	2,676		1	1				1
	19:00	2,899		1	1				1
	20:00	3,014		1	1	1			1
	21:00	2,933		1	1	1			1
	22:00	2,668		1	1	1			1
	23:00	2,488		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 21 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Πέμπτη, 21 Αυγούστου 2025	00:00	2,157		1	1	1			1
	01:00	1,982		1	1	1			
	02:00	1,873		1	1				
	03:00	1,765		1	1				
	04:00	1,767		1	1				
	05:00	1,746		1	1				
	06:00	1,783		1	1				
	07:00	1,814		1	1				
	08:00	1,959		1	1				1
	09:00	2,208		1	1				1
	10:00	2,495		1	1				1
	11:00	2,487		1	1				1
	12:00	2,506		1	1				1
	13:00	2,577		1	1				1
	14:00	2,494		1	1				1
	15:00	2,465		1	1				1
	16:00	2,490		1	1				1
	17:00	2,579		1	1				1
	18:00	2,667		1	1				1
	19:00	2,917		1	1	1			1
	20:00	3,100		1	1	1			1
	21:00	2,946		1	1	1			1
	22:00	2,805		1	1	1			1
	23:00	2,584		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 22 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Παρασκευή, 22 Αυγούστου 2025	00:00	2,378		1	1	1			1
	01:00	2,122		1	1	1			
	02:00	1,982		1	1	1			
	03:00	1,887		1		1			
	04:00	1,845		1		1			
	05:00	1,857		1		1			
	06:00	1,816		1		1			
	07:00	1,793		1		1			
	08:00	1,953		1		1			1
	09:00	2,220		1		1			1
	10:00	2,570		1		1			1
	11:00	2,621		1	1	1			1
	12:00	2,660		1	1				1
	13:00	2,761		1	1				1
	14:00	2,705		1	1				1
	15:00	2,669		1	1				1
	16:00	2,688		1	1				1
	17:00	2,686		1	1				1
	18:00	2,806		1	1				1
	19:00	2,982		1	1	1			1
	20:00	3,181		1	1	1			1
	21:00	3,086		1	1	1			1
	22:00	2,992		1	1	1			1
	23:00	2,683		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 23 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Σάββατο, 23 Αυγούστου 2025	00:00	2,392		1	1	1			1
	01:00	2,156		1	1	1			
	02:00	1,966		1	1	1			
	03:00	1,864		1	1				
	04:00	1,823		1	1				
	05:00	1,830		1	1				
	06:00	1,860		1	1				
	07:00	1,874		1	1				
	08:00	2,099		1	1				1
	09:00	2,456		1	1				1
	10:00	2,678		1	1				1
	11:00	2,698		1	1				1
	12:00	2,710		1	1				1
	13:00	2,656		1	1				1
	14:00	2,649		1	1				1
	15:00	2,450		1	1				1
	16:00	2,515		1	1				1
	17:00	2,606		1	1				1
	18:00	2,736		1	1				1
	19:00	2,965		1	1	1			1
	20:00	3,157	1	1	1	1			1
	21:00	3,064	1	1	1	1			1
	22:00	2,814		1	1	1			1
	23:00	2,618		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 24 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Κυριακή, 24 Αυγούστου 2025	00:00	2,405		1	1	1			1
	01:00	2,185		1	1	1			
	02:00	2,053		1	1	1			
	03:00	2,005		1	1	1			
	04:00	1,941		1	1				
	05:00	1,867		1	1				
	06:00	1,857		1	1				
	07:00	1,925		1	1				
	08:00	2,126		1	1				1
	09:00	2,317		1	1				1
	10:00	2,383		1	1				1
	11:00	2,470		1	1				1
	12:00	2,534		1	1				1
	13:00	2,593		1	1				1
	14:00	2,529		1	1				1
	15:00	2,411		1	1				1
	16:00	2,383		1	1				1
	17:00	2,493		1	1				1
	18:00	2,517		1	1				1
	19:00	2,759		1	1				1
	20:00	2,819		1	1				1
	21:00	2,731		1	1				1
	22:00	2,481		1	1				1
	23:00	2,198		1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 25 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Δευτέρα, 25 Αυγούστου 2025	00:00	2,094		1	1	1			
	01:00	1,964		1	1	1			
	02:00	1,888		1	1				
	03:00	1,818		1	1				
	04:00	1,750		1	1				
	05:00	1,713		1	1				
	06:00	1,682		1	1				
	07:00	1,773		1	1				
	08:00	1,988		1	1	1			
	09:00	2,187		1	1	1			
	10:00	2,329		1	1	1			
	11:00	2,356		1	1	1			
	12:00	2,346		1	1	1			
	13:00	2,313		1	1	1			
	14:00	2,352		1	1	1			
	15:00	2,319		1	1	1			
	16:00	2,354		1	1	1			
	17:00	2,431		1	1	1			
	18:00	2,510		1	1	1			
	19:00	2,710		1	1	1			
	20:00	3,031	1	1	1	1			
	21:00	2,862	1	1	1	1			
	22:00	2,636	1	1	1	1			
	23:00	2,459	1	1	1	1			

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης