

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 5 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τρίτη, 5 Αυγούστου 2025	00:00	2,469		1	1	1			1
	01:00	2,242		1	1	1			
	02:00	2,068		1	1	1			
	03:00	1,980		1	1	1			
	04:00	1,959		1	1				
	05:00	1,921		1	1				
	06:00	1,918		1	1				
	07:00	1,997		1	1	1			
	08:00	2,216		1	1	1			
	09:00	2,420		1	1	1			
	10:00	2,514		1	1	1			
	11:00	2,546		1	1	1			
	12:00	2,494		1	1	1			
	13:00	2,576		1	1	1			
	14:00	2,613		1	1	1			
	15:00	2,594		1	1	1			1
	16:00	2,605		1	1	1			1
	17:00	2,721		1	1	1			1
	18:00	2,802		1	1	1			1
	19:00	2,928		1	1	1			1
	20:00	3,071		1	1	1			1
	21:00	3,159		1	1	1			1
	22:00	2,969		1	1	1			1
	23:00	2,783		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 6 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τετάρτη, 6 Αυγούστου 2025	00:00	2,526		1	1	1			1
	01:00	2,324		1	1	1			
	02:00	2,209		1	1	1			
	03:00	2,153		1	1	1			
	04:00	2,101		1	1	1			
	05:00	2,063		1	1	1			
	06:00	2,079		1	1	1			
	07:00	2,147		1	1	1			
	08:00	2,277		1	1	1			
	09:00	2,469		1	1	1			
	10:00	2,589		1	1	1			
	11:00	2,641		1	1	1			
	12:00	2,740		1	1	1			
	13:00	2,745		1	1	1			
	14:00	2,685		1	1	1			1
	15:00	2,664		1	1	1			1
	16:00	2,662		1	1	1			1
	17:00	2,774		1	1	1			1
	18:00	2,924		1	1	1			1
	19:00	3,127		1	1	1			1
	20:00	3,247		1	1	1			1
	21:00	3,228		1	1	1			1
	22:00	2,979		1	1	1			1
	23:00	2,750		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 7 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Πέμπτη, 7 Αυγούστου 2025	00:00	2,463		1	1	1			1
	01:00	2,238		1	1	1			
	02:00	2,173		1	1	1			
	03:00	2,107		1	1	1			
	04:00	2,085		1	1	1			
	05:00	2,020		1	1	1			
	06:00	2,008		1	1	1			
	07:00	2,074		1	1	1			
	08:00	2,338		1	1	1			
	09:00	2,574		1	1	1			
	10:00	2,652		1	1	1			
	11:00	2,613		1	1	1			
	12:00	2,687		1	1	1			
	13:00	2,792		1	1	1			1
	14:00	2,767		1	1	1			1
	15:00	2,711		1	1	1			1
	16:00	2,690		1	1	1			1
	17:00	2,752		1	1	1			1
	18:00	2,932		1	1	1			1
	19:00	3,094		1	1	1			1
	20:00	3,165		1	1	1			1
	21:00	3,193		1	1	1			1
	22:00	3,016		1	1	1			1
	23:00	2,807		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 8 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Παρασκευή, 8 Αυγούστου 2025	00:00	2,568		1	1	1			1
	01:00	2,338		1	1	1			
	02:00	2,216		1	1	1			
	03:00	2,151		1	1	1			
	04:00	2,110		1	1	1			
	05:00	2,036		1	1	1			
	06:00	2,029		1	1	1			
	07:00	2,101		1	1	1			
	08:00	2,359		1	1	1			
	09:00	2,546		1	1	1			
	10:00	2,620		1	1	1			
	11:00	2,643		1	1	1			
	12:00	2,675		1	1	1			
	13:00	2,734		1	1	1			
	14:00	2,706		1	1	1			
	15:00	2,682		1	1	1			
	16:00	2,683		1	1	1			
	17:00	2,854		1	1	1			1
	18:00	2,958		1	1	1			1
	19:00	3,021		1	1	1			1
	20:00	3,179	1		1	1			1
	21:00	3,257	1		1	1			1
	22:00	3,112	1		1	1			1
	23:00	2,871	1		1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 9 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Σάββατο, 9 Αυγούστου 2025	00:00	2,704	1		1	1			1
	01:00	2,426	1		1	1			
	02:00	2,216	1		1	1			
	03:00	2,129	1		1	1			
	04:00	2,079	1		1	1			
	05:00	2,043	1		1	1			
	06:00	2,062	1		1	1			
	07:00	2,034	1		1	1			
	08:00	2,326	1		1	1			
	09:00	2,524	1		1	1			
	10:00	2,609	1		1	1			
	11:00	2,597		1	1	1			
	12:00	2,698		1	1	1			1
	13:00	2,740		1	1	1			1
	14:00	2,722		1	1	1			1
	15:00	2,640		1	1	1			1
	16:00	2,647		1	1	1			1
	17:00	2,797		1	1	1			1
	18:00	2,984		1	1	1			1
	19:00	3,063		1	1	1			1
	20:00	3,231		1	1	1			1
	21:00	3,220		1	1	1			1
	22:00	3,066		1	1	1			1
	23:00	2,904		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 10 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Κυριακή, 10 Αυγούστου 2025	00:00	2,716		1	1	1			1
	01:00	2,402		1	1	1			
	02:00	2,137		1	1	1			
	03:00	2,015		1	1	1			
	04:00	2,011		1	1	1			
	05:00	2,012		1	1	1			
	06:00	1,975		1	1	1			
	07:00	1,994		1	1	1			
	08:00	2,275		1	1	1			
	09:00	2,382		1	1	1			
	10:00	2,608		1	1	1			
	11:00	2,728		1	1	1			1
	12:00	2,754		1	1	1			1
	13:00	2,707		1	1	1			1
	14:00	2,611		1	1	1			1
	15:00	2,597		1	1	1			1
	16:00	2,672		1	1	1			1
	17:00	2,806		1	1	1			1
	18:00	2,879		1	1	1			1
	19:00	2,958		1	1	1			1
	20:00	3,167		1	1	1			1
	21:00	3,140		1	1	1			1
	22:00	3,026		1	1	1			1
	23:00	2,818		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 11 Αυγούστου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Δευτέρα, 11 Αυγούστου 2025	00:00	2,535	1	1	1	1			1
	01:00	2,342	1	1		1			
	02:00	2,186	1	1		1			
	03:00	2,069	1	1		1			
	04:00	2,066	1	1		1			
	05:00	2,023	1	1		1			
	06:00	1,999	1	1		1			
	07:00	2,098	1	1		1			
	08:00	2,326	1	1		1			
	09:00	2,452	1	1		1			
	10:00	2,559		1	1	1			
	11:00	2,648		1	1	1			1
	12:00	2,657		1	1	1			1
	13:00	2,683		1	1	1			1
	14:00	2,610		1	1	1			1
	15:00	2,517		1	1	1			1
	16:00	2,703		1	1	1			1
	17:00	2,753		1	1	1			1
	18:00	2,884		1	1	1			1
	19:00	3,068		1	1	1			1
	20:00	3,193		1	1	1			1
	21:00	3,289		1	1	1			1
	22:00	3,052		1	1	1			1
	23:00	2,798		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης