

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 15 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τρίτη, 15 Ιουλίου 2025	00:00	1,939		1	1				1
	01:00	1,786		1	1				
	02:00	1,650		1	1				
	03:00	1,597		1	1				
	04:00	1,529		1	1				
	05:00	1,413		1	1				
	06:00	1,416		1	1				
	07:00	1,508		1	1				
	08:00	1,757		1	1				
	09:00	1,880		1	1				1
	10:00	2,035		1	1				1
	11:00	2,123		1	1				1
	12:00	2,142		1	1				1
	13:00	2,125		1	1				1
	14:00	2,131		1	1				1
	15:00	2,043		1	1				1
	16:00	2,096		1	1				1
	17:00	2,186		1	1				1
	18:00	2,275		1	1				1
	19:00	2,354		1	1				1
	20:00	2,497		1	1				1
	21:00	2,547		1	1				1
	22:00	2,385		1	1				1
	23:00	2,210		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 16 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τετάρτη, 16 Ιουλίου 2025	00:00	1,981		1	1				1
	01:00	1,831		1	1				
	02:00	1,702		1	1				
	03:00	1,610		1	1				
	04:00	1,617		1	1				
	05:00	1,624		1	1				
	06:00	1,598		1	1				
	07:00	1,662		1	1				
	08:00	1,704		1	1				
	09:00	1,858		1	1				1
	10:00	2,009		1	1				1
	11:00	2,132		1	1				1
	12:00	2,199		1	1				1
	13:00	2,186		1	1				1
	14:00	2,155		1	1				1
	15:00	2,103		1	1				1
	16:00	2,121		1	1				1
	17:00	2,123		1	1				1
	18:00	2,198		1	1				1
	19:00	2,371		1	1				1
	20:00	2,483		1	1				1
	21:00	2,540		1	1				1
	22:00	2,387		1	1				1
	23:00	2,181		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 17 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Πέμπτη, 17 Ιουλίου 2025	00:00	1,979		1	1				1
	01:00	1,831		1	1				
	02:00	1,744		1	1				
	03:00	1,635		1	1				
	04:00	1,622		1	1				
	05:00	1,603		1	1				
	06:00	1,602		1	1				
	07:00	1,740		1	1				
	08:00	1,973		1	1				1
	09:00	2,151		1	1				1
	10:00	2,180		1	1				1
	11:00	2,251		1	1				1
	12:00	2,253		1	1				1
	13:00	2,256		1	1				1
	14:00	2,208		1	1				1
	15:00	2,181		1	1				1
	16:00	2,160		1	1				1
	17:00	2,294		1	1				1
	18:00	2,388		1	1				1
	19:00	2,474		1	1				1
	20:00	2,702		1	1				1
	21:00	2,754		1	1				1
	22:00	2,639		1	1				1
	23:00	2,452		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 18 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Παρασκευή, 18 Ιουλίου 2025	00:00	2,206		1	1	1			1
	01:00	1,995		1	1	1			
	02:00	1,873			1	1			
	03:00	1,849			1	1			
	04:00	1,880			1	1			
	05:00	1,789			1	1			
	06:00	1,751			1	1			
	07:00	1,817			1	1			
	08:00	1,991			1	1			1
	09:00	2,081			1	1			1
	10:00	2,192		1	1				1
	11:00	2,258		1	1				1
	12:00	2,314		1	1				1
	13:00	2,377		1	1				1
	14:00	2,421		1	1				1
	15:00	2,362		1	1				1
	16:00	2,497		1	1				1
	17:00	2,535		1	1				1
	18:00	2,611		1	1				1
	19:00	2,668		1	1				1
	20:00	2,721		1	1				1
	21:00	2,770		1	1				1
	22:00	2,725		1	1				1
	23:00	2,510		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 19 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Σάββατο, 19 Ιουλίου 2025	00:00	2,315		1	1	1			1
	01:00	2,094		1	1	1			
	02:00	1,978		1		1			
	03:00	1,896		1		1			
	04:00	1,829		1		1			
	05:00	1,813		1		1			
	06:00	1,791		1		1			
	07:00	1,859		1		1			
	08:00	2,042		1		1			1
	09:00	2,200		1		1			1
	10:00	2,295		1	1				1
	11:00	2,310		1	1				1
	12:00	2,303		1	1				1
	13:00	2,423		1	1				1
	14:00	2,384		1	1				1
	15:00	2,377		1	1				1
	16:00	2,438		1	1				1
	17:00	2,409		1	1				1
	18:00	2,501		1	1				1
	19:00	2,678		1	1				1
	20:00	2,715		1	1				1
	21:00	2,850		1	1				1
	22:00	2,673		1	1				1
	23:00	2,399		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 20 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Κυριακή, 20 Ιουλίου 2025	00:00	2,225		1	1				1
	01:00	1,987		1	1				
	02:00	1,942		1	1				
	03:00	1,886		1	1				
	04:00	1,851		1	1				
	05:00	1,841		1	1				
	06:00	1,769		1	1				
	07:00	1,889		1	1				
	08:00	2,050		1	1				1
	09:00	2,167		1	1				1
	10:00	2,285		1	1				1
	11:00	2,300		1	1				1
	12:00	2,408		1	1				1
	13:00	2,415		1	1				1
	14:00	2,418		1	1				1
	15:00	2,297		1	1				1
	16:00	2,261		1	1				1
	17:00	2,427		1	1				1
	18:00	2,531		1	1				1
	19:00	2,651		1	1				1
	20:00	2,676		1	1				1
	21:00	2,743		1	1				1
	22:00	2,618		1	1				1
	23:00	2,400		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 21 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Δευτέρα, 21 Ιουλίου 2025	00:00	2,247		1	1				1
	01:00	1,985		1	1				
	02:00	1,957		1	1				
	03:00	1,902		1	1				
	04:00	1,900		1	1				
	05:00	1,816		1	1				
	06:00	1,833		1	1				
	07:00	1,931		1	1				
	08:00	2,089		1	1				1
	09:00	2,192		1	1				1
	10:00	2,316		1	1				1
	11:00	2,350		1	1				1
	12:00	2,462		1	1				1
	13:00	2,472		1	1				1
	14:00	2,400		1	1				1
	15:00	2,427		1	1				1
	16:00	2,401		1	1				1
	17:00	2,416		1	1				1
	18:00	2,608		1	1				1
	19:00	2,739		1	1				1
	20:00	2,752		1	1				1
	21:00	2,899		1	1				1
	22:00	2,795		1	1				1
	23:00	2,600		1	1				1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης