

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 22 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τρίτη, 22 Ιουλίου 2025	00:00	2,342		1	1				1
	01:00	2,173		1	1				
	02:00	2,063		1	1				
	03:00	1,994		1	1				
	04:00	1,915		1	1				
	05:00	1,923		1	1				
	06:00	1,940		1	1				
	07:00	1,945		1	1				
	08:00	2,139		1	1				1
	09:00	2,319		1	1				1
	10:00	2,380		1	1				1
	11:00	2,459		1	1				1
	12:00	2,473		1	1				1
	13:00	2,594		1	1				1
	14:00	2,577		1	1				1
	15:00	2,572		1	1				1
	16:00	2,512		1	1				1
	17:00	2,606		1	1				1
	18:00	2,725		1	1	1			1
	19:00	2,842		1	1	1			1
	20:00	2,997		1	1	1			1
	21:00	3,070		1	1	1			1
	22:00	2,964		1	1	1			1
	23:00	2,847		1	1	1			1

Μισθωμένη ισχύς 1 MW. Οι μονάδες G2 και G3 λειτουργούν στην ονομαστική τους ισχύ.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 23 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Τετάρτη, 23 Ιουλίου 2025	00:00	2,697		1	1	1			1
	01:00	2,485		1	1	1			
	02:00	2,374		1	1	1			
	03:00	2,292		1	1	1			
	04:00	2,157		1	1	1			
	05:00	2,098		1	1	1			
	06:00	1,998		1	1	1			
	07:00	1,975		1	1	1			
	08:00	2,197		1	1				1
	09:00	2,332		1	1				1
	10:00	2,623		1	1				1
	11:00	2,677		1	1				1
	12:00	2,749		1	1				1
	13:00	2,772		1	1				1
	14:00	2,728		1	1				1
	15:00	2,777		1	1				1
	16:00	2,809		1	1				1
	17:00	2,822		1	1				1
	18:00	2,932		1	1	1			1
	19:00	3,030		1	1	1			1
	20:00	3,117		1	1	1			1
	21:00	3,142		1	1	1			1
	22:00	3,049		1	1	1			1
	23:00	2,883		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 24 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Πέμπτη, 24 Ιουλίου 2025	00:00	2,653		1	1	1			1
	01:00	2,436		1	1	1			
	02:00	2,329		1	1	1			
	03:00	2,245		1	1	1			
	04:00	2,150		1	1	1			
	05:00	2,122		1	1	1			
	06:00	2,090		1	1	1			
	07:00	2,083		1	1	1			
	08:00	2,358		1	1				1
	09:00	2,651		1	1				1
	10:00	2,745		1	1				1
	11:00	2,690		1	1				1
	12:00	2,687		1	1				1
	13:00	2,764		1	1				1
	14:00	2,739		1	1				1
	15:00	2,761		1	1				1
	16:00	2,775		1	1				1
	17:00	2,786		1	1				1
	18:00	2,864		1	1	1			1
	19:00	2,938		1	1	1			1
	20:00	3,063		1	1	1			1
	21:00	3,196		1	1	1			1
	22:00	3,070		1	1	1			1
	23:00	2,852		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 25 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Παρασκευή, 25 Ιουλίου 2025	00:00	2,686		1	1	1			
	01:00	2,511		1	1	1			
	02:00	2,410		1	1	1			
	03:00	2,320		1	1	1			
	04:00	2,255		1	1	1			
	05:00	2,212		1	1	1			
	06:00	2,142		1	1	1			
	07:00	2,156		1	1	1			
	08:00	2,286		1	1				1
	09:00	2,340		1	1				1
	10:00	2,494		1	1				1
	11:00	2,443		1	1				1
	12:00	2,439		1	1				1
	13:00	2,599		1	1				1
	14:00	2,688		1	1				1
	15:00	2,716		1	1				1
	16:00	2,812		1	1				1
	17:00	2,912		1	1	1			1
	18:00	2,921		1	1	1			1
	19:00	2,976		1	1	1			1
	20:00	2,982		1	1	1			1
	21:00	2,939		1	1	1			1
	22:00	2,803		1	1	1			1
	23:00	2,618		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 26 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Π Ρ Ο Δ Ο Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Σάββατο, 26 Ιουλίου 2025	00:00	2,495		1	1	1			1
	01:00	2,394		1	1	1			
	02:00	2,277		1	1	1			
	03:00	2,227		1	1	1			
	04:00	2,198		1	1	1			
	05:00	2,183		1	1	1			
	06:00	2,133		1	1	1			
	07:00	2,141		1	1	1			
	08:00	2,254		1	1				1
	09:00	2,416		1	1				1
	10:00	2,451		1	1				1
	11:00	2,467		1	1				1
	12:00	2,531		1	1				1
	13:00	2,541		1	1				1
	14:00	2,516		1	1				1
	15:00	2,481		1	1				1
	16:00	2,546		1	1				1
	17:00	2,565		1	1				1
	18:00	2,700		1	1				1
	19:00	2,825		1	1	1			1
	20:00	2,901		1	1	1			1
	21:00	2,892		1	1	1			1
	22:00	2,778		1	1	1			1
	23:00	2,554		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 27 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
α ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Κυριακή, 27 Ιουλίου 2025	00:00	2,404		1	1	1			1
	01:00	2,204		1	1	1			
	02:00	2,121		1	1	1			
	03:00	2,036		1	1	1			
	04:00	2,000		1	1	1			
	05:00	1,906		1	1	1			
	06:00	1,888		1	1	1			
	07:00	1,948		1	1	1			
	08:00	2,148		1	1				1
	09:00	2,300		1	1				1
	10:00	2,420		1	1				1
	11:00	2,489		1	1				1
	12:00	2,542		1	1				1
	13:00	2,675		1	1				1
	14:00	2,543		1	1				1
	15:00	2,512		1	1				1
	16:00	2,570		1	1				1
	17:00	2,652		1	1				1
	18:00	2,771		1	1				1
	19:00	2,886		1	1	1			1
	20:00	2,998		1	1	1			1
	21:00	3,108		1	1	1			1
	22:00	2,958		1	1	1			1
	23:00	2,826		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 28 Ιουλίου 2025						
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Π Ρ Ο Σ Τ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9	HZ (x1)
Δευτέρα, 28 Ιουλίου 2025	00:00	2,636		1	1	1			1
	01:00	2,443		1	1	1			
	02:00	2,315		1	1	1			
	03:00	2,240		1	1	1			
	04:00	2,146		1	1	1			
	05:00	2,102		1	1	1			
	06:00	2,074		1	1	1			
	07:00	2,156		1	1	1			
	08:00	2,365		1	1				1
	09:00	2,589		1	1				1
	10:00	2,680		1	1				1
	11:00	2,682		1	1				1
	12:00	2,746		1	1				1
	13:00	2,832		1	1				1
	14:00	2,774		1	1				1
	15:00	2,763		1	1				1
	16:00	2,766		1	1	1			1
	17:00	2,879		1	1	1			1
	18:00	2,890		1	1	1			1
	19:00	3,004		1	1	1			1
	20:00	3,065		1	1	1			1
	21:00	3,110		1	1	1			1
	22:00	2,930		1	1	1			1
	23:00	2,765		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης