

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τετάρτη, 10 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 10 Σεπτεμβρίου 2025	00:00	1,620	1	1				
	01:00	1,491	1	1				
	02:00	1,424	1	1				
	03:00	1,376	1	1				
	04:00	1,350	1	1				
	05:00	1,353	1	1				
	06:00	1,393	1	1				
	07:00	1,499	1	1				
	08:00	1,680	1	1				
	09:00	1,711	1	1				
	10:00	1,745	1	1				
	11:00	1,734	1	1				
	12:00	1,735	1	1				
	13:00	1,788	1	1		1		
	14:00	1,957	1	1		1		
	15:00	1,891	1	1		1		
	16:00	1,931	1	1		1		
	17:00	1,955	1	1		1		
	18:00	2,021	1	1		1		
	19:00	2,108	1	1		1		
	20:00	2,164	1	1		1		
	21:00	2,095	1	1		1		
	22:00	1,922	1	1		1		
	23:00	1,845	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Πέμπτη, 11 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 11 Σεπτεμβρίου 2025	00:00	1,620	1	1				
	01:00	1,493	1	1				
	02:00	1,422	1	1				
	03:00	1,373	1	1				
	04:00	1,349	1	1				
	05:00	1,353	1	1				
	06:00	1,392	1	1				
	07:00	1,497	1	1				
	08:00	1,679	1	1				
	09:00	1,732	1	1				
	10:00	1,758	1	1		1		
	11:00	1,763	1	1		1		
	12:00	1,765	1	1		1		
	13:00	1,800	1	1		1		
	14:00	1,926	1	1		1		
	15:00	1,866	1	1		1		
	16:00	1,978	1	1		1		
	17:00	1,997	1	1		1		
	18:00	2,029	1	1		1		
	19:00	2,088	1	1		1		
	20:00	2,129	1	1		1		
	21:00	2,064	1	1		1		
	22:00	1,899	1	1		1		
	23:00	1,824	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Παρασκευή, 12 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 12 Σεπτεμβρίου 2025	00:00	1,631	1	1				
	01:00	1,492	1	1				
	02:00	1,410	1	1				
	03:00	1,359	1	1				
	04:00	1,335	1	1				
	05:00	1,339	1	1				
	06:00	1,381	1	1				
	07:00	1,487	1	1				
	08:00	1,685	1	1				
	09:00	1,776	1	1		1		
	10:00	1,819	1	1		1		
	11:00	1,834	1	1		1		
	12:00	1,838	1	1		1		
	13:00	1,851	1	1		1		
	14:00	1,920	1	1		1		
	15:00	1,900	1	1		1		
	16:00	1,988	1	1		1		
	17:00	2,023	1	1		1		
	18:00	2,054	1	1		1		
	19:00	2,100	1	1		1		
	20:00	2,124	1	1		1		
	21:00	2,066	1	1		1		
	22:00	1,904	1	1		1		
	23:00	1,832	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Σάββατο, 13 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 13 Σεπτεμβρίου 2025	00:00	1,640	1	1				
	01:00	1,505	1	1				
	02:00	1,428	1	1				
	03:00	1,377	1	1				
	04:00	1,351	1	1				
	05:00	1,352	1	1				
	06:00	1,386	1	1				
	07:00	1,479	1	1				
	08:00	1,664	1	1				
	09:00	1,769	1	1		1		
	10:00	1,809	1	1		1		
	11:00	1,822	1	1		1		
	12:00	1,822	1	1		1		
	13:00	1,829	1	1		1		
	14:00	1,876	1	1		1		
	15:00	1,868	1	1		1		
	16:00	1,950	1	1		1		
	17:00	1,996	1	1		1		
	18:00	2,034	1	1		1		
	19:00	2,080	1	1		1		
	20:00	2,100	1	1		1		
	21:00	2,047	1	1		1		
	22:00	1,889	1	1		1		
	23:00	1,810	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Κυριακή, 14 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 14 Σεπτεμβρίου 2025	00:00	1,638	1	1				
	01:00	1,501	1	1				
	02:00	1,418	1	1				
	03:00	1,364	1	1				
	04:00	1,337	1	1				
	05:00	1,330	1	1				
	06:00	1,361	1	1				
	07:00	1,451	1	1				
	08:00	1,635	1	1				
	09:00	1,760	1	1		1		
	10:00	1,793	1	1		1		
	11:00	1,797	1	1		1		
	12:00	1,787	1	1		1		
	13:00	1,786	1	1		1		
	14:00	1,822	1	1		1		
	15:00	1,811	1	1		1		
	16:00	1,877	1	1		1		
	17:00	1,927	1	1		1		
	18:00	1,974	1	1		1		
	19:00	2,032	1	1		1		
	20:00	2,057	1	1		1		
	21:00	2,009	1	1		1		
	22:00	1,846	1	1		1		
	23:00	1,754	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Δευτέρα, 15 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 15 Σεπτεμβρίου 2025	00:00	1,573	1	1				
	01:00	1,438	1	1				
	02:00	1,361	1	1				
	03:00	1,321	1	1				
	04:00	1,307	1	1				
	05:00	1,320	1	1				
	06:00	1,363	1	1				
	07:00	1,458	1	1				
	08:00	1,623	1	1				
	09:00	1,747	1	1				
	10:00	1,788	1	1		1		
	11:00	1,796	1	1		1		
	12:00	1,795	1	1		1		
	13:00	1,796	1	1		1		
	14:00	1,802	1	1		1		
	15:00	1,813	1	1		1		
	16:00	1,864	1	1		1		
	17:00	1,907	1	1		1		
	18:00	1,948	1	1		1		
	19:00	1,991	1	1		1		
	20:00	2,010	1	1		1		
	21:00	1,975	1	1		1		
	22:00	1,841	1	1		1		
	23:00	1,764	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τρίτη, 16 Σεπτεμβρίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 16 Σεπτεμβρίου 2025	00:00	1,550	1	1				
	01:00	1,431	1	1				
	02:00	1,361	1	1				
	03:00	1,313	1	1				
	04:00	1,282	1	1				
	05:00	1,274	1	1				
	06:00	1,304	1	1				
	07:00	1,391	1	1				
	08:00	1,550	1	1				
	09:00	1,668	1	1				
	10:00	1,708	1	1				
	11:00	1,717	1	1				
	12:00	1,720	1	1				
	13:00	1,732	1	1				
	14:00	1,757	1	1		1		
	15:00	1,776	1	1		1		
	16:00	1,827	1	1		1		
	17:00	1,879	1	1		1		
	18:00	1,927	1	1		1		
	19:00	1,965	1	1		1		
	20:00	1,983	1	1		1		
	21:00	1,960	1	1		1		
	22:00	1,850	1	1		1		
	23:00	1,767	1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης