

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τετάρτη, 13 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τετάρτη, 13 Αυγούστου 2025	00:00	2,413		1	1	1			
	01:00	2,302		1	1	1			
	02:00	2,195		1	1	1			
	03:00	2,113		1	1	1			
	04:00	2,065		1	1	1			
	05:00	2,041		1	1	1			
	06:00	2,056		1	1	1			
	07:00	2,115		1	1	1			
	08:00	2,293		1	1	1			1
	09:00	2,506		1	1	1			1
	10:00	2,644		1	1	1			1
	11:00	2,713		1	1	1			1
	12:00	2,704		1	1	1			1
	13:00	2,719		1	1	1			1
	14:00	2,673		1	1	1			1
	15:00	2,643		1	1	1			1
	16:00	2,685		1	1	1			1
	17:00	2,768		1	1	1			1
	18:00	2,900		1	1	1			1
	19:00	3,106		1	1	1			1
	20:00	3,246		1	1	1			1
	21:00	3,271		1	1	1			1
	22:00	3,036		1	1	1			1
	23:00	2,840		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Πέμπτη, 14 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Πέμπτη, 14 Αυγούστου 2025	00:00	2,383		1	1	1			
	01:00	2,285		1	1	1			
	02:00	2,170		1	1	1			
	03:00	2,081		1	1	1			
	04:00	2,018		1	1	1			
	05:00	1,978		1	1	1			
	06:00	2,010		1	1	1			
	07:00	2,078		1	1	1			
	08:00	2,257		1	1	1			1
	09:00	2,480		1	1	1			1
	10:00	2,601		1	1	1			1
	11:00	2,639		1	1	1			1
	12:00	2,663		1	1	1			1
	13:00	2,711		1	1	1			1
	14:00	2,679		1	1	1			1
	15:00	2,634		1	1	1			1
	16:00	2,652		1	1	1			1
	17:00	2,701		1	1	1			1
	18:00	2,815		1	1	1			1
	19:00	3,004		1	1	1			1
	20:00	3,162		1	1	1			1
	21:00	3,225		1	1	1			1
	22:00	3,006		1	1	1			1
	23:00	2,801		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Παρασκευή, 15 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Παρασκευή, 15 Αυγούστου 2025	00:00	2,378		1	1	1			
	01:00	2,170		1	1	1			
	02:00	2,050		1	1	1			
	03:00	1,978		1	1	1			
	04:00	1,944		1	1	1			
	05:00	1,935		1	1	1			
	06:00	1,938		1	1	1			
	07:00	1,984		1	1	1			
	08:00	2,160		1	1	1			1
	09:00	2,439		1	1	1			1
	10:00	2,590		1	1	1			1
	11:00	2,643		1	1	1			1
	12:00	2,670		1	1	1			1
	13:00	2,714		1	1	1			1
	14:00	2,682		1	1	1			1
	15:00	2,654		1	1	1			1
	16:00	2,667		1	1	1			1
	17:00	2,720		1	1	1			1
	18:00	2,812		1	1	1			1
	19:00	2,961		1	1	1			1
	20:00	3,121		1	1	1			1
	21:00	3,180		1	1	1			1
	22:00	2,959		1	1	1			1
	23:00	2,719		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Σάββατο, 16 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Τ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Σάββατο, 16 Αυγούστου 2025	00:00	2,348		1	1	1			
	01:00	2,148		1	1	1			
	02:00	2,044		1	1	1			
	03:00	1,975		1	1	1			
	04:00	1,943		1	1	1			
	05:00	1,928		1	1	1			
	06:00	1,936		1	1	1			
	07:00	1,935		1	1	1			
	08:00	2,260		1	1	1			1
	09:00	2,430		1	1	1			1
	10:00	2,506		1	1	1			1
	11:00	2,537		1	1	1			1
	12:00	2,568		1	1	1			1
	13:00	2,600		1	1	1			1
	14:00	2,579		1	1	1			1
	15:00	2,554		1	1	1			1
	16:00	2,569		1	1	1			1
	17:00	2,620		1	1	1			1
	18:00	2,724		1	1	1			1
	19:00	2,839		1	1	1			1
	20:00	3,023		1	1	1			1
	21:00	3,066		1	1	1			1
	22:00	2,849		1	1	1			1
	23:00	2,633		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Κυριακή, 17 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Κυριακή, 17 Αυγούστου 2025	00:00	2,381		1	1	1			
	01:00	2,039		1	1	1			
	02:00	1,944		1	1	1			
	03:00	1,878		1	1	1			
	04:00	1,831		1	1	1			
	05:00	1,796		1	1	1			
	06:00	1,795		1	1	1			
	07:00	1,840		1	1	1			
	08:00	2,070		1	1	1			1
	09:00	2,224		1	1	1			1
	10:00	2,415		1	1	1			1
	11:00	2,492		1	1	1			1
	12:00	2,520		1	1	1			1
	13:00	2,527		1	1	1			1
	14:00	2,503		1	1	1			1
	15:00	2,494		1	1	1			1
	16:00	2,509		1	1	1			1
	17:00	2,554		1	1	1			1
	18:00	2,626		1	1	1			1
	19:00	2,710		1	1	1			1
	20:00	2,913		1	1	1			1
	21:00	2,942		1	1	1			1
	22:00	2,719		1	1	1			1
	23:00	2,489		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Δευτέρα, 18 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Δευτέρα, 18 Αυγούστου 2025	00:00	2,263		1	1	1			
	01:00	2,053		1	1	1			
	02:00	1,908		1	1	1			
	03:00	1,812		1	1	1			
	04:00	1,768		1	1	1			
	05:00	1,752		1	1	1			
	06:00	1,773		1	1	1			
	07:00	1,854		1	1	1			
	08:00	2,112		1	1	1			1
	09:00	2,208		1	1	1			1
	10:00	2,359		1	1	1			1
	11:00	2,430		1	1	1			1
	12:00	2,448		1	1	1			1
	13:00	2,462		1	1	1			1
	14:00	2,436		1	1	1			1
	15:00	2,426		1	1	1			1
	16:00	2,469		1	1	1			1
	17:00	2,515		1	1	1			1
	18:00	2,604		1	1	1			1
	19:00	2,742		1	1	1			1
	20:00	2,949		1	1	1			1
	21:00	3,059		1	1	1			1
	22:00	2,818		1	1	1			1
	23:00	2,551		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Τρίτη, 19 Αυγούστου 2025				
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	1,000	1,000	0,460	0,460	1,000
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9	HZ (X1)
Τρίτη, 19 Αυγούστου 2025	00:00	2,269		1	1	1			
	01:00	2,029		1	1	1			
	02:00	1,916		1	1	1			
	03:00	1,804		1	1	1			
	04:00	1,749		1	1	1			
	05:00	1,725		1	1	1			
	06:00	1,737		1	1	1			
	07:00	1,793		1	1	1			
	08:00	1,958		1	1				1
	09:00	2,150		1	1				1
	10:00	2,254		1	1				1
	11:00	2,287		1	1				1
	12:00	2,289		1	1				1
	13:00	2,288		1	1				1
	14:00	2,278		1	1				1
	15:00	2,280		1	1				1
	16:00	2,285		1	1				1
	17:00	2,308		1	1				1
	18:00	2,397		1	1	1			1
	19:00	2,531		1	1	1			1
	20:00	2,742		1	1	1			1
	21:00	2,863		1	1	1			1
	22:00	2,675		1	1	1			1
	23:00	2,470		1	1	1			1

Μισθωμένη ισχύς 1 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης