

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας			Τετάρτη, 16 Ιούλιος 2025							
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τετάρτη, 16 Ιούλιος 2025	00:00	44,07		1	1		1	1	1	1	1	1	
	01:00	42,19		1	1		1	1	1	1	1	1	
	02:00	40,26		1	1		1	1	1	1	1	1	
	03:00	39,15		1	1		1	1	1	1	1	1	
	04:00	37,95		1	1		1	1	1	1	1	1	
	05:00	37,97		1	1		1	1	1	1	1	1	
	06:00	38,58		1	1		1	1	1	1	1	1	
	07:00	42,26		1	1		1	1	1	1	1	1	
	08:00	46,73		1	1		1	1	1	1	1	1	2
	09:00	49,64		1	1		1	1	1	1	1	1	5
	10:00	52,52		1	1		1	1	1	1	1	1	6
	11:00	53,72		1	1	1	1	1	1	1	1	1	6
	12:00	55,04		1	1	1	1	1	1	1	1	1	6
	13:00	56,32		1	1	1	1	1	1	1	1	1	7
	14:00	57,26		1	1	1	1	1	1	1	1	1	7
	15:00	57,15		1	1	1	1	1	1	1	1	1	7
	16:00	56,41		1	1	1	1	1	1	1	1	1	6
	17:00	56,70		1	1	1	1	1	1	1	1	1	6
	18:00	56,45		1	1	1	1	1	1	1	1	1	6
	19:00	55,76		1	1	1	1	1	1	1	1	1	6
	20:00	55,14		1	1	1	1	1	1	1	1	1	5
	21:00	54,73		1	1	1	1	1	1	1	1	1	5
	22:00	52,03		1	1	1	1	1	1	1	1	1	3
	23:00	48,99		1	1	1	1	1	1	1	1	1	1

Μισθωμένη ισχύς 14 MW. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης