

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Πέμπτη, 17 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Πέμπτη, 17 Ιούλιος 2025	00:00	43,44		1	1	1	1	1	1	1	1	1	1
	01:00	40,70		1	1		1	1	1	1	1	1	1
	02:00	38,75		1	1		1	1	1	1	1	1	1
	03:00	37,63		1	1		1	1	1	1	1	1	1
	04:00	37,23		1	1		1	1	1	1	1	1	1
	05:00	37,18		1	1		1	1	1	1	1	1	1
	06:00	37,71		1	1		1	1	1	1	1	1	1
	07:00	42,10		1	1		1	1	1	1	1	1	1
	08:00	46,60		1	1		1	1	1	1	1	1	2
	09:00	50,10		1	1		1	1	1	1	1	1	4
	10:00	52,83		1	1	1	1	1	1	1	1	1	4
	11:00	54,32		1	1	1	1	1	1	1	1	1	4
	12:00	56,35		1	1	1	1	1	1	1	1	1	5
	13:00	57,73		1	1	1	1	1	1	1	1	1	7
	14:00	58,00		1	1	1	1	1	1	1	1	1	7
	15:00	57,47		1	1	1	1	1	1	1	1	1	7
	16:00	57,14		1	1	1	1	1	1	1	1	1	7
	17:00	57,09		1	1	1	1	1	1	1	1	1	7
	18:00	57,05		1	1	1	1	1	1	1	1	1	6
	19:00	56,27		1	1	1	1	1	1	1	1	1	6
	20:00	55,27		1	1	1	1	1	1	1	1	1	5
	21:00	54,42		1	1	1	1	1	1	1	1	1	5
	22:00	53,44		1	1	1	1	1	1	1	1	1	4
	23:00	49,91		1	1	1	1	1	1	1	1	1	1

Μισθωμένη ισχύς 14 MW. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης