

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 20 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Κυριακή, 20 Ιούλιος 2025	00:00	45,55		1	1	1	1	1	1	1	1	1	
	01:00	42,19		1	1		1	1	1	1	1	1	
	02:00	40,42		1	1		1	1	1	1	1	1	
	03:00	39,08		1	1		1	1	1	1	1	1	
	04:00	38,79		1	1		1	1	1	1	1	1	
	05:00	38,41		1	1		1	1	1	1	1	1	
	06:00	38,95		1	1		1	1	1	1	1	1	
	07:00	42,80		1	1		1	1	1	1	1	1	
	08:00	46,79		1	1		1	1	1	1	1	1	3
	09:00	50,57		1	1		1	1	1	1	1	1	6
	10:00	53,13		1	1		1	1	1	1	1	1	7
	11:00	54,18		1	1		1	1	1	1	1	1	8
	12:00	56,24		1	1		1	1	1	1	1	1	9
	13:00	58,12		1	1	1	1	1	1	1	1	1	9
	14:00	58,37		1	1	1	1	1	1	1	1	1	9
	15:00	57,58		1	1	1	1	1	1	1	1	1	9
	16:00	56,66		1	1	1	1	1	1	1	1	1	9
	17:00	56,78		1	1	1	1	1	1	1	1	1	9
	18:00	57,14		1	1	1	1	1	1	1	1	1	9
	19:00	56,21		1	1	1	1	1	1	1	1	1	9
	20:00	55,92		1	1	1	1	1	1	1	1	1	9
	21:00	56,48		1	1	1	1	1	1	1	1	1	9
	22:00	54,05		1	1	1	1	1	1	1	1	1	7
	23:00	50,81		1	1	1	1	1	1	1	1	1	6

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης