

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Δευτέρα, 21 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	10,000	10,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Δευτέρα, 21 Ιούλιος 2025	00:00	45,75		1	1	1	1		1	1	1	1	5
	01:00	42,58		1	1	1	1		1	1	1	1	2
	02:00	40,49		1	1	1	1		1	1	1	1	
	03:00	39,90		1	1	1	1		1	1	1	1	
	04:00	38,90		1	1	1	1		1	1	1	1	
	05:00	38,43		1	1	1	1		1	1	1	1	
	06:00	39,48		1	1	1	1		1	1	1	1	
	07:00	42,74		1	1	1	1		1	1	1	1	
	08:00	47,41		1	1	1	1		1	1	1	1	4
	09:00	52,05		1	1	1	1		1	1	1	1	11
	10:00	55,71		1	1	1	1		1	1	1	1	12
	11:00	56,90		1	1	1	1		1	1	1	1	12
	12:00	59,41		1	1	1	1	1	1	1	1	1	12
	13:00	61,34		1	1	1	1	1	1	1	1	1	12
	14:00	61,90		1	1	1	1	1	1	1	1	1	12
	15:00	61,53		1	1	1	1	1	1	1	1	1	12
	16:00	61,35		1	1	1	1	1	1	1	1	1	12
	17:00	61,30		1	1	1	1	1	1	1	1	1	12
	18:00	61,06		1	1	1	1	1	1	1	1	1	12
	19:00	60,26		1	1	1	1	1	1	1	1	1	12
	20:00	59,02		1	1	1	1	1	1	1	1	1	11
	21:00	59,19		1	1	1	1	1	1	1	1	1	11
	22:00	56,97		1	1	1	1	1	1	1	1	1	11
	23:00	52,10			1	1	1	1	1	1	1	1	11

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης