

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 22 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τρίτη, 22 Ιούλιος 2025	00:00	48,60		1	1	1	1	1	1	1	1	1	2
	01:00	45,55		1	1	1	1	1	1	1	1	1	2
	02:00	43,29		1	1	1	1	1	1	1	1	1	
	03:00	41,83		1	1	1	1	1	1	1	1	1	
	04:00	40,94		1	1	1	1	1	1	1	1	1	
	05:00	40,62		1	1	1	1	1	1	1	1	1	
	06:00	40,86		1	1	1	1	1	1	1	1	1	
	07:00	44,99		1	1	1	1	1	1	1	1	1	6
	08:00	50,15		1	1	1	1	1	1	1	1	1	9
	09:00	54,63		1	1	1	1	1	1	1	1	1	8
	10:00	58,04		1	1	1	1	1	1	1	1	1	10
	11:00	59,72		1	1	1	1	1	1	1	1	1	12
	12:00	62,35		1	1	1	1	1	1	1	1	1	13
	13:00	65,19		1	1	1	1	1	1	1	1	1	13
	14:00	65,27		1	1	1	1	1	1	1	1	1	14
	15:00	64,37		1	1	1	1	1	1	1	1	1	13
	16:00	64,06		1	1	1	1	1	1	1	1	1	13
	17:00	64,02		1	1	1	1	1	1	1	1	1	13
	18:00	64,07		1	1	1	1	1	1	1	1	1	13
	19:00	62,43		1	1	1	1	1	1	1	1	1	13
	20:00	61,50		1	1	1	1	1	1	1	1	1	13
	21:00	62,41		1	1	1	1	1	1	1	1	1	13
	22:00	61,18		1	1	1	1	1	1	1	1	1	13
	23:00	58,55		1	1	1	1	1	1	1	1	1	13

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης