

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Σάββατο, 26 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Σάββατο, 26 Ιούλιος 2025	00:00	52,85			1	1	1	1	1	1	1	1	7
	01:00	49,36			1	1	1	1	1	1	1	1	4
	02:00	46,95			1	1	1	1	1	1	1	1	1
	03:00	45,99			1	1	1	1	1	1	1	1	
	04:00	45,19			1	1	1	1	1	1	1	1	
	05:00	44,81			1	1	1	1	1	1	1	1	
	06:00	44,81			1	1	1	1	1	1	1	1	
	07:00	47,61			1	1	1	1	1	1	1	1	3
	08:00	52,45			1	1	1	1	1	1	1	1	5
	09:00	55,79		1	1	1	1	1	1	1	1	7	
	10:00	58,33		1	1	1	1	1	1	1	1	8	
	11:00	60,02		1	1	1	1	1	1	1	1	9	
	12:00	61,68		1	1	1	1	1	1	1	1	12	
	13:00	63,60		1	1	1	1	1	1	1	1	14	
	14:00	65,34		1	1	1	1	1	1	1	1	14	
	15:00	65,01		1	1	1	1	1	1	1	1	14	
	16:00	64,69		1	1	1	1	1	1	1	1	14	
	17:00	64,84		1	1	1	1	1	1	1	1	14	
	18:00	64,32		1	1	1	1	1	1	1	1	14	
	19:00	63,54		1	1	1	1	1	1	1	1	13	
	20:00	62,07		1	1	1	1	1	1	1	1	12	
	21:00	61,38		1	1	1	1	1	1	1	1	12	
	22:00	59,30		1	1	1	1	1	1	1	1	9	
	23:00	56,07		1	1	1	1	1	1	1	1	5	

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης