

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 27 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)		7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000	
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Κυριακή, 27 Ιούλιος 2025	00:00	51,18		1	1	1	1	1	1	1	1	1	
	01:00	47,90		1	1	1	1	1	1	1	1	1	
	02:00	46,65		1	1	1	1	1	1	1	1	1	
	03:00	45,06		1	1	1	1	1	1	1	1	1	
	04:00	43,44		1	1	1	1	1	1	1	1	1	
	05:00	43,23		1	1	1	1	1	1	1	1	1	
	06:00	43,18		1	1	1	1	1	1	1	1	1	
	07:00	46,09		1	1	1	1	1	1	1	1	1	
	08:00	50,31		1	1	1	1	1	1	1	1	1	
	09:00	53,61		1	1	1	1	1	1	1	1	1	3
	10:00	56,27		1	1	1	1	1	1	1	1	1	7
	11:00	57,89		1	1	1	1	1	1	1	1	1	7
	12:00	59,78		1	1	1	1	1	1	1	1	1	9
	13:00	62,37		1	1	1	1	1	1	1	1	1	12
	14:00	62,67		1	1	1	1	1	1	1	1	1	12
	15:00	61,65		1	1	1	1	1	1	1	1	1	12
	16:00	61,37		1	1	1	1	1	1	1	1	1	12
	17:00	61,14		1	1	1	1	1	1	1	1	1	12
	18:00	61,67		1	1	1	1	1	1	1	1	1	12
	19:00	60,73		1	1	1	1	1	1	1	1	1	12
	20:00	60,25		1	1	1	1	1	1	1	1	1	12
	21:00	59,64		1	1	1	1	1	1	1	1	1	11
	22:00	58,51		1	1	1	1	1	1	1	1	1	8
	23:00	54,17		1	1	1	1	1	1	1	1	1	5

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης