

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 30 Ιούλιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τετάρτη, 30 Ιούλιος 2025	00:00	47,10		1	1	1	1	1	1	1	1	1	3
	01:00	43,80		1	1	1	1	1	1	1	1	1	
	02:00	42,02		1	1	1	1	1	1	1	1	1	
	03:00	40,37		1	1	1	1	1	1	1	1	1	
	04:00	38,80		1	1	1	1	1	1	1	1	1	
	05:00	38,73		1	1	1	1	1	1	1	1	1	
	06:00	39,76		1	1	1	1	1	1	1	1	1	
	07:00	43,79		1	1	1	1	1	1	1	1	1	
	08:00	48,49		1	1	1	1	1	1	1	1	1	
	09:00	52,99		1	1	1	1	1	1	1	1	1	3
	10:00	55,51		1	1	1	1	1	1	1	1	1	4
	11:00	57,71		1	1	1	1	1	1	1	1	1	7
	12:00	60,14		1	1	1	1	1	1	1	1	1	8
	13:00	61,98		1	1	1	1	1	1	1	1	1	9
	14:00	62,80		1	1	1	1	1	1	1	1	1	9
	15:00	61,97		1	1	1	1	1	1	1	1	1	9
	16:00	60,95		1	1	1	1	1	1	1	1	1	9
	17:00	60,00		1	1	1	1	1	1	1	1	1	7
	18:00	61,11		1	1	1	1	1	1	1	1	1	7
	19:00	59,98		1	1	1	1	1	1	1	1	1	7
	20:00	59,02		1	1	1	1	1	1	1	1	1	7
	21:00	58,25		1	1	1	1	1	1	1	1	1	6
	22:00	54,08		1	1	1	1	1	1	1	1	1	6
	23:00	50,26		1	1	1	1	1	1	1	1	1	6

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης