

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 3 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Κυριακή, 3 Αύγουστος 2025	00:00	45,21		1	1	1	1	1	1	1	1	1	
	01:00	42,35		1	1	1	1	1	1	1	1	1	
	02:00	40,70		1	1	1	1	1	1	1	1	1	
	03:00	39,34		1	1	1	1	1	1	1	1	1	
	04:00	38,30		1	1	1	1	1	1	1	1	1	
	05:00	38,32		1	1	1	1	1	1	1	1	1	
	06:00	38,71		1	1	1	1	1	1	1	1	1	
	07:00	42,68		1	1	1	1	1	1	1	1	1	
	08:00	46,36		1	1	1	1	1	1	1	1	1	
	09:00	49,50		1	1	1	1	1	1	1	1	1	
	10:00	51,80		1	1	1	1	1	1	1	1	1	
	11:00	53,10		1	1	1	1	1	1	1	1	1	
	12:00	54,97	1	1	1	1	1	1	1	1	1	1	
	13:00	57,08	1	1	1	1	1	1	1	1	1	1	
	14:00	57,16	1	1	1	1	1	1	1	1	1	1	
	15:00	56,21	1	1	1	1	1	1	1	1	1	1	
	16:00	55,99	1	1	1	1	1	1	1	1	1	1	
	17:00	55,97	1	1	1	1	1	1	1	1	1	1	
	18:00	56,76	1	1	1	1	1	1	1	1	1	1	
	19:00	56,13	1	1	1	1	1	1	1	1	1	1	
	20:00	55,57	1	1	1	1	1	1	1	1	1	1	
	21:00	54,01	1	1	1	1	1	1	1	1	1	1	
	22:00	51,61	1	1	1	1	1	1	1	1	1	1	
	23:00	47,78	1	1	1	1	1	1	1	1	1	1	

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης