

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 4 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Δευτέρα, 4 Αύγουστος 2025	00:00	43,81	1	1	1	1	1	1		1	1	1	
	01:00	40,83	1	1	1	1	1	1		1	1	1	
	02:00	39,32	1	1	1	1	1	1		1	1	1	
	03:00	38,57	1	1	1	1	1	1		1	1	1	
	04:00	37,67	1	1	1	1	1	1		1	1	1	
	05:00	37,17	1	1	1	1	1	1		1	1	1	
	06:00	37,72	1	1	1	1	1	1		1	1	1	
	07:00	42,17	1	1	1	1	1	1		1	1	1	
	08:00	46,88	1	1	1	1	1	1		1	1	1	
	09:00	51,21	1	1	1	1	1	1		1	1	1	4
	10:00	54,81	1	1	1	1	1	1		1	1	1	4
	11:00	57,48	1	1	1	1	1	1		1	1	1	6
	12:00	59,37	1	1	1	1	1	1		1	1	1	7
	13:00	61,23	1	1	1	1	1	1		1	1	1	8
	14:00	61,84	1	1	1	1	1	1		1	1	1	8
	15:00	62,45	1	1	1	1	1	1		1	1	1	8
	16:00	61,83	1	1	1	1	1	1		1	1	1	8
	17:00	61,75	1	1	1	1	1	1		1	1	1	8
	18:00	60,82	1	1	1	1	1	1		1	1	1	8
	19:00	59,20	1	1	1	1	1	1		1	1	1	8
	20:00	58,48	1	1	1	1	1	1		1	1	1	8
	21:00	57,61	1	1	1	1	1	1		1	1	1	8
	22:00	54,14	1	1	1	1	1	1		1	1	1	10
	23:00	50,36	1		1	1	1	1		1	1	1	5

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης