

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 5 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τρίτη, 5 Αύγουστος 2025	00:00	46,00	1		1	1	1	1		1	1	1	2
	01:00	43,27	1		1	1	1	1		1	1	1	
	02:00	41,43	1		1	1	1	1		1	1	1	
	03:00	40,35	1		1	1	1	1		1	1	1	
	04:00	39,28	1		1	1	1	1		1	1	1	
	05:00	38,78	1		1	1	1	1		1	1	1	
	06:00	39,90	1		1	1	1	1		1	1	1	
	07:00	43,55	1		1	1	1	1		1	1	1	
	08:00	48,28	1		1	1	1	1		1	1	1	5
	09:00	51,94	1		1	1	1	1		1	1	1	11
	10:00	55,53	1		1		1	1		1	1	1	14
	11:00	57,88	1		1		1	1		1	1	1	10
	12:00	59,28	1		1	1	1	1	1	1	1	1	10
	13:00	60,77	1		1	1	1	1	1	1	1	1	10
	14:00	61,51	1		1	1	1	1	1	1	1	1	10
	15:00	60,73	1		1	1	1	1	1	1	1	1	10
	16:00	60,03	1		1	1	1	1	1	1	1	1	10
	17:00	59,13	1		1	1	1	1	1	1	1	1	10
	18:00	59,43	1		1	1	1	1	1	1	1	1	10
	19:00	58,68	1		1	1	1	1	1	1	1	1	10
	20:00	57,07	1		1	1	1	1	1	1	1	1	7
	21:00	56,18	1		1	1	1	1	1	1	1	1	7
	22:00	53,51	1		1	1	1	1	1	1	1	1	4
	23:00	49,43	1		1	1	1	1	1	1	1	1	

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης