

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 6 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τετάρτη, 6 Αύγουστος 2025	00:00	44,81	1		1	1	1	1	1	1	1	1	
	01:00	41,04	1		1	1	1	1	1	1	1	1	
	02:00	39,54	1		1	1	1	1	1	1	1	1	
	03:00	39,31	1		1	1	1	1	1	1	1	1	
	04:00	38,67	1		1	1	1	1	1	1	1	1	
	05:00	38,27	1		1	1	1	1	1	1	1	1	
	06:00	38,29	1		1	1	1	1	1	1	1	1	
	07:00	41,99	1		1	1	1	1	1	1	1	1	
	08:00	47,25	1		1	1	1	1	1	1	1	1	
	09:00	51,24	1		1	1	1	1	1	1	1	1	3
	10:00	54,86	1		1	1	1	1	1	1	1	1	5
	11:00	56,39	1		1	1	1	1	1	1	1	1	6
	12:00	58,17	1		1	1	1	1	1	1	1	1	6
	13:00	59,63	1	1	1	1	1	1	1	1	1	1	6
	14:00	60,09	1	1	1	1	1	1	1	1	1	1	6
	15:00	59,13	1	1	1	1	1	1	1	1	1	1	6
	16:00	58,35	1	1	1	1	1	1	1	1	1	1	6
	17:00	58,28	1	1	1	1	1	1	1	1	1	1	6
	18:00	58,73	1	1	1	1	1	1	1	1	1	1	6
	19:00	57,15	1		1	1	1	1	1	1	1	1	6
	20:00	56,73	1		1	1	1	1	1	1	1	1	6
	21:00	57,27	1		1	1	1	1	1	1	1	1	6
	22:00	53,54	1		1	1	1	1	1	1	1	1	4
	23:00	50,03	1		1	1	1	1	1	1	1	1	

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης