

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 7 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)		7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000	
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Πέμπτη, 7 Αύγουστος 2025	00:00	46,03	1		1	1	1	1	1	1	1	1	
	01:00	42,54	1		1	1	1	1	1	1	1	1	
	02:00	40,92	1		1	1	1	1	1	1	1	1	
	03:00	40,13	1		1	1	1	1	1	1	1	1	
	04:00	39,62	1		1	1	1	1	1	1	1	1	
	05:00	39,57	1		1	1	1	1	1	1	1	1	
	06:00	40,35	1		1	1	1	1	1	1	1	1	
	07:00	44,21	1		1	1	1	1	1	1	1	1	
	08:00	48,43	1		1	1	1	1	1	1	1	1	3
	09:00	51,92	1		1	1	1	1	1	1	1	1	3
	10:00	55,48	1		1	1	1	1	1	1	1	1	6
	11:00	57,91	1		1	1	1	1	1	1	1	1	8
	12:00	59,17	1		1	1	1	1	1	1	1	1	9
	13:00	60,56	1		1	1	1	1	1	1	1	1	9
	14:00	61,45	1		1	1	1	1	1	1	1	1	9
	15:00	60,80	1		1	1	1	1	1	1	1	1	9
	16:00	60,18	1		1	1	1	1	1	1	1	1	9
	17:00	60,00	1		1	1	1	1	1	1	1	1	9
	18:00	59,63	1		1	1	1	1	1	1	1	1	9
	19:00	59,10	1		1	1	1	1	1	1	1	1	9
	20:00	57,98	1		1	1	1	1	1	1	1	1	9
	21:00	57,94	1		1	1	1	1	1	1	1	1	8
	22:00	56,82	1		1	1	1	1	1	1	1	1	4
	23:00	52,17	1		1	1	1	1	1	1	1	1	3

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης