

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 11 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)		7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000	
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Δευτέρα, 11 Αύγουστος 2025	00:00	48,33	1		1	1	1	1	1	1	1	1	
	01:00	44,41	1		1	1	1	1	1	1	1	1	
	02:00	42,32	1		1	1	1	1	1	1	1	1	
	03:00	41,17	1		1	1	1	1	1	1	1	1	
	04:00	40,54	1		1	1	1	1	1	1	1	1	
	05:00	40,22	1		1	1	1	1	1	1	1	1	
	06:00	41,03	1		1	1	1	1	1	1	1	1	
	07:00	44,90	1		1	1	1	1	1	1	1	1	
	08:00	49,46	1		1		1	1	1	1	1	1	3
	09:00	53,64	1		1	1	1	1	1	1	1	1	8
	10:00	56,95	1		1	1	1	1	1	1	1	1	8
	11:00	58,24	1		1	1	1	1	1	1	1	1	10
	12:00	60,49	1		1	1	1	1	1	1	1	1	11
	13:00	61,52	1		1	1	1	1	1	1	1	1	11
	14:00	61,79	1		1	1	1	1	1	1	1	1	14
	15:00	61,37	1		1	1	1	1	1	1	1	1	14
	16:00	60,93			1	1	1	1	1	1	1	1	14
	17:00	61,46			1	1	1	1	1	1	1	1	14
	18:00	61,37			1	1	1	1	1	1	1	1	14
	19:00	59,68			1	1	1	1	1	1	1	1	14
	20:00	59,19			1	1	1	1	1	1	1	1	14
	21:00	58,04			1	1	1	1	1	1	1	1	14
	22:00	54,91			1	1	1	1	1	1	1	1	12
	23:00	51,44			1	1	1	1	1	1	1	1	7

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης