

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Τετάρτη, 20 Αύγουστος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τετάρτη, 20 Αύγουστος 2025	00:00	46,93		1		1	1	1	1	1	1	1	
	01:00	43,87		1		1	1	1	1	1	1	1	
	02:00	41,82		1		1	1	1	1	1	1	1	
	03:00	40,26		1		1	1	1	1	1	1	1	
	04:00	39,75		1		1	1	1	1	1	1	1	
	05:00	38,91		1		1	1	1	1	1	1	1	
	06:00	40,16		1		1	1	1	1	1	1	1	
	07:00	43,57				1	1	1	1	1	1	1	
	08:00	48,45				1	1	1	1	1	1	1	5
	09:00	52,09		1		1	1	1	1	1	1	1	5
	10:00	55,01		1		1	1	1	1	1	1	1	5
	11:00	56,50		1		1	1	1	1	1	1	1	5
	12:00	58,47		1		1	1	1	1	1	1	1	7
	13:00	59,57		1		1	1	1	1	1	1	1	9
	14:00	59,85		1		1	1	1	1	1	1	1	9
	15:00	59,05		1		1	1	1	1	1	1	1	8
	16:00	57,84		1		1	1	1	1	1	1	1	8
	17:00	57,75		1		1	1	1	1	1	1	1	8
	18:00	57,91		1		1	1	1	1	1	1	1	8
	19:00	57,32		1		1	1	1	1	1	1	1	8
	20:00	57,52		1		1	1	1	1	1	1	1	8
	21:00	57,18		1		1	1	1	1	1	1	1	7
	22:00	54,57		1		1	1	1	1	1	1	1	7
	23:00	50,83		1		1	1	1	1	1	1	1	5

Μισθωμένη ισχύς 14 MW. Δύο φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης