

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 22 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Παρασκευή, 22 Αυγούστου 2025	00:00	44,70		1		1	1	1	1	1	1	1	
	01:00	48,80		1		1	1	1	1	1	1	1	
	02:00	40,30		1		1	1	1	1	1	1	1	
	03:00	38,90		1		1	1	1	1	1	1	1	
	04:00	38,90		1		1	1	1	1	1	1	1	
	05:00	38,40		1		1	1	1	1	1	1	1	
	06:00	43,50		1		1	1	1	1	1	1	1	
	07:00	46,80		1		1	1	1	1	1	1	1	
	08:00	57,50		1		1	1	1	1	1	1	1	3
	09:00	58,30		1		1	1	1	1	1	1	1	6
	10:00	58,60		1		1	1	1	1	1	1	1	13
	11:00	60,70		1		1	1	1	1	1	1	1	13
	12:00	63,70		1		1	1	1	1	1	1	1	16
	13:00	64,10		1		1	1	1	1	1	1	1	13
	14:00	63,20		1		1	1	1	1	1	1	1	13
	15:00	61,70		1		1	1	1	1	1	1	1	12
	16:00	61,05		1		1	1	1	1	1	1	1	11
	17:00	61,05		1		1	1	1	1	1	1	1	11
	18:00	60,85		1		1	1	1	1	1	1	1	11
	19:00	59,55		1		1	1	1	1	1	1	1	10
	20:00	61,70		1		1	1	1	1	1	1	1	10
	21:00	59,70		1		1	1	1	1	1	1	1	10
	22:00	59,20		1		1	1	1	1	1	1	1	10
	23:00	53,16		1		1	1	1	1	1	1	1	9

Μισθωμένη ισχύς 14 MW. Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης