

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 24 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Κυριακή, 24 Αυγούστου 2025	00:00	48,70				1	1	1	1	1	1	1	
	01:00	45,63				1	1	1	1	1	1	1	
	02:00	43,17				1	1	1	1	1	1	1	
	03:00	41,49				1	1	1	1	1	1	1	
	04:00	40,12				1	1	1	1	1	1	1	
	05:00	39,21				1	1	1	1	1	1	1	
	06:00	40,38				1	1	1	1	1	1	1	
	07:00	43,83				1	1	1	1	1	1	1	
	08:00	48,86				1	1	1	1	1	1	1	5
	09:00	52,30				1	1	1	1	1	1	1	8
	10:00	54,54				1	1	1	1	1	1	1	10
	11:00	56,17				1	1	1	1	1	1	1	13
	12:00	58,68				1	1	1	1	1	1	1	14
	13:00	60,26				1	1	1	1	1	1	1	15
	14:00	60,15				1	1	1	1	1	1	1	14
	15:00	59,34			1	1	1	1	1	1	1	1	11
	16:00	57,81			1	1	1	1	1	1	1	1	11
	17:00	58,25			1	1	1	1	1	1	1	1	11
	18:00	58,91			1	1	1	1	1	1	1	1	11
	19:00	57,15			1	1	1	1	1	1	1	1	11
	20:00	57,66			1	1	1	1	1	1	1	1	11
	21:00	57,00			1	1	1	1	1	1	1	1	10
	22:00	54,45			1	1	1	1	1	1	1	1	10
	23:00	51,06			1	1	1	1	1	1	1	1	8

Μισθωμένη ισχύς 14 MW. Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης