

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 25 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Δευτέρα, 25 Αυγούστου 2025	00:00	45,60			1	1	1	1	1	1	1	1	
	01:00	42,60			1	1	1	1	1	1	1	1	
	02:00	41,30			1	1	1	1	1	1	1	1	
	03:00	39,20			1	1	1	1	1	1	1	1	
	04:00	38,20			1	1	1	1	1	1	1	1	
	05:00	38,50			1	1	1	1	1	1	1	1	
	06:00	42,68			1	1	1	1	1	1	1	1	
	07:00	47,00			1	1	1	1	1	1	1	1	
	08:00	50,00			1	1	1	1	1	1	1	1	
	09:00	53,00		1		1	1	1	1	1	1	1	2
	10:00	55,50		1		1	1	1	1	1	1	1	4
	11:00	55,50		1		1	1	1	1	1	1	1	4
	12:00	56,85		1		1	1	1	1	1	1	1	6
	13:00	57,70		1		1	1	1	1	1	1	1	6
	14:00	57,40		1		1	1	1	1	1	1	1	6
	15:00	56,80		1		1	1	1	1	1	1	1	6
	16:00	56,80		1		1	1	1	1	1	1	1	6
	17:00	56,90		1		1	1	1	1	1	1	1	6
	18:00	56,90		1		1	1	1	1	1	1	1	6
	19:00	56,90		1		1	1	1	1	1	1	1	6
	20:00	57,00		1		1	1	1	1	1	1	1	6
	21:00	54,60		1		1	1	1	1	1	1	1	6
	22:00	51,90		1		1	1	1	1	1	1	1	6
	23:00	47,10		1		1	1	1	1	1	1	1	5

Μισθωμένη ισχύς 14 MW. Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης