

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Τετάρτη, 27 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Τετάρτη, 27 Αυγούστου 2025	00:00	43,70		1		1	1	1	1	1	1	1	8
	01:00	40,70		1		1	1	1	1	1	1	1	
	02:00	39,00		1		1	1	1	1	1	1	1	
	03:00	37,90		1		1	1	1	1	1	1	1	
	04:00	37,40		1		1	1	1	1	1	1	1	
	05:00	37,90		1		1	1	1	1	1	1	1	
	06:00	40,65		1		1	1	1	1	1	1	1	
	07:00	44,30		1		1	1	1	1	1	1	1	
	08:00	50,55		1		1	1	1	1	1	1	1	
	09:00	58,50		1		1	1	1	1	1	1	1	2
	10:00	59,95		1		1	1	1	1	1	1	1	2
	11:00	54,00		1		1	1	1	1	1	1	1	2
	12:00	54,25		1		1	1	1	1	1	1	1	4
	13:00	55,90		1		1	1	1	1	1	1	1	4
	14:00	54,00		1		1	1	1	1	1	1	1	4
	15:00	53,40		1		1	1	1	1	1	1	1	4
	16:00	53,40		1		1	1	1	1	1	1	1	4
	17:00	54,00		1		1	1	1	1	1	1	1	4
	18:00	54,00		1		1	1	1	1	1	1	1	4
	19:00	54,80		1		1	1	1	1	1	1	1	4
	20:00	54,30		1		1	1	1	1	1	1	1	4
	21:00	51,50		1		1	1	1	1	1	1	1	4
	22:00	49,70		1		1	1	1	1	1	1	1	
	23:00	47,42		1		1	1	1	1	1	1	1	

Μισθωμένη ισχύς 14 MW. Ένα φορητό H/Z βρίσκεται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης