

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Σάββατο, 30 Αυγούστου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x30)
Σάββατο, 30 Αυγούστου 2025	00:00	41,72		1		1	1	1	1	1	1	1	
	01:00	39,11		1		1	1	1	1	1	1	1	
	02:00	37,23		1		1	1	1	1	1	1	1	
	03:00	36,03		1		1	1	1	1	1	1	1	
	04:00	35,10		1		1	1	1	1	1	1	1	
	05:00	34,48		1		1	1	1	1	1	1	1	
	06:00	36,07		1		1	1	1	1	1	1	1	
	07:00	40,44		1		1	1	1	1	1	1	1	
	08:00	44,93		1		1	1	1	1	1	1	1	
	09:00	48,45		1		1	1	1	1	1	1	1	
	10:00	51,41		1		1	1	1	1	1	1	1	1
	11:00	52,06		1	1	1	1	1	1	1	1	1	5
	12:00	53,37			1	1	1	1	1	1	1	1	11
	13:00	54,81			1	1	1	1	1	1	1	1	10
	14:00	54,93			1	1	1	1	1	1	1	1	14
	15:00	53,54			1	1	1	1	1	1	1	1	14
	16:00	53,11			1		1	1	1	1	1	1	14
	17:00	52,96			1		1	1	1	1	1	1	14
	18:00	53,16			1		1	1	1	1	1	1	14
	19:00	53,41			1		1	1	1	1	1	1	14
	20:00	54,22			1		1	1	1	1	1	1	14
	21:00	53,39			1		1	1	1	1	1	1	9
	22:00	51,14			1		1	1	1	1	1	1	6
	23:00	47,19			1		1	1	1	1	1	1	2

Μισθωμένη ισχύς 14 MW. Ένα φορητό Η/Ζ βρίσκεται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης